

OHA - Drinking Water Program - Turbidity Monitoring Report form County
Clackamas

TURBIDITY MONITORING REPORT FORM (bag cartridge)

SYSTEM NAME RHODODENDRON WATER ID# 4100702

Sep-25

DAY	Cartridge Turbidity null values = system off A2						WPT HIGHEST READING
	12-4	4-8	8-12	12-16	16-20	20-24	NTU
1	0.011	0.011	0.011	0.011	0.011	0.011	0.011
2	0.011	0.011		0.011	0.011	0.026	0.026
3			0.011	0.011	0.016		0.016
4	0.011	0.011	0.011		0.010	0.011	0.011
5	0.011	0.021		0.011	0.008	0.011	0.021
6			0.011	0.011	0.015	0.033	0.033
7	0.011	0.011			0.011	0.011	0.011
8	0.012			0.011	0.011	0.015	0.015
9		0.016	0.011	0.011		0.026	0.026
10	0.011	0.011			0.011	0.011	0.011
11			0.025	0.011	0.011		0.025
12				0.026	0.011	0.011	0.026
13			0.026	0.026	0.011	0.011	0.026
14	0.011			0.011	0.011	0.011	0.011
15			0.026	0.011	0.011	0.024	0.026
16					0.011	0.011	0.011
17						0.011	0.011
18	0.011				0.011	0.011	0.011
19	0.015				0.011	0.011	0.015
20	0.026				0.011	0.011	0.026
21	0.011				0.011	0.011	0.011
22	0.011						0.011
23	0.011						0.011
24			0.011	0.011			0.011
25			0.015	0.011	0.011		0.015
26				0.014	0.011	0.011	0.014
27				0.018	0.011	0.011	0.018
28	0.011					0.015	0.015
29	0.011						0.011
30		0.011	0.011				0.011
31							0

OHA - Drinking Water Program - Turbidity Monitoring Report form County Clackamas
RHODODENDRON WATER ASSOCIATION PWS ID# 4100702
SURFACE WATER QUALITY DATA

Sep-25

DATE	TIME	NE RESIDU	CONTACT TIME	ACTUAL CT	WATER TEMP	WATER PH	REQUIRE D	PEAK HOURLY FLOW	CT MET
		PPM	minutes	C x T	C°	-log(h)	reg equ	GPM	YES/NO
9/1/2025	16:00	0.85	404	343	11.3	7.5	42	74	YES
9/2/2025	15:00	0.86	397	340	11.2	7.5	42	76	YES
9/3/2025	6:00	0.84	496	415	11.9	7.5	40	61	YES
9/4/2025	20:00	0.80	458	366	12.2	7.5	39	66	YES
9/5/2025	18:00	0.80	524	419	12.3	7.5	38	57	YES
9/6/2025	9:00	0.95	493	469	12.3	7.5	39	61	YES
9/7/2025	18:00	0.86	539	465	11.8	7.5	40	56	YES
9/8/2025	14:00	0.86	464	401	11.3	7.5	41	65	YES
9/9/2025	6:00	0.89	535	475	11.4	7.5	41	56	YES
9/10/2025	20:00	0.89	551	490	11.4	7.4	40	54	YES
9/11/2025	10:00	0.92	553	507	11.2	7.1	37	54	YES
9/12/2025	17:00	0.92	532	492	11.0	7.1	37	56	YES
9/13/2025	19:00	0.94	491	462	10.9	7.2	38	61	YES
9/14/2025	13:00	0.95	486	462	10.8	7.3	40	62	YES
9/15/2025	16:00	0.95	507	480	10.0	7.3	42	59	YES
9/16/2025	16:00	0.94	527	496	10.6	7.2	40	57	YES
9/17/2025	19:00	0.94	435	409	10.8	7.2	39	69	YES
9/18/2025	18:00	0.94	549	516	10.8	7.2	39	55	YES
9/19/2025	15:00	0.95	443	419	10.7	7.1	38	68	YES
9/20/2025	15:00	0.93	476	445	10.9	7.1	38	63	YES
9/21/2025	19:00	0.92	504	464	10.4	7.1	38	60	YES
9/22/2025	23:00	0.87	608	530	10.4	7.1	38	49	YES
9/23/2025	0:00	0.87	623	543	10.1	7.1	39	48	YES
9/24/2025	6:00	0.86	509	436	10.3	7.0	38	59	YES
9/25/2025	10:00	0.85	475	404	10.2	7.0	38	63	YES
9/26/2025	14:00	0.73	500	364	9.4	7.0	39	60	YES
9/27/2025	16:00	0.84	455	384	9.5	7.0	39	66	YES
9/28/2025	22:00	0.80	523	417	9.8	7.0	38	57	YES
9/29/2025	0:00	0.79	569	447	9.9	7.0	38	53	YES
9/30/2025	5:00	0.78	516	402	9.6	7.0	39	58	YES
95% of Daily Turbidity Readings < 1 ntu					yes	CL ₂ RESID AT Entry Point ALWAYS >0.2 MG/L			yes
All Daily Turbidity Readings < 5 NTU					yes	CT's Met Everyday?			yes

phone 503-310-9262

SIGNATURE:

David Jacob

PRINT NAME

David Jacob

DATE

5-Oct-25

CERT # 3675