

OHA - Drinking Water Program - Turbidity Monitoring Report form County
Clackamas

TURBIDITY MONITORING REPORT FORM (bag cartridge)

SYSTEM NAME RHODODENDRON WATER ID# 4100702

Oct-25

DAY	Cartridge Turbidity null values = system off A2						WPT	HIGHEST READING
	12-4	4-8	8-12	12-16	16-20	20-24		NTU
1	0.026	0.026	0.026	0.023	0.011			0.026
2						0.018		0.018
3	0.022	0.028						0.028
4		0.026	0.011	0.011		0.026		0.026
5					0.011	0.011		0.011
6								0.000
7	0.015					0.026		0.026
8				0.018	0.013	0.011		0.018
9						0.025		0.025
10	0.018	0.014	0.011					0.018
11				0.018	0.018	0.018		0.018
12	0.033					0.040		0.040
13	0.030	0.022	0.033			0.033		0.033
14				0.018	0.018	0.019		0.019
15	0.026					0.026		0.026
16		0.020	0.018	0.021				0.021
17					0.018	0.018		0.018
18	0.026				0.026	0.019		0.026
19	0.026	0.033	0.026	0.024	0.033			0.033
20			0.021	0.018	0.018	0.018		0.021
21	0.033							0.033
22		0.021	0.018					0.021
23				0.029	0.018	0.018		0.029
24	0.028							0.028
25		0.021	0.019	0.026	0.026	0.027		0.027
26	0.040	0.040			0.034	0.027		0.040
27	0.027	0.026	0.040					0.040
28			0.019	0.019	0.033	0.033		0.033
29								0.000
30	0.027	0.023	0.033					0.033
31		0.032	0.031	0.031	0.033			0.033

12/6 and 12/29 reported 0.00
turbidity. No indication
treatment was off.

OHA - Drinking Water Program - Turbidity Monitoring Report form County Clackamas
 RHODODENDRON WATER ASSOCIATION PWS ID# 4100702
 SURFACE WATER QUALITY DATA

Oct-25

DATE	TIME	NE RESIDU	CONTACT TIME	ACTUAL CT	WATER TEMP	WATER PH	REQUIRE D	PEAK HOURLY FLOW	CT MET
		PPM	minutes	C x T	C°	-log(h)	reg equ	GPM	YES/NO
10/1/2025	13:00	0.78	575	449	9	7.0	39	52	YES
10/2/2025	20:00	0.78	556	432	9	7.0	39	54	YES
10/3/2025	20:00	0.77	1490	1140	9	7.0	39	20	YES
10/4/2025	8:00	0.76	540	409	9	7.0	40	56	YES
10/5/2025	16:00	0.77	474	365	9	7.0	41	63	YES
10/6/2025	21:00	0.81	611	494	9	7.0	40	49	YES
10/7/2025	0:00	0.82	655	539	9	7.0	41	46	YES
10/8/2025	12:00	0.82	500	412	9	7.0	41	60	YES
10/9/2025	22:00	0.87	571	498	9	7.0	41	53	YES
10/10/2025	0:00	0.87	635	550	9	7.0	42	47	YES
10/11/2025	11:00	0.83	496	410	8	7.0	42	61	YES
10/12/2025	11:00	0.71	711	503	9	7.0	41	42	YES
10/13/2025	4:00	0.47	652	306	7	7.0	43	46	YES
10/14/2025	17:00	0.45	553	251	7	7.0	45	54	YES
10/15/2025	12:00	0.54	1666	896	7	7.0	45	18	YES
10/16/2025	7:00	0.76	605	460	7	7.0	47	50	YES
10/17/2025	18:00	0.78	498	388	7	7.0	45	60	YES
10/18/2025	11:00	0.78	1253	979	7	7.0	46	24	YES
10/19/2025	1:00	0.61	630	384	7	7.0	44	48	YES
10/20/2025	12:00	0.48	504	241	7	7.0	43	60	YES
10/21/2025	15:00	0.46	1588	727	7	7.0	43	19	YES
10/22/2025	7:00	0.55	589	324	7	7.0	43	51	YES
10/23/2025	19:00	0.62	519	322	7	7.0	44	58	YES
10/24/2025	17:00	0.70	1469	1026	8	7.0	43	20	YES
10/25/2025	8:00	0.78	512	400	7	7.0	44	59	YES
10/26/2025	19:00	1.28	505	647	7	6.9	48	59	YES
10/27/2025	18:00	1.27	1418	1794	7	6.9	49	21	YES
10/28/2025	9:00	1.30	560	726	6	6.9	49	54	YES
10/29/2025	23:00	1.35	700	943	7	6.9	48	43	YES
10/30/2025	3:00	1.47	623	913	6	6.9	49	48	YES
10/31/2025	9:00	0.88	581	511	6	6.9	46	52	YES
95% of Daily Turbidity Readings < 1 ntu					yes	CL ₂ RESID AT Entry Point ALWAYS >0.2 MG/L			yes
All Daily Turbidity Readings < 5 NTU					yes	CT's Met Everyday?			yes

phone 503-310-9262

SIGNATURE:

David Jacob

PRINT NAME

David Jacob

DATE

11-Mar-25

CERT # 3675