

OHA - Drinking Water Program - Turbidity Monitoring Report form County
Clackamas

TURBIDITY MONITORING REPORT FORM (bag cartridge)

SYSTEM NAME RHODODENDRON WATER ID# 4100702

Nov-25

DAY	Cartridge Turbidity null values = system off A2						WPT HIGHEST READING
	12-4	4-8	8-12	12-16	16-20	20-24	NTU
1	0.033	0.033	0.033	0.000	0.000	0.000	0.033
2	0.048	0.062	0.062	0.058	0.050	0.040	0.062
3	0.040	0.040	0.040	0.040	0.040	0.048	0.048
4	0.048	0.042	0.040	0.040	0.040	0.040	0.048
5			0.048	0.040	0.047	0.048	0.048
6			0.040	0.040	0.040	0.040	0.040
7	0.048	0.048	0.048	0.048	0.040	0.040	0.048
8	0.029	0.026	0.026	0.032	0.033	0.442	0.442
9	0.029	0.026	0.027	0.028	0.028	0.050	0.050
10	0.034	0.033	0.031	0.033	0.027	0.028	0.034
11	0.035	0.033	0.033	0.033	0.033	0.035	0.035
12	0.029	0.033	0.033	0.033	0.033	0.035	0.035
13	0.035	0.033	0.033	0.033	0.033	0.030	0.035
14	0.190	0.119	0.065	0.040	0.033	0.037	0.190
15	0.313	0.323	0.390	0.216	0.272	0.275	0.390
16	0.190	0.190	0.871	0.690	0.543	0.376	0.871
17	0.313	0.275	0.216	0.390	0.543	0.275	0.543
18	0.037	0.190	0.216	0.390	0.216	0.037	0.390
19	0.037	0.275	0.543	0.323	0.323	0.275	0.543
20	0.323	0.313	0.216	0.323	0.216	0.216	0.323
21	0.048	0.323	0.216	0.390	0.390	0.216	0.390
22	0.047	0.047	0.047	0.047	0.048	0.047	0.048
23	0.074	0.077	0.061	0.061	0.061	0.051	0.077
24	0.032	0.032	0.032	0.233	0.097	0.081	0.233
25	0.032	0.030	0.030	0.031	0.032	0.032	0.032
26	0.036	0.032	0.032	0.033	0.035	0.033	0.036
27	0.032	0.032	0.033	0.034	0.033	0.038	0.038
28	0.033	0.036	0.037	0.037	0.033	0.032	0.037
29	0.026	0.026	0.026	0.032	0.032	0.033	0.033
30	0.027	0.034	0.042	0.026	0.026	0.026	0.042
31							

OHA - Drinking Water Program - Turbidity Monitoring Report form County Clackamas
 RHODODENDRON WATER ASSOCIATION PWS ID# 4100702
 SURFACE WATER QUALITY DATA

Nov-25

DATE	TIME	NE RESIDU	CONTACT TIME	ACTUAL CT	WATER TEMP	WATER PH	REQUIRE D	PEAK HOURLY FLOW	CT MET
		PPM	minutes	C x T	C°	-log(h)	reg equ	GPM	YES/NO
11/1/2025	14:00	0.75	367	275	7.5	6.8	42	82	YES
11/2/2025	16:00	0.89	376	334	7.3	6.8	42	80	YES
11/3/2025	21:00	0.85	396	338	7.3	6.8	42	76	YES
11/4/2025	22:00	0.89	416	368	7.4	6.8	42	72	YES
11/5/2025	10:00	0.79	378	299	7.5	6.8	41	79	YES
11/6/2025	12:00	0.75	373	280	7.4	6.8	42	80	YES
11/7/2025	19:00	0.75	363	272	7.5	6.8	41	83	YES
11/8/2025	19:00	0.84	344	290	7.3	6.8	42	87	YES
11/9/2025	22:00	1.12	408	459	7.4	6.8	44	73	YES
11/10/2025	1:00	1.28	423	539	7.6	6.8	44	71	YES
11/11/2025	0:00	1.35	417	563	7.5	6.8	44	72	YES
11/12/2025	7:00	1.64	389	637	7.6	6.8	45	77	YES
11/13/2025	13:00	1.50	381	572	7.8	6.8	43	79	YES
11/14/2025	19:00	1.42	380	540	8.0	6.8	42	79	YES
11/15/2025	20:00	1.40	354	496	8.1	6.8	42	85	YES
11/16/2025	12:00	1.37	322	441	8.1	6.8	42	93	YES
11/17/2025	11:00	1.44	306	441	7.7	6.7	43	98	YES
11/18/2025	9:00	1.44	646	931	6.8	6.7	45	46	YES
11/19/2025	7:00	1.49	375	560	6.2	6.7	47	80	YES
11/20/2025	11:00	1.57	387	608	6.3	6.7	47	77	YES
11/21/2025	17:00	1.60	382	613	5.8	6.7	48	78	YES
11/22/2025	16:00	1.69	362	610	5.7	6.6	48	83	YES
11/23/2025	17:00	1.56	378	590	5.9	6.6	47	79	YES
11/24/2025	19:00	1.31	372	489	6.0	6.6	46	81	YES
11/25/2025	21:00	1.26	380	481	5.7	6.6	46	79	YES
11/26/2025	23:00	0.95	390	369	6.2	6.6	44	77	YES
11/27/2025	23:00	1.14	390	444	5.9	6.6	45	77	YES
11/28/2025	19:00	0.94	356	333	6.5	6.7	43	84	YES
11/29/2025	8:00	0.97	612	594	6.2	6.7	44	49	YES
11/30/2025	9:00	1.08	656	707	5.1	6.7	48	46	YES
95% of Daily Turbidity Readings < 1 ntu					yes	CL ₂ RESID AT Entry Point ALWAYS >0.2 MG/L			yes
All Daily Turbidity Readings < 5 NTU					yes	CT's Met Everyday?			yes

phone 503-310-9262

SIGNATURE:

David Jacob

PRINT NAME

David Jacob

DATE

7-Dec-25

CERT # 3675