

ID #: 41 00703

Month/Year: June 2023

DAY	12 AM (NTU)	4 AM (NTU)	8 AM (NTU)	NOON (NTU)	4 PM (NTU)	8 PM (NTU)	Highest Reading (NTU)	Peak Hourly Flow (GPM)
1	.20							
2	.21							
3	.19							
4	.25							360
5	.22							352
6	.22							353
7	.3							354
8	.19							361
9	.19							361
10	.18							355
11	.21							357
12	.18							352
13	.13							352
14	.34							355
15	.17							360
16	.16							353
17	.53							363
18	.5							354
19	.16							358
20	.14							355
21	.18							357
22	.1							354
23	.1							349
24	.14							362
25	.59							360
26	.20							370
27	.16							375
28	.28							359
29	.09							361
30	.15							356
31								356
								352
								357

Monthly Summary (Answer Yes or No)

CT's met everyday? (see back) <input checked="" type="checkbox"/> Yes / <input type="checkbox"/> No	All Cl <sub>2</sub> residual at entry point ≥ 0.2 mg/l? <input checked="" type="checkbox"/> Yes / <input type="checkbox"/> No	Cl <sub>2</sub> residual measured in 95% of distribution samples? <input checked="" type="checkbox"/> Yes / <input type="checkbox"/> No
---	--	--

PRINTED NAME: Gary Chamberlin

SIGNATURE: *[Handwritten Signature]*

DATE: 7/05/2023

PHONE #: (541)893-6141

CERT #: 7025

Flow Sand/Cartridge/Membrane/DE Filtration  
of turbidity readings ≤ 1 NTU?  
of turbidity readings < 5 NTU?  Yes /  No

Scanned & certified  
7-6-23

Oregon DHS - Drinking Water Program - Surface Water Quality Data Form

System Name: *City of Richmond* ID #: *41 00703* Month/Year: *June, 2023*

Date / Time	Minimum Cl <sub>2</sub> Residual at 1 <sup>st</sup> User (C) ppm or mg/L	Contact Time (T) minutes	Actual CT CXT	Temp °C	pH	Required CT Use tables	CT Met? Yes / No
1/	.33	561	168	13.5	7.0	35	Y
2/	.38	573	171	14.0	6.9	35	
3/	.25	572	108	14.7	6.8	23	
4/	.34	570	171	15.1	6.9	23	
5/	.4	559	223	15.2	6.9	23	
6/	.51	559	279	14.7	7.2	24	
7/	.5	569	284	15.3	6.9	24	
8/	.69	565	339	15.2	6.9	24	
9/	.48	573	229	15.1	7.0	23	
10/	.42	573	229	15.2	6.8	23	
11/	.35	569	170	15.8	6.8	23	
12/	.43	561	224	15.7	6.7	23	
13/	.51	572	286	15.7	6.9	24	
14/	.52	556	278	15.7	7.0	24	
15/	.52	570	285	15.2	6.9	24	
16/	.56	564	282	14.6	6.8	30	
17/	.74	569	398	15.2	6.8	20	
18/	.84	565	452	14.5	7.7	44	
19/	.78	570	399	13.7	6.9	31	
20/	.51	578	289	13.1	6.9	30	
21/	.45	558	223	13.1	6.9	29	
22/	.43	561	241	13.4	7.2	35	
23/	.43	545	218	14.0	7.1	35	
24/	.51	538	274	13.9	6.9	30	
25/	.50	562	281	16.2	7.1	24	
26/	.53	559	279	15.0	7.0	24	
27/	.63	567	340	15.2	7.0	24	
28/	.60	567	340	15.3	7.0	24	
29/	.38	573	217	15.4	6.8	20	
30/	.39	565	169	15.3	7.0	23	
31/							