

DAY	12 AM (NTU)	4 AM (NTU)	8 AM (NTU)	NOON (NTU)	4 PM (NTU)	8 PM (NTU)	Highest Reading (NTU)	Peak Hourly Flow (GPM)	
1	.69								
2	.30								
3	.42								
4	.68							340	
5	.41							344	
6	.36							353	
7	.41							358	
8	.35							354	
9	D.E	Flow meter stopped working during							337
10	.39							336	
11	.34							343	
12	.35								
13	.66							340	
14	.65							339	
15	.48							341	
16	.94							338	
17	.70							338	
18	.50							336	
19	.51							336	
20	.60							344	
21	.49							337	
22	.37							338	
23	1.07							346	
24	.83							322	
25	.79							499	
26	.43							490	
27	.61							564	
28	.41							351	
29	.50							340	
30	.44							350	
31	.45							347	
								338	
								342	
								342	

Met on ALL Days  
 Bot Day flow meter  
 was down  
*[Signature]*

Monthly Summary (Answer Yes or No)

GT's met everyday? (see back)  Yes /  No

All Cl<sub>2</sub> residual at entry point > 0.2 mg/l?  Yes /  No

Cl<sub>2</sub> residual measured in 95% of distribution samples?  Yes /  No

Flow Sand/Cartridge/Membrane/DE Filtration

of turbidity readings ≤ 1 NTU?  Yes /  No

turbidity readings < 5 NTU  Yes /  No

PRINTED NAME: **Gary Chamberlin**

SIGNATURE: *[Signature]*

PHONE #: **(341)893-6141**

DATE: **4/8/2024**

CERT #: **7025**

Oregon DHS - Drinking Water Program - Surface Water Quality Data Form

System Name:

City of Richland

ID #: 41 00 703

Month/Year: Mar 2014

Date/Time	Minimum Cl <sub>2</sub> Residual at 1 <sup>st</sup> User (C) ppm or mg/L	Contact Time (T) minutes	Actual CT CXT	Temp °C	pH	Required CT Use tables	CT Met? Yes / No
1/	.43	594	255	7.0	7.7	66	Yes
2/	.46	587	270	7.6	7.7	66	
3/	.46	572	263	6.3	7.6	66	
4/	.44	564	248	6.1	7.5	55	
5/	.49	570	279	6.4	7.6	55	
6/	.39	599	233	6.2	7.4	55	
7/	.41	601	246	6.1	7.6	55	
8/	.50	588	294	5.8	7.5	55	
9/	flow meter went out and restarted it			O.E			
10/	.42	594	249	5.9	7.0	46	
11/	.43	594	255	8.2	7.2	46	
12/	.48	592	284	7.3	6.9	46	
13/	.50	597	298	7.2	7.2	46	
14/	.44	597	280	6.9	7.0	46	
15/	.46	601	276	7.0	6.9	46	
16/	.60	601	360	8.4	6.9	48	
17/	.47	587	275	8.7	6.9	46	
18/	.49	599	293	8.2	6.8	46	
19/	.48	597	286	8.4	7.1	46	
20/	.55	583	320	7.9	6.8	48	
21/	.50	627	313	9.7	7.0	46	
22/	.49	252	123	9.1	7.0	46	
23/	.41	412	168	9.5	7.1	46	
24/	.45	358	161	9.4	6.9	46	
25/	.38	575	218	8.8	7.0	46	
26/	.36	594	213	8.8	6.8	46	
27/	.32	577	184	8.4	6.7	46	
28/	.36	582	209	8.3	6.9	46	
29/	.36	597	214	8.2	6.8	46	
30/	.40	590	236	9.0	6.8	46	
31/	.42	590	247	8.4	6.9	46	

Sub maintenance <sup>work of</sup> had family emergency on the 8<sup>th</sup> left to Boise, recalibrated PH reader on 8<sup>th</sup> on the 26<sup>th</sup> inlet side .43 @ 8pm