

OHA - Drinking Water Services - Surface Water Quality Data Form

Slow Sand, Membrane, Diatomaceous Earth Filtration, or Unfiltered Systems

County: Tillamook

Month/Year: DEC. 2021

System Name: Rockaway Beach Water Dist		ID#: 41 00708		WTP : TP -		WTP-A		
Day		12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the day ¹ [NTU]
1		0.02	0.02	0.02	0.02	0.02	0.02	0.02
2		0.02	0.02	0.02	0.02	0.03	0.02	0.03
3		0.03	0.02	0.03	0.02	0.03	0.03	0.03
4		0.03	0.03	0.03	0.03	0.03	0.03	0.03
5		0.03	off	off	0.02	0.02	0.02	0.03
6		0.02	0.02	0.03	0.03	0.02	0.02	0.03
7		0.02	off	off	off	0.03	0.02	0.03
8		0.02	0.02	0.02	0.02	0.03	0.02	0.03
9		0.02	0.02	off	off	off	off	0.02
10		off	off	0.02	0.02	0.02	0.03	0.03
11		0.05	0.11	0.02	0.05	off	off	0.11
12		off	off	0.03	0.03	0.03	0.03	0.03
13		0.03	0.04	0.03	0.02	0.02	0.03	0.04
14		0.03	0.03	0.03	0.03	off	0.02	0.03
15		0.02	0.02	0.02	0.02	0.03	0.02	0.03
16		0.03	0.02	0.02	0.02	0.02	0.02	0.03
17		0.02	0.02	0.03	0.03	0.03	0.07	0.07
18		0.02	0.02	0.02	0.03	0.03	0.03	0.03
19		0.03	0.03	0.04	0.03	0.02	0.02	0.04
20		0.02	off	off	0.03	0.02	0.03	0.03
21		0.03	0.02	0.03	0.03	0.03	0.03	0.03
22		0.03	0.03	0.03	0.02	0.02	off	0.03
23		0.03	0.03	0.03	0.04	0.03	0.03	0.04
24		0.03	0.03	0.03	0.02	0.02	0.03	0.03
25		0.03	0.02	0.02	0.02	0.02	0.03	0.03
26		0.02	0.03	0.02	0.03	0.03	0.02	0.03
27		0.02	0.03	0.02	0.02	0.03	0.03	0.03
28		0.03	0.02	0.02	0.03	0.03	off	0.03
29		off	0.02	0.03	0.02	0.03	0.02	0.03
30		0.02	0.02	0.03	0.03	0.02	0.02	0.03
31		0.03	0.03	0.02	0.03	0.02	0.03	0.03
Slow Sand/Membrane/DE Filtration/Unfiltered					Monthly Summary (Answer Yes or No)			
95% of daily turbidity readings ≤ 1 NTU? ²			Yes	CT's met everyday?		All Cl ₂ residual at entry point ≥ 0.2 mg/l?		
All daily turbidity readings ≤ 5 NTU?			Yes	Yes		Yes		
Note				PRINTED NAME: <i>Julie Shepard</i>				
				SIGNATURE: <i>S. Shepard</i>				
				PHONE #: (503) 374-0586				
				CERT #: <i>Q629</i>				

¹ Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in columns 12 AM through 8 PM may notcorrespond to continuous readings' maximum. ² Filtered systems only.

OHA - Drinking Water Services - Surface Water Quality Data Form

WTP- :

WTP-A

Rockaway Beach

Disinfection Giardia

System Name:

Water Dist.

ID#: 41 00708

Month/Year:

Log Inactiv:

0.5

Date / Time	Minimum Cl ₂ Residual at 1st User (C) ³	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? ³	Peak Hourly Demand Flow
	[ppm or mg/L]	[minutes]	C X T	[° C]		formula	Yes / No	[GPM]
1 15:11	1.50	31	46.5	11.4	7.90	25.5	YES	375
2 8:51	1.41	31	43.7	11.5	7.90	25.1	YES	400
3 20:46	1.41	31	43.7	9.5	8.00	29.8	YES	375
4 8:02	1.47	31	45.6	10.2	7.90	27.6	YES	375
5 16:04	1.43	31	44.3	9.9	7.80	27.0	YES	375
6 9:03	1.57	31	48.7	9.1	7.90	30.1	YES	375
7 17:51	1.58	31	49.0	10.4	8.00	28.6	YES	350
8 12:12	1.48	31	45.9	10.6	7.90	26.9	YES	350
9 4:39	1.55	31	48.1	9.6	7.90	29.0	YES	350
10 11:55	1.55	31	48.1	9.3	7.90	29.6	YES	300
11 11:00	1.34	31	41.5	10.2	7.80	26.2	YES	300
12 13:03	1.59	31	49.3	9.7	7.50	25.1	YES	400
13 12:53	1.76	31	54.6	9.1	7.70	28.6	YES	400
14 5:14	1.79	31	55.5	8.9	7.80	30.2	YES	400
15 20:11	1.67	31	51.8	9.0	7.80	29.5	YES	400
16 13:57	1.65	31	51.2	9.1	7.80	29.3	YES	200
17 1:08	1.62	31	50.2	9.2	7.70	28.0	YES	400
18 9:03	1.70	31	52.7	9.9	7.90	28.9	YES	400
19 10:40	1.57	31	48.7	9.1	7.70	28.0	YES	400
20 18:37	1.47	31	45.6	10.0	7.70	26.0	YES	350
21 14:48	1.69	31	52.4	10.2	7.80	27.3	YES	350
22 17:01	1.76	31	54.6	10.6	7.80	26.8	YES	300
23 15:50	1.63	31	50.5	9.9	7.50	24.9	YES	350
24 12:45	1.60	31	49.6	9.4	7.70	27.5	YES	420
25 20:27	1.47	31	45.6	8.7	7.80	29.5	YES	420
26 23:11	1.65	31	51.2	7.2	7.80	33.3	YES	400
27 16:21	1.67	31	51.8	7.4	7.80	32.9	YES	400
28 7:48	1.61	31	49.9	7.4	7.80	32.7	YES	400
29 15:53	1.69	31	52.4	7.1	7.80	33.7	YES	350
30 21:50	1.60	31	49.6	8.3	8.00	33.0	YES	350
31 7:26	1.60	31	49.6	8.0	7.90	32.5	YES	350

³ If Cl₂ at entry point < 0.2 mg/l or CT not met, notify DWS within 24 hours.

Revised September 2016

Return by 10th of following month by email, fax, or mail to:

dwp.dmc@state.or.us; 971-673-0694; or Drinking Water Services, PO Box 14350, Portland, OR 97293-0350