

OHA - Drinking Water Services - Surface Water Quality Data Form

County: Tillamook

Slow Sand, Membrane, Diatomaceous Earth Filtration, or Unfiltered Systems

Month/Year: Apr-22

System Name:	Rockaway Beach Water Dist			ID#: 41 00708			WTP: TP -	WTP-A
Day	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the day ¹ [NTU]	
1	0.03	0.03	0.03	0.04	0.04	0.04	0.04	
2	0.04	0.03	0.03	0.03	0.03	0.03	0.04	
3	0.03	0.03	0.03	0.03	0.03	0.03	0.03	
4	Off	Off	0.03	0.03	0.04	0.04	0.04	
5	0.03	0.03	0.03	0.05	0.04	0.04	0.05	
6	0.03	0.03	0.03	0.03	0.03	0.04	0.04	
7	0.03	0.03	0.03	0.03	0.04	0.04	0.04	
8	0.04	0.04	0.03	0.04	0.04	0.04	0.04	
9	0.04	0.03	0.03	0.04	0.05	0.04	0.05	
10	Off	Off	Off	0.03	0.04	0.04	0.04	
11	0.04	0.03	0.03	0.04	0.03	0.03	0.04	
12	0.04	Off	0.03	0.03	0.03	0.03	0.04	
13	Off	Off	Off	0.03	0.05	0.04	0.05	
14	0.03	0.04	0.03	0.03	0.03	0.03	0.04	
15	Off	Off	0.03	0.03	0.03	0.03	0.03	
16	0.04	0.04	0.03	0.03	0.03	0.03	0.04	
17	0.03	0.03	0.03	0.03	0.03	0.04	0.04	
18	0.04	0.04	0.03	0.03	0.03	Off	0.04	
19	Off	0.03	0.03	0.03	0.03	0.03	0.03	
20	0.04	0.04	0.04	0.04	0.04	0.04	0.04	
21	0.04	0.03	0.04	0.03	0.03	0.03	0.04	
22	0.03	0.03	0.03	0.03	0.03	0.04	0.04	
23	0.04	0.03	0.03	0.03	0.06	0.04	0.06	
24	Off	Off	0.03	0.04	0.05	0.04	0.05	
25	0.03	0.03	0.04	0.03	0.03	0.04	0.04	
26	0.03	0.03	0.03	0.03	0.03	0.03	0.03	
27	0.03	0.03	0.03	0.03	0.04	0.04	0.04	
28	0.04	Off	Off	0.04	0.04	0.04	0.04	
29	0.04	0.04	0.03	0.03	0.03	0.03	0.04	
30	0.04	0.04	0.04	0.04	0.05	0.04	0.05	

Slow Sand/Membrane/DE Filtration/Unfiltered	Monthly Summary (Answer Yes or No)	
95% of daily turbidity readings ≤ 1 NTU? ²	Yes	CT's met everyday?
All daily turbidity readings ≤ 5 NTU?	Yes	Yes
Note	PRINTED NAME: <i>Linda Sheparey</i>	
	SIGNATURE: <i>[Signature]</i>	5/4/22
	PHONE #: (503) 374-0586	CERT #:

¹ Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in columns 12 AM through 8 PM may not correspond to continuous readings' maximum. ² Filtered systems only.

OHA - Drinking Water Services - Surface Water Quality Data Form

WTP- :

WTP-A

Rockaway Beach

Disinfection *Giardia*
Log Inactiv:

System Name:

Water Dist.

ID#: 41 00708

Month/Year: Apr-22

0.5

Date / Time	Minimum Cl ₂ Residual at 1st User (C) ³	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? ³	Peak Hourly Demand Flow
	[ppm or mg/L]	[minutes]	C X T	[° C]		formula	Yes / No	[GPM]
1 6:59	1.21	31	37.5	9.3	7.90	28.5	YES	360
2 23:23	1.25	31	38.8	11.5	8.00	25.6	YES	360
3 8:06	1.25	31	38.8	11.5	8.00	25.6	YES	350
4 8:52	1.35	31	41.9	10.3	8.00	28.0	YES	350
5 21:08	1.38	31	42.8	11.3	8.00	26.3	YES	350
6 14:14	1.31	31	40.6	8.9	8.00	30.7	YES	350
7 5:43	1.25	31	38.8	9.7	8.00	28.8	YES	350
8 3:46	1.48	31	45.9	11.3	8.00	26.6	YES	350
9 18:03	1.49	31	46.2	10.7	8.00	27.7	YES	350
10 23:40	1.54	31	47.7	9.1	7.60	26.9	YES	350
11 17:33	1.34	31	41.5	8.0	7.90	31.6	YES	350
12 8:09	1.23	31	38.1	8.2	7.90	30.7	YES	400
13 9:17	1.33	31	41.2	8.5	7.80	29.4	YES	350
14 9:18	1.34	31	41.5	8.0	7.80	30.4	YES	350
15 9:26	1.26	31	39.1	8.6	7.90	30.0	YES	350
16 8:50	1.29	31	40.0	8.5	7.90	30.3	YES	350
17 20:56	1.46	31	45.3	10.0	8.00	29.0	YES	300
18 11:08	1.49	31	46.2	9.4	7.90	29.2	YES	300
19 1:39	1.47	31	45.6	9.9	8.00	29.2	YES	300
20 21:43	1.45	31	45.0	10.3	8.00	28.3	YES	300
21 18:33	1.53	31	47.4	10.7	7.90	26.9	YES	300
22 15:19	1.34	31	41.5	10.2	7.80	26.2	YES	300
23 12:13	1.55	31	48.1	11.8	7.90	25.0	YES	300
24 7:53	1.39	31	43.1	11.8	8.00	25.5	YES	300
25 22:48	1.54	31	47.7	12.1	8.00	25.4	YES	300
26 14:50	1.61	31	49.9	10.8	7.90	26.9	YES	300
27 8:06	1.49	31	46.2	10.3	7.90	27.5	YES	300
28 13:28	1.50	31	46.5	10.8	7.90	26.6	YES	300
29 12:05	1.58	31	49.0	10.2	7.80	27.0	YES	300
30 19:30	1.17	31	36.3	12.4	7.80	22.2	YES	300

³ If Cl₂ at entry point < 0.2 mg/l or CT not met, notify DWS within 24 hours.

Revised September 2016

Return by 10th of following month by email, fax, or mail to:

dwp.dmce@state.or.us; 971-673-0694; or Drinking Water Services, PO Box 14350, Portland, OR 97293-0350