

OHA - Drinking Water Services - Surface Water Quality Data Form

County: Tillamook

Slow Sand, Membrane, Diatomaceous Earth Filtration, or Unfiltered Systems

Month/Year: Jun-22

System Name:	Rockaway Beach Water Dist						ID#: 41 00708	WTP : TP -	WTP-A
Day	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the day ¹ [NTU]		
1	0.03	0.03	0.03	Off	Off	Off	0.03		
2	Off	0.03	0.03	0.03	0.04	0.04	0.04		
3	0.03	0.03	0.03	0.03	0.03	0.04	0.04		
4	0.04	0.04	0.04	0.03	0.04	0.04	0.04		
5	Off	Off	0.03	0.03	0.03	0.05	0.05		
6	0.05	0.03	0.03	0.03	0.03	0.03	0.05		
7	0.03	0.03	0.03	Off	Off	Off	0.03		
8	Off	Off	0.03	0.03	0.03	0.03	0.03		
9	0.04	0.04	0.03	0.04	0.04	0.04	0.04		
10	0.04	0.05	0.04	0.03	0.04	0.04	0.05		
11	0.04	0.04	0.03	0.04	0.04	0.05	0.05		
12	0.04	0.03	0.03	0.03	0.03	Off	0.04		
13	0.04	0.03	0.03	0.03	0.03	0.03	0.04		
14	0.03	0.03	0.03	0.03	0.03	0.03	0.03		
15	0.04	0.04	0.04	0.05	0.05	0.04	0.05		
16	0.03	0.04	0.04	0.04	0.04	0.04	0.04		
17	0.04	0.04	0.03	0.03	Off	Off	0.04		
18	0.05	0.04	0.04	0.04	0.05	0.04	0.05		
19	0.04	0.04	0.03	0.04	0.04	0.04	0.04		
20	0.04	0.03	0.03	0.03	0.03	0.03	0.04		
21	0.05	0.04	0.04	0.05	0.04	0.04	0.05		
22	0.03	0.04	0.04	0.04	0.04	0.05	0.05		
23	0.05	0.04	0.03	0.03	0.03	0.05	0.05		
24	0.05	0.04	0.04	0.04	0.03	0.03	0.05		
25	0.03	0.03	0.03	0.03	0.05	0.05	0.05		
26	0.04	0.04	0.04	0.04	0.05	0.04	0.05		
27	0.05	0.04	0.05	0.04	Off	Off	0.05		
28	Off	Off	0.03	0.03	0.03	0.03	0.03		
29	0.03	0.03	0.03	0.04	0.04	0.03	0.04		
30	0.03	0.03	0.03	0.04	0.05	0.04	0.05		

Slow Sand/Membrane/DE Filtration/Unfiltered	Monthly Summary (Answer Yes or No)	
95% of daily turbidity readings ≤ 1 NTU? ²	Yes	CT's met everyday?
All daily turbidity readings ≤ 5 NTU?	Yes	Yes
Note	PRINTED NAME: Luke Shepard	All Cl ₂ residual at entry point ≥ 0.2 mg/l?
	SIGNATURE: 	Yes
	PHONE #: (503) 374-0586	7/6/22
		CERT #:

¹ Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in columns 12 AM through 8 PM may not correspond to continuous readings' maximum. ² Filtered systems only.

OHA - Drinking Water Services - Surface Water Quality Data Form

WTP- : WTP-A

Rockaway Beach

System Name: Water Dist. ID#: 41 00708 Month/Year: Jun-22

Disinfection *Giardia*
Log Inactiv: 0.5

Date / Time	Minimum Cl ₂ Residual at 1st User (C) ³	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? ³	Peak Hourly Demand Flow
	[ppm or mg/L]	[minutes]	C X T	[° C]		formula	Yes / No	[GPM]
1 4:38	1.23	31	38.1	12.8	8.10	24.3	YES	360
2 6:05	1.06	31	32.9	12.5	7.80	21.8	YES	370
3 4:11	1.15	31	35.7	12.7	8.10	24.2	YES	350
4 16:28	1.21	31	37.5	12.9	7.80	21.6	YES	350
5 12:47	1.07	31	33.2	12.9	7.90	22.0	YES	360
6 13:54	1.21	31	37.5	12.0	7.70	22.1	YES	350
7 7:58	1.42	31	44.0	12.1	8.00	25.0	YES	350
8 11:13	0.98	31	30.4	12.7	7.80	21.3	YES	360
9 17:50	1.12	31	34.7	13.0	7.80	21.2	YES	370
10 18:20	0.93	31	28.8	13.1	7.60	19.1	YES	360
11 17:00	1.07	31	33.2	13.6	7.60	18.8	YES	370
12 5:51	1.01	31	31.3	12.8	7.80	21.2	YES	360
13 8:03	1.01	31	31.3	12.1	8.00	23.9	YES	350
14 1:20	1.17	31	36.3	12.3	7.70	21.6	YES	350
15 14:47	1.20	31	37.2	12.5	8.00	23.8	YES	350
16 4:57	1.15	31	35.7	12.1	8.00	24.3	YES	370
17 9:02	1.23	31	38.1	11.7	7.70	22.6	YES	350
18 2:44	1.24	31	38.4	12.7	7.90	22.7	YES	370
19 17:41	1.01	31	31.3	13.7	7.90	20.7	YES	370
20 6:42	1.09	31	33.8	12.8	7.90	22.2	YES	370
21 1:44	1.06	31	32.9	14.7	8.10	21.0	YES	350
22 12:25	1.02	31	31.6	13.1	7.60	19.3	YES	350
23 14:47	1.00	31	31.0	12.5	7.80	21.6	YES	350
24 21:51	1.02	31	31.6	15.0	8.20	21.3	YES	350
25 23:14	1.20	31	37.2	16.0	7.70	16.9	YES	350
26 19:14	1.00	31	31.0	17.0	7.90	16.6	YES	350
27 14:45	0.97	31	30.1	15.1	7.80	18.1	YES	400
28 18:48	1.23	31	38.1	14.8	8.20	22.1	YES	400
29 18:00	1.18	31	36.6	14.1	7.90	20.6	YES	420
30 17:09	1.12	31	34.7	15.6	7.90	18.5	YES	420

³ If Cl₂ at entry point < 0.2 mg/l or CT not met, notify DWS within 24 hours.

Revised September 2016

Return by 10th of following month by email, fax, or mail to:
dwp.dmce@state.or.us; 971-673-0694; or Drinking Water Services, PO Box 14350, Portland, OR 97293-0350