


OHA - Drinking Water Services - Surface Water Quality Data Form

County: Tillamook

Slow Sand, Membrane, Diatomaceous Earth Filtration, or Unfiltered Systems

Month/Year: Aug-22

System Name:	Rockaway Beach Water Dist			ID#: 41 00708			WTP : TP -	WTP-A
Day	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the day ¹ [NTU]	
1	0.04	0.04	0.03	0.03	0.04	0.03	0.04	
2	0.03	0.03	0.03	0.03	0.05	0.04	0.05	
3	0.04	0.04	0.03	0.04	0.05	0.05	0.05	
4	0.04	0.04	0.04	0.04	0.05	0.05	0.05	
5	0.04	0.04	0.04	0.03	0.03	0.03	0.04	
6	0.05	0.04	0.04	0.04	0.04	0.06	0.06	
7	0.05	0.04	0.04	0.06	0.04	0.05	0.06	
8	0.05	0.05	0.04	0.04	0.04	0.05	0.05	
9	0.04	0.04	0.03	0.03	0.04	0.04	0.04	
10	0.04	0.03	0.03	0.03	0.04	0.05	0.05	
11	0.04	0.04	0.03	0.03	0.03	0.03	0.04	
12	0.03	0.03	0.04	0.04	0.04	0.04	0.04	
13	0.04	0.04	0.04	0.04	0.04	0.05	0.05	
14	0.05	0.05	0.05	0.04	Off	0.06	0.06	
15	0.04	0.04	0.05	0.04	0.04	0.04	0.05	
16	0.04	0.04	0.04	0.04	0.04	0.04	0.04	
17	0.04	Off	0.04	0.04	0.05	0.04	0.05	
18	0.04	0.04	Off	0.05	0.04	0.05	0.05	
19	0.05	0.05	0.04	Off	Off	0.05	0.05	
20	0.05	0.04	0.05	0.04	0.05	0.05	0.05	
21	0.04	0.04	0.04	0.04	Off	0.05	0.05	
22	0.04	0.04	0.04	0.04	0.04	0.05	0.05	
23	0.04	0.04	0.04	0.05	0.05	0.05	0.05	
24	0.05	0.05	0.04	0.04	0.04	0.04	0.05	
25	0.05	0.05	0.05	0.04	0.04	0.06	0.06	
26	0.05	0.05	0.04	Off	0.04	0.05	0.05	
27	0.05	0.05	0.04	0.04	0.05	0.05	0.05	
28	0.04	0.04	0.04	0.04	0.04	0.05	0.05	
29	0.05	0.04	0.04	0.04	0.04	0.04	0.05	
30	0.04	0.04	0.04	0.04	0.04	0.04	0.04	
31	0.04	0.04	0.04	0.04	0.00	0.04	0.04	

Slow Sand/Membrane/DE Filtration/Unfiltered	Monthly Summary (Answer Yes or No)	
95% of daily turbidity readings ≤ 1 NTU? ²	Yes	CT's met everyday?
All daily turbidity readings ≤ 5 NTU?	Yes	All Cl ₂ residual at entry point ≥ 0.2 mg/l?
		Yes
Note	PRINTED NAME: Luke Shepard	
	SIGNATURE: 	9/7/22
	PHONE #: (503) 374-0586	CERT #:

¹ Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in columns 12 AM through 8 PM may not correspond to continuous readings' maximum. ² Filtered systems only.

OHA - Drinking Water Services - Surface Water Quality Data Form

WTP- :

WTP-A

Rockaway Beach

Disinfection *Giardia*
Log Inactiv:

System Name:

Water Dist.

ID#: 41 00708

Month/Year: Aug-22

0.5

Date / Time	Minimum Cl ₂ Residual at 1st User (C) ³	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? ³	Peak Hourly Demand Flow
	[ppm or mg/L]	[minutes]	C X T	[° C]		formula	Yes / No	[GPM]
1 20:23	1.23	31	38.1	15.5	8.00	19.6	YES	435
2 7:29	1.17	31	36.3	14.5	7.80	19.3	YES	420
3 14:37	1.32	31	40.9	14.5	7.70	18.9	YES	420
4 4:53	1.33	31	41.2	14.6	7.90	20.3	YES	415
5 23:43	1.20	31	37.2	15.7	8.20	20.7	YES	420
6 16:30	1.00	31	31.0	15.1	7.80	18.2	YES	420
7 15:56	1.23	31	38.1	15.1	7.70	18.0	YES	430
8 23:34	1.20	31	37.2	14.6	8.20	22.3	YES	415
9 16:23	1.30	31	40.3	15.0	7.80	18.9	YES	420
10 22:43	1.23	31	38.1	15.6	7.90	18.7	YES	435
11 18:21	1.20	31	37.2	16.6	8.00	18.1	YES	420
12 19:47	1.12	31	34.7	15.8	8.10	19.7	YES	420
13 13:46	1.20	31	37.2	15.1	7.80	18.6	YES	420
14 9:34	1.20	31	37.2	13.9	7.70	19.4	YES	420
15 19:25	1.15	31	35.7	16.5	8.00	18.2	YES	420
16 19:34	1.16	31	36.0	17.1	8.00	17.5	YES	420
17 14:05	1.13	31	35.0	15.1	7.60	17.1	YES	420
18 22:27	1.16	31	36.0	16.2	8.10	19.2	YES	420
19 19:17	1.14	31	35.3	16.2	8.10	19.2	YES	420
20 13:56	1.06	31	32.9	16.1	7.70	16.5	YES	420
21 18:43	1.13	31	35.0	16.1	7.70	16.6	YES	420
22 18:44	1.12	31	34.7	17.7	7.90	16.1	YES	420
23 19:43	1.13	31	35.0	17.2	7.80	16.1	YES	430
24 22:37	1.12	31	34.7	15.6	7.70	17.2	YES	430
25 19:13	1.03	31	31.9	16.3	7.80	16.9	YES	400
26 11:03	1.00	31	31.0	15.1	7.60	16.9	YES	415
27 20:58	1.13	31	35.0	16.5	8.00	18.1	YES	430
28 3:56	1.16	31	36.0	14.9	7.80	18.8	YES	415
29 12:26	1.08	31	33.5	15.5	8.00	19.2	YES	415
30 20:49	1.01	31	31.3	16.4	7.90	17.3	YES	420
31 23:57	0.97	31	30.1	15.6	7.80	17.5	YES	420

³ If Cl₂ at entry point < 0.2 mg/l or CT not met, notify DWS within 24 hours.

Revised September 2016

Return by 10th of following month by email, fax, or mail to:

dwp.dmce@state.or.us; 971-673-0694; or Drinking Water Services, PO Box 14350, Portland, OR 97293-0350