

OHA - Drinking Water Services - Surface Water Quality Data Form

Slow Sand, Membrane, Diatomaceous Earth Filtration, or Unfiltered Systems

County: Tillamook

Month/Year: Apr-23

System Name:	Rockaway Beach Water Dist ID# 41 00708						WTP : TP -	WTP-A
Day	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the day ¹ [NTU]	
1	0.03	0.03	0.03	0.03	0.03	0.04	0.04	
2	0.03	0.03	0.03	0.03	0.03	0.03	0.03	
3	0.03	0.03	0.03	0.03	0.03	0.04	0.04	
4	0.04	0.03	0.03	0.04	0.04	0.03	0.04	
5	Off	0.03	0.03	0.03	0.03	0.03	0.03	
6	0.03	Off	0.03	0.03	0.03	0.04	0.04	
7	0.04	0.03	0.04	0.04	0.03	0.04	0.04	
8	0.04	0.04	0.04	0.03	0.03	0.04	0.04	
9	0.04	0.05	0.03	0.04	0.04	Off	0.05	
10	Off	Off	Off	0.03	0.03	0.04	0.04	
11	0.03	0.03	0.03	0.03	0.03	0.04	0.04	
12	0.04	0.03	0.04	0.04	0.04	0.03	0.04	
13	0.04	Off	Off	0.03	0.03	0.03	0.04	
14	0.03	0.03	0.03	0.04	0.03	0.03	0.04	
15	0.04	0.04	0.03	0.03	0.03	0.03	0.04	
16	0.03	0.03	Off	0.04	0.04	0.04	0.04	
17	0.03	0.03	0.03	0.03	0.03	0.03	0.03	
18	0.03	0.03	Off	Off	Off	Off	0.03	
19	Off	Off	Off	0.03	0.03	0.03	0.03	
20	0.03	0.03	0.03	0.03	0.03	0.04	0.04	
21	0.04	0.03	0.03	0.03	0.03	0.03	0.04	
22	0.04	0.04	0.04	0.04	0.04	0.04	0.04	
23	0.03	0.03	0.04	0.04	0.04	0.04	0.04	
24	0.03	0.03	0.03	0.03	0.03	0.03	0.03	
25	Off	Off	Off	0.03	0.04	0.04	0.04	
26	0.04	0.03	0.03	0.03	0.03	0.03	0.04	
27	0.04	0.04	0.03	0.03	Off	Off	0.04	
28	Off	Off	Off	0.03	0.04	0.04	0.04	
29	0.03	0.03	0.03	0.03	0.04	0.04	0.04	
30	0.04	0.04	0.04	0.04	0.04	0.03	0.04	

Slow Sand/Membrane/DE Filtration/Unfiltered			Monthly Summary (Answer Yes or No)		
95% of daily turbidity readings \leq 1 NTU? ² #REF!			CT's met everyday? All Cl ₂ residual at entry point \geq 0.2 mg/l?		
All daily turbidity readings \leq 5 NTU? #REF!			#REF! #REF!		
Note			PRINTED NAME: <i>Luke Shepard</i>		
			SIGNATURE: <i>Luke Shepard</i>		
			PHONE #: (503) 374-0586 CERT #: <i>5/21/23</i>		

¹ Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in columns 12 AM through 8 PM may not correspond to continuous readings' maximum. ² Filtered systems only.

OHA - Drinking Water Services - Surface Water Quality Data Form

WTP- :

WTP-A

Rockaway Beach							Disinfection Giardia Log Inactiv:
System Name:	Water Dist.	ID#: 41 00708	Month/Year: Apr-23				0.5

Date / Time	Minimum Cl ₂ Residual at 1st User (C) ³	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? ³	Peak Hourly Demand Flow
	[ppm or mg/L]	[minutes]	C X T	[° C]		formula	Yes / No	[GPM]
1 19:51	1.69	31	52.4	9.7	7.90	29.3	YES	350
2 4:08	1.73	31	53.6	8.7	8.00	32.6	YES	370
3 5:24	1.74	31	53.9	8.2	7.90	32.6	YES	365
4 16:58	1.74	31	53.9	9.5	8.00	31.0	YES	360
5 2:05	1.38	31	42.8	9.4	7.80	27.8	YES	360
6 9:41	1.56	31	48.4	9.4	7.90	29.4	YES	370
7 11:01	1.40	31	43.4	10.0	7.70	25.8	YES	350
8 14:38	1.40	31	43.4	9.9	8.10	30.0	YES	350
9 11:26	1.70	31	52.7	10.2	7.90	28.3	YES	350
10 16:32	1.60	31	49.6	10.3	7.70	25.9	YES	350
11 6:12	1.56	31	48.4	9.6	7.70	27.0	YES	380
12 10:09	1.76	31	54.6	9.3	7.90	30.3	YES	360
13 10:59	1.76	31	54.6	9.6	7.60	26.7	YES	370
14 2:26	1.60	31	49.6	10.3	7.80	26.8	YES	350
15 8:28	1.62	31	50.2	10.4	7.90	27.7	YES	360
16 10:38	1.52	31	47.1	10.5	8.00	28.2	YES	350
17 11:40	1.49	31	46.2	9.0	8.00	31.1	YES	360
18 10:10	1.73	31	53.6	9.2	7.90	30.4	YES	370
19 20:41	1.66	31	51.5	10.4	7.90	27.8	YES	370
20 17:20	1.71	31	53.0	9.2	8.10	32.6	YES	360
21 14:42	1.72	31	53.3	10.1	7.90	28.6	YES	370
22 22:44	1.58	31	49.0	12.1	7.90	24.6	YES	370
23 22:08	1.60	31	49.6	11.4	7.90	25.8	YES	360
24 10:54	1.67	31	51.8	10.4	8.00	28.9	YES	370
25 21:54	1.69	31	52.4	12.9	8.00	24.5	YES	370
26 16:55	1.68	31	52.1	11.6	8.00	26.7	YES	370
27 6:48	1.56	31	48.4	11.1	7.90	26.2	YES	360
28 12:33	1.54	31	47.7	12.5	7.80	23.0	YES	350
29 21:04	1.60	31	49.6	13.6	8.00	23.2	YES	350
30 2:50	1.64	31	50.8	12.4	8.00	25.2	YES	350

³ If Cl₂ at entry point < 0.2 mg/l or CT not met, notify DWS within 24 hours.

Revised September 2016

Return by 10th of following month by email, fax, or mail to:

dwp.dmc@state.or.us; 971-673-0694; or Drinking Water Services, PO Box 14350, Portland, OR 97293-0350