

OHA - Drinking Water Services - Surface Water Quality Data Form

County: **Tillamook**

Slow Sand, Membrane, Diatomaceous Earth Filtration, or Unfiltered Systems

Month/Year: **Aug-23**

System Name: **Rockaway Beach Water Dist** ID#: **41 00708** WTP : **TP - WTP-A**

Day	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the day ¹ [NTU]
1	0.03	0.03	0.04	0.03	0.05	0.04	0.05
2	0.04	0.04	0.03	0.03	0.04	0.06	0.06
3	Off	Off	0.02	0.02	0.02	0.02	0.02
4	0.02	0.02	0.02	0.02	0.02	0.03	0.03
5	0.03	0.03	0.02	0.02	0.03	0.03	0.03
6	0.03	0.02	0.02	0.02	0.03	0.03	0.03
7	0.03	0.03	0.02	0.02	0.02	0.02	0.03
8	0.02	0.02	0.02	0.03	0.03	0.03	0.03
9	0.03	0.02	0.02	0.02	0.02	0.02	0.03
10	0.02	0.03	0.06	0.03	0.04	0.05	0.06
11	0.03	0.03	0.04	0.04	0.04	0.04	0.04
12	0.05	0.04	0.03	0.03	0.03	0.03	0.05
13	0.03	0.03	0.03	0.03	0.03	0.04	0.04
14	0.04	0.04	0.04	0.04	0.05	0.05	0.05
15	0.04	0.04	0.03	0.03	0.03	0.03	0.04
16	0.04	0.04	0.03	0.03	0.03	0.04	0.04
17	0.06	0.05	0.07	0.06	0.05	0.05	0.07
18	0.03	0.04	0.04	0.04	0.05	0.05	0.05
19	0.05	0.05	0.04	0.04	0.04	0.04	0.05
20	0.03	0.03	0.03	0.05	0.04	0.05	0.05
21	0.04	0.04	0.03	0.06	0.05	0.04	0.06
22	0.04	0.04	0.04	0.05	0.05	0.04	0.05
23	0.04	0.04	0.03	0.04	0.03	0.04	0.04
24	0.04	0.04	0.04	0.03	0.03	0.03	0.04
25	0.03	0.03	0.03	0.03	0.03	0.04	0.04
26	0.04	0.04	0.03	0.03	0.03	0.03	0.04
27	0.03	0.04	Off	0.03	0.03	0.03	0.04
28	0.03	0.03	0.04	0.04	0.03	0.03	0.04
29	0.03	0.03	Off	Off	0.03	0.03	0.03
30	0.03	0.03	0.03	0.03	0.03	0.03	0.03
31	0.03	0.03	0.03	Off	0.03	0.03	0.03

Slow Sand/Membrane/DE Filtration/Unfiltered	Monthly Summary (Answer Yes or No)	
95% of daily turbidity readings ≤ 1 NTU? ² Yes	CT's met everyday?	All Cl ₂ residual at entry point ≥ 0.2 mg/l?
All daily turbidity readings ≤ 5 NTU? Yes	Yes	Yes
Note	PRINTED NAME: <i>Luella Shepard</i>	
	SIGNATURE: <i>[Signature]</i>	<i>9/5/23</i>
	PHONE #: (503) 374-0586	CERT #:

¹ Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in columns 12 AM through 8 PM may not correspond to continuous readings' maximum. ² Filtered systems only.

OHA - Drinking Water Services - Surface Water Quality Data Form

WTP- : **WTP-A**

Rockaway Beach
 System Name: **Water Dist.** ID#: **41 00708** Month/Year: **Aug-23** Disinfection *Giardia* Log Inactiv: **0.5**

Date / Time	Minimum Cl ₂ Residual at 1st User (C) ³	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? ³	Peak Hourly Demand Flow
1 23:56	0.95	31	29.5	15.1	7.90	18.8	YES	485
2 0:00	0.96	31	29.8	15.1	7.90	18.8	YES	489
3 20:18	1.09	23	25.1	15.7	8.10	19.7	YES	549
4 16:56	1.19	23	27.4	15.2	7.80	18.5	YES	545
5 8:31	1.31	31	40.6	14.3	7.80	19.9	YES	487
6 1:00	1.10	31	34.1	14.9	7.90	19.3	YES	426
7 12:02	0.90	23	20.7	14.9	7.70	17.6	YES	550
8 16:17	0.90	23	20.7	16.6	8.10	18.2	YES	550
9 13:15	1.09	31	33.8	14.7	7.80	18.9	YES	430
10 10:40	0.96	31	29.8	13.9	8.00	21.1	YES	430
11 19:25	0.98	31	30.4	15.1	8.10	20.3	YES	440
12 20:17	1.12	31	34.7	15.1	8.10	20.6	YES	440
13 20:17	1.09	31	33.8	15.0	8.20	21.4	YES	425
14 20:08	1.08	31	33.5	15.4	8.20	20.9	YES	423
15 5:00	0.99	31	30.7	14.9	8.10	20.6	YES	431
16 22:29	1.06	31	32.9	15.5	8.20	20.7	YES	500
17 20:10	1.09	23	25.1	15.6	7.80	17.8	YES	600
18 8:55	0.80	31	24.8	13.9	8.00	20.7	YES	311
19 9:42	1.00	31	31.0	14.1	7.80	19.4	YES	500
20 19:02	1.10	23	25.3	14.5	7.90	19.9	YES	564
21 19:15	1.10	31	34.1	13.6	7.90	21.1	YES	426
22 4:23	1.10	31	34.1	13.6	8.00	21.9	YES	450
23 19:30	1.50	31	46.5	14.3	7.90	21.1	YES	472
24 14:15	1.90	31	58.9	13.8	7.90	22.8	YES	433
25 4:18	1.71	31	53.0	14.4	7.90	21.4	YES	424
26 6:10	1.76	31	54.6	14.6	7.90	21.3	YES	416
27 12:51	1.56	31	48.4	14.5	7.90	20.9	YES	435
28 15:39	1.90	23	43.7	14.4	7.90	21.9	YES	525
29 20:34	2.05	31	63.6	14.1	7.90	22.7	YES	425
30 22:13	1.92	31	59.5	14.4	7.90	21.9	YES	420
31 1:34	1.96	31	60.8	14.3	7.90	22.2	YES	430

³ If Cl₂ at entry point < 0.2 mg/l or CT not met, notify DWS within 24 hours.

Revised September 2016

Return by 10th of following month by email, fax, or mail to:
 dwp.dmce@state.or.us; 971-673-0694; or Drinking Water Services, PO Box 14350, Portland, OR 97293-0350