

OHA - Drinking Water Services -Turbidity Monitoring Report Form

County: Jackson  
 Month/Year: Jun-22

Conventional or Direct Filtration

System Name:	City of Rogue River		ID#: 41-00712				WTP : TP -	WTP-A
Day	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the Day <sup>1</sup> [NTU]	
1	---	---	0.05	---	0.06	---	0.06	
2	0.05	---	0.06	---	0.06	---	0.06	
3	---	---	0.03	0.03	---	0.06	0.06	
4	---	---	0.06	0.06	0.06	0.09	0.09	
5	0.06	---	0.05	0.04	---	---	0.06	
6	---	---	0.03	0.03	0.08	---	0.08	
7	0.06	0.06	0.04	0.04	---	0.06	0.06	
8	0.06	---	0.06	0.06	---	0.06	0.06	
9	0.11	0.06	0.07	---	---	---	0.11	
10	---	0.17	0.05	0.05	0.07	---	0.17	
11	---	0.15	0.05	0.05	---	---	0.15	
12	---	0.07	0.04	0.05	---	0.07	0.07	
13	---	---	0.05	0.04	---	---	0.05	
14	---	---	0.04	0.04	---	---	0.04	
15	---	---	0.12	---	0.17	0.04	0.17	
16	---	---	0.07	---	0.07	---	0.07	
17	---	---	0.04	0.04	---	0.07	0.07	
18	---	---	0.04	0.03	---	0.18	0.18	
19	---	---	0.03	0.04	0.02	---	0.04	
20	0.15	0.08	0.04	0.04	0.08	---	0.15	
21	0.08	---	0.04	---	---	---	0.08	
22	---	---	---	---	---	---	0.00	
23	---	---	---	---	---	---	0.00	
24	---	---	0.04	0.04	---	---	0.04	
25	---	---	0.04	0.04	0.07	0.03	0.07	
26	---	0.17	0.04	0.04	---	---	0.17	
27	---	---	0.05	0.05	---	---	0.05	
28	---	---	0.05	0.05	---	---	0.05	
29	---	---	0.08	---	---	---	0.08	
30	---	---	---	---	---	0.09	0.09	
31	0.08	---	0.07	---	0.07	0.12	0.12	

Conventional or Direct Filtration	Monthly Summary (Answer Yes or No)	
95% of 4-hour turbidity readings ≤ 0.3 NTU? All 4-hour turbidity readings ≤ 1 NTU? All turbidity readings < IFE <sup>2</sup> triggers	CT's met everyday? (see back) Yes / No	All Cl2 residual at entry point ≥ 0.2 mg/l? Yes / No
	PRINTED NAME: Michael Bollweg SIGNATURE: <i>Michael Bollweg</i> PHONE #: ( 541 ) 415-1117	DATE: <i>11.10.22</i> CERT #: 5296

<sup>1</sup> Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in columns 12 AM through 8 PM may not correspond to continuous readings' maximum. <sup>2</sup> IFE = Individ. Filter Effl. (333-061-0040(1)(d)(B&C))

OHA - Drinking Water Program - Surface Water Quality Data Form

WTP - :	WTP-A
Disinfection <i>Giardia</i> Log Inactive:	0.5

System Name:	City of Rogue River	ID#: 41-00712	Month/Year:	Oct-22
--------------	---------------------	---------------	-------------	--------

Date / Time	Minimum Cl <sub>2</sub> Residual at 1st User ( C ) <sup>3</sup>	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? <sup>3</sup>	Peak Hourly Demand Flow
	[ppm or mg/L]	[minutes]	C X T	[° C]		formula	Yes / No	[GPM]
1	1.65	76	125	14.9	8.0	21	YES	796
2	1.67	76	127	14.8	8.0	22	YES	788
3	1.65	76	125	13.8	8.1	24	YES	791
4	1.61	76	122	13.8	7.9	22	YES	798
5	1.55	76	118	14.2	8.0	22	YES	791
6	1.69	76	128	14.7	7.4	17	YES	785
7	1.51	76	115	14.2	8.0	22	YES	791
8	1.41	76	107	14.2	8.1	23	YES	796
9	1.73	76	131	14.0	8.0	23	YES	785
10	1.56	76	119	13.0	7.9	23	YES	798
11	1.76	76	134	12.5	7.9	24	YES	796
12	1.68	76	128	12.3	8.0	25	YES	790
13	1.78	76	135	12.5	7.7	23	YES	791
14	1.75	76	133	12.1	7.5	22	YES	797
15	1.72	76	131	11.7	7.9	26	YES	792
16	1.78	76	135	11.9	7.9	26	YES	787
17	1.65	76	125	11.8	7.8	24	YES	799
18	1.73	76	131	11.6	7.7	24	YES	795
19	1.58	76	120	10.8	7.7	25	YES	802
20	1.80	76	137	12.6	7.7	23	YES	799
21	1.90	76	144	11.0	7.6	25	YES	783
22								
23								
24	1.06	76	81	10.7	7.5	22	YES	788
25	1.47	76	112	9.5	7.6	26	YES	782
26	1.76	76	134	9.4	7.9	30	YES	785
27	1.82	76	138	9.3	7.7	28	YES	789
28	1.82	76	138	9.5	7.8	29	YES	778
29	1.90	76	144	9.9	7.6	27	YES	784
30	1.90	76	144	11.4	7.7	25	YES	777
31	1.68	76	128	9.7	7.7	27	YES	795

<sup>3</sup> If Cl<sub>2</sub> at entry point < 0.2 mg/l or CT not met, notify DWS within 24 hours.

Revised July 2018

Return by 10th of following month by email, fax, or mail to:  
 dwp.dmce@state.or.us; 971-673-0694; or Drinking Water Services, PO Box 14350, Portland, OR 97293-0350