

OHA - Drinking Water Services -Turbidity Monitoring Report Form

County: Jackson

Conventional or Direct Filtration

Month/Year: Aug-25

System Name:	City of Rogue River	ID#: 41-00712	WTP : TP -	WTP-A			
Day	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the Day ¹ [NTU]
1	0.03	0.04	0.04	0.04	0.14	0.08	0.14
2	0.03	0.05	0.04	0.04	0.05	0.03	0.05
3	0.03	0.04	0.04	0.04	0.04	0.04	0.04
4	0.03	0.04	0.04	0.04	0.04	0.03	0.04
5	0.04	0.04	0.03	0.16	0.04	0.03	0.16
6	0.03	0.03	---	---	---	0.04	0.04
7	0.08	0.04	0.04	0.04	0.04	0.04	0.08
8	0.04	0.03	0.04	0.09	0.04	0.04	0.09
9	0.13	0.05	0.04	0.04	0.04	0.03	0.13
10	0.05	0.03	0.03	0.11	0.00	0.04	0.11
11	0.14	0.03	0.03	0.09	0.04	0.04	0.14
12	0.04	---	0.04	0.04	0.04	0.04	0.04
13	0.04	0.03	0.04	0.04	0.04	0.03	0.04
14	0.03	0.03	0.14	0.04	0.04	0.04	0.14
15	0.03	0.03	0.03	0.04	0.04	0.04	0.04
16	0.03	0.03	---	0.04	0.04	0.04	0.04
17	0.03	0.04	0.04	0.05	0.04	0.22	0.22
18	0.04	0.04	0.04	0.04	0.05	0.04	0.05
19	0.24	0.04	0.04	0.04	0.04	0.04	0.24
20	0.03	0.04	0.03	0.04	0.04	0.03	0.04
21	0.07	0.03	0.04	0.06	0.05	0.04	0.07
22	0.05	0.04	0.04	0.04	0.04	0.04	0.05
23	0.04	0.11	0.04	0.10	0.04	0.00	0.11
24	0.04	0.04	0.04	0.04	0.06	0.04	0.06
25	0.05	0.10	0.04	0.04	0.04	0.04	0.10
26	0.04	0.04	0.04	0.05	0.04	0.05	0.05
27	0.04	0.10	0.04	0.04	0.05	0.04	0.10
28	0.04	0.05	0.06	0.03	0.03	0.05	0.06
29	0.10	0.04	0.04	0.05	0.05	0.02	0.10
30	0.05	0.04	0.06	0.04	0.04	0.04	0.06
31	0.04	0.13	0.05	0.04	0.05	0.04	0.13

Conventional or Direct Filtration	Monthly Summary (Answer Yes or No)	
95% of 4-hour turbidity readings $\leq$ 0.3 NTU? Yes / No	CT's met everyday? (see back) Yes / No	All Cl ₂ residual at entry point $\geq$ 0.2 mg/l? Yes / No
All 4-hour turbidity readings $\leq$ 1 NTU? Yes / No		
All turbidity readings < IFE ² triggers Yes / No		

PRINTED NAME: Michael Bollweg	
SIGNATURE: Michael Bollweg	DATE: 11.8.25
PHONE #: (541) 415-1117	CERT #: 5296

¹ Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in columns 12 AM through 8 PM may not correspond to continuous readings' maximum. ² IFE = Individ. Filter Eff. (333-061-0040(1)(d)(B&C))

OHA - Drinking Water Program - Surface Water Quality Data Form

WTP - :

WTP-A

System Name:

City of Rogue River

ID#: 41-00712

Month/Year:

Aug-25

Disinfection *Giardia*
Log Inactive:

0.5

Date / Time	Minimum Cl ₂ Residual at 1st User (C) ³	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? ³	Peak Hourly Demand Flow
	[ppm or mg/L]	[minutes]	C X T	[° C]		formula	Yes / No	[GPM]
1	1.25	76	95	18.0	8.1	17	YES	769
2	1.40	76	106	17.9	8.3	19	YES	779
3	1.41	76	107	18.3	8.4	19	YES	768
4	1.38	76	105	17.7	7.7	15	YES	762
5	1.38	76	105	17.7	7.7	15	YES	761
6	1.77	76	135	16.7	7.7	17	YES	761
7	1.37	76	104	18.2	8.3	19	YES	771
8	1.31	76	100	17.4	7.9	17	YES	768
9	1.10	76	84	17.5	7.7	15	YES	770
10	1.39	76	106	18.0	8.5	20	YES	770
11	1.43	76	109	18.6	8.4	19	YES	762
12	1.40	76	106	19.0	8.5	19	YES	774
13	1.37	76	104	18.9	8.5	19	YES	774
14	1.39	76	106	18.9	8.4	18	YES	781
15	1.45	76	110	18.4	7.9	16	YES	763
16	1.42	76	108	19.1	7.8	15	YES	763
17	1.43	76	109	18.9	7.8	15	YES	764
18	1.05	76	80	18.4	7.8	15	YES	768
19	1.14	76	87	18.2	7.8	15	YES	766
20	1.28	76	97	18.1	8.6	21	YES	772
21	1.27	76	97	18.2	8.4	19	YES	773
22	1.32	76	100	18.5	8.6	20	YES	778
23	1.40	76	106	18.5	8.3	18	YES	763
24	1.39	76	106	18.2	8.4	19	YES	763
25	1.30	76	99	17.2	8.3	20	YES	779
26	1.43	76	109	18.4	8.1	17	YES	764
27	0.99	76	75	18.6	8.1	16	YES	770
28	0.73	76	55	18.5	8.2	16	YES	770
29	1.06	76	81	17.9	8.3	18	YES	768
30	1.59	76	121	17.8	8.1	18	YES	782
31	1.59	76	121	17.6	8.0	18	YES	764

³ If Cl₂ at entry point < 0.2 mg/l or CT not met, notify DWS within 24 hours.

Revised July 2018

Return by 10th of following month by email, fax, or mail to:

dwp.dnce@state.or.us; 971-673-0694; or Drinking Water Services, PO Box 14350, Portland, OR 97293-0350