

OHA - Drinking Water Services -Turbidity Monitoring Report Form

County:

Jackson

Conventional or Direct Filtration

Month/Year:

Sep-25

System Name:

City of Rogue River

ID#: 41-00712

WTP : TP -

WTP-A

Day	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the Day ¹ [NTU]
1	0.18	0.04	0.05	0.05	0.12	0.17	0.18
2	0.05	0.05	0.05	0.12	0.05	0.05	0.12
3	0.04	0.05	0.05	0.06	0.05	0.05	0.06
4	0.05	0.05	0.15	0.05	0.05	0.05	0.15
5	0.05	0.06	0.05	0.05	0.05	0.05	0.06
6	0.05	0.05	0.05	0.06	0.05	0.05	0.06
7	0.05	0.05	0.06	0.05	0.06	0.05	0.06
8	0.05	---	0.08	0.04	0.04	0.05	0.08
9	0.01	0.04	0.05	0.05	0.05	0.06	0.06
10	---	---	0.18	0.06	0.06	0.05	0.18
11	0.07	0.04	0.04	0.06	0.06	0.04	0.07
12	0.18	0.06	0.04	0.07	0.16	0.04	0.18
13	0.04	0.04	0.03	0.04	0.04	0.21	0.21
14	0.04	0.04	0.16	0.04	0.04	0.05	0.16
15	0.05	0.04	0.06	0.07	0.04	0.16	0.16
16	0.08	0.04	0.08	---	0.08	0.03	0.08
17	0.05	0.12	0.05	0.04	---	0.04	0.12
18	0.03	0.12	0.17	---	0.04	0.04	0.17
19	0.11	0.04	0.04	0.05	0.04	0.04	0.11
20	0.04	0.11	0.05	0.04	0.05	---	0.11
21	---	---	0.04	0.04	0.05	0.04	0.05
22	0.04	0.21	0.04	0.04	0.06	0.04	0.21
23	0.06	---	0.03	0.12	0.12	0.04	0.12
24	0.03	0.03	0.07	0.10	0.05	0.04	0.10
25	0.07	0.04	0.04	0.06	0.04	0.04	0.07
26	0.04	0.03	0.04	0.05	0.06	0.08	0.08
27	0.08	---	0.04	0.06	0.06	0.04	0.08
28	---	---	0.04	0.05	---	0.04	0.05
29	0.05	0.07	0.04	0.04	0.07	0.04	0.07
30	0.05	0.04	0.09	0.20	0.06	0.08	0.20

Conventional or Direct Filtration

95% of 4-hour turbidity readings $\leq$ 0.3 NTU?

Yes / No

All 4-hour turbidity readings $\leq$ 1 NTU?

Yes / No

All turbidity readings < IFE² triggers

Yes / No

Monthly Summary (Answer Yes or No)

CT's met everyday?
(see back)

Yes / No

All Cl₂ residual at entry point
 $\geq$ 0.2 mg/l?

Yes / No

PRINTED NAME: Michael Bollweg

SIGNATURE: Michael Bollweg

DATE: 10.6.25

PHONE #: (541) 415-1117

CERT #: 5296

¹ Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in columns 12 AM through 8 PM may not correspond to continuous readings' maximum. ² IFE = Indiv. Filter Effl. (333-061-0040(1)(d)(B&C))

OHA - Drinking Water Program - Surface Water Quality Data Form

WTP - :

WTP-A

System Name:

City of Rogue River

ID#: 41-00712

Month/Year:

Sep-25

Disinfection *Giardia*
Log Inactive:

0.5

Date / Time	Minimum Cl ₂ Residual at 1st User (C) ³	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? ³	Peak Hourly Demand Flow
	[ppm or mg/L]	[minutes]	C X T	[° C]		formula	Yes / No	[GPM]
1	1.47	76	112	17.8	8.3	19	YES	767
2	1.14	76	87	17.9	8.1	17	YES	771
3	1.26	76	96	18.0	8.1	17	YES	768
4	1.40	76	106	17.9	8.1	18	YES	761
5	1.55	76	118	18.4	8.1	17	YES	765
6	1.41	76	107	18.5	8.1	17	YES	775
7	1.41	76	107	18.1	8.1	17	YES	769
8	0.91	76	69	17.3	8.1	17	YES	770
9	1.11	76	84	17.0	7.9	17	YES	763
10	1.02	76	78	17.2	8.0	17	YES	764
11	1.26	76	96	16.8	8.1	19	YES	770
12	1.31	76	100	17.0	8.1	19	YES	768
13	1.30	76	99	16.8	8.2	19	YES	766
14	1.34	76	102	17.1	8.1	18	YES	771
15	1.29	76	98	16.7	8.1	19	YES	764
16	1.54	76	117	16.5	7.9	18	YES	768
17	1.49	76	113	16.0	8.0	20	YES	764
18	1.47	76	112	16.3	8.0	19	YES	769
19	1.20	76	91	16.4	8.0	18	YES	781
20	1.07	76	81	17.0	8.0	17	YES	762
21	1.24	76	94	16.4	8.0	18	YES	767
22	0.70	76	53	16.1	8.0	18	YES	760
23	1.50	76	114	15.5	8.1	21	YES	766
24	1.64	76	125	14.2	8.0	22	YES	769
25	1.48	76	112	14.2	8.0	22	YES	766
26	1.50	76	114	14.0	8.0	22	YES	776
27	1.53	76	116	13.6	8.0	23	YES	770
28	1.49	76	113	14.0	8.0	22	YES	771
29	1.24	76	94	13.9	8.0	22	YES	770
30	0.65	76	49	13.1	7.9	21	YES	765

³ If Cl₂ at entry point < 0.2 mg/l or CT not met, notify DWS within 24 hours.

Revised July 2018

Return by 10th of following month by email, fax, or mail to:

dwp.dmce@state.or.us; 971-673-0694; or Drinking Water Services, PO Box 14350, Portland, OR 97293-0350