

OHA - Drinking Water Services -Turbidity Monitoring Report Form

County: Jackson

Conventional or Direct Filtration

Month/Year: Nov-25

System Name:		City of Rogue River		ID#: 41-00712		WTP : TP - WTP-A	
Day	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the Day ¹ [NTU]
1	0.05	0.04	0.06	0.05	---	0.05	0.06
2	---	---	0.07	0.04	0.03	0.05	0.07
3	---	0.05	---	0.06	0.04	---	0.06
4	0.04	---	0.07	---	0.05	---	0.07
5	0.04	---	---	0.07	0.04	0.04	0.07
6	---	---	0.23	0.05	0.09	---	0.23
7	---	---	---	---	0.06	0.02	0.06
8	0.09	0.04	0.07	0.05	0.06	0.04	0.09
9	---	0.04	0.05	0.04	0.04	0.05	0.05
10	0.06	0.03	---	0.05	0.06	---	0.06
11	---	---	0.08	0.04	0.03	0.06	0.08
12	---	---	0.04	0.06	---	0.05	0.16
13	0.09	---	0.06	0.03	0.10	0.05	0.10
14	0.04	0.04	0.10	0.04	0.04	0.03	0.10
15	0.08	---	0.08	0.04	0.10	0.04	0.10
16	---	---	0.03	0.10	0.09	0.07	0.10
17	0.09	---	0.05	0.03	0.04	0.07	0.09
18	0.06	0.05	0.17	0.06	0.05	0.08	0.17
19	---	---	0.07	---	0.05	---	0.07
20	0.08	---	0.06	0.06	0.05	---	0.08
21	0.07	---	0.07	0.19	---	0.14	0.19
22	---	0.05	---	---	0.06	0.13	0.13
23	0.11	---	---	0.08	0.04	---	0.11
24	---	---	---	---	0.04	0.11	0.11
25	0.07	0.11	0.08	0.07	0.05	0.07	0.11
26	0.07	---	0.05	0.04	0.04	---	0.07
27	0.06	---	0.06	0.05	0.06	---	0.06
28	---	---	0.12	0.08	0.06	---	0.12
29	---	---	0.17	0.07	0.11	---	0.17
30	---	---	0.13	0.06	0.11	0.10	0.13
							0.00

Conventional or Direct Filtration		Monthly Summary (Answer Yes or No)	
95% of 4-hour turbidity readings $\leq$ 0.3 NTU?	Yes / No	CT's met everyday? (see back)	All Cl ₂ residual at entry point $\geq$ 0.2 mg/l?
All 4-hour turbidity readings $\leq$ 1 NTU?	Yes / No	Yes / No	Yes / No
All turbidity readings < IFE ² triggers	Yes / No		

* The PLC that records data to the SCADA was OFF from 2140 hrs 11/5/25 - 0710 hrs on 11/6/25 - Determined with our controls engineer the data we were seeing was interpolated and not actual. Once the interpolation was removed there was no data.

PRINTED NAME: Michael Bollweg	
SIGNATURE: Michael Bollweg	DATE: 12.9.25
PHONE #: (541) 415-1117	CERT #: 5296

¹ Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in columns 12 AM through 8 PM may not correspond to continuous readings' maximum. ² IFE = Individ. Filter Effl. (333-061-0040(1)(d)(B&C))

OHA - Drinking Water Program - Surface Water Quality Data Form
WTP - :
WTP-A
System Name:
City of Rogue River
ID#: 41-00712
Month/Year:
Nov-25
**Disinfection *Giardia*
Log Inactive:**
0.5

Date / Time	Minimum Cl ₂ Residual at 1st User (C) ³	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? ³	Peak Hourly Demand Flow
	[ppm or mg/L]	[minutes]	C X T	[° C]		formula	Yes / No	[GPM]
1	1.39	76	106	9.9	7.9	28	YES	687
2	1.09	76	83	10.1	7.9	27	YES	687
3	1.22	76	93	10.8	7.9	26	YES	694
4	1.20	76	91	10.3	7.9	27	YES	675
5	1.38	76	105	9.7	7.9	28	YES	673
6	0.91	76	69	10.4	7.9	25	YES	684
7	1.45	76	110	10.2	7.9	28	YES	682
8	1.20	76	91	9.5	8.0	29	YES	692
9	1.22	76	93	9.3	7.9	29	YES	685
10	1.20	76	91	9.2	7.9	29	YES	687
11	0.95	76	72	9.5	7.9	27	YES	680
12	1.00	76	76	9.3	7.9	27	YES	686
13	1.02	76	78	10.0	7.9	27	YES	683
14	1.20	76	91	10.3	7.9	26	YES	678
15	1.30	76	99	10.0	7.9	27	YES	673
16	1.21	76	92	9.3	7.8	28	YES	685
17	1.21	76	92	9.0	7.9	29	YES	693
18	0.81	76	62	9.8	7.9	26	YES	675
19	1.20	76	91	9.9	7.8	26	YES	661
20	1.09	76	83	9.6	7.9	28	YES	656
21	1.33	76	101	8.2	7.9	31	YES	661
22	1.22	76	93	7.6	7.9	32	YES	644
23	0.79	76	60	7.1	7.9	31	YES	659
24	0.70	76	53	8.5	7.9	28	YES	656
25	1.08	76	82	8.5	7.9	30	YES	658
26	1.09	76	83	8.9	7.9	29	YES	659
27	1.08	76	82	8.6	7.9	30	YES	661
28	1.19	76	90	7.9	7.9	31	YES	657
29	1.01	76	77	8.0	7.9	30	YES	652
30	0.90	76	68	7.9	7.9	30	YES	656

³ If Cl₂ at entry point < 0.2 mg/l or CT not met, notify DWS within 24 hours.

Revised July 2018

Return by 10th of following month by email, fax, or mail to:

dwp.dmce@state.or.us; 971-673-0694; or Drinking Water Services, PO Box 14350, Portland, OR 97293-0350