

OHA - Drinking Water Services -Turbidity Monitoring Report Form

County: Jackson

Conventional or Direct Filtration

Month/Year: Dec-25

System Name: City of Rogue River ID#: 41-00712 WTP : TP - WTP-A

Day	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the Day ¹ [NTU]
1	---	---	0.07	0.10	0.08	0.08	0.10
2	0.09	0.07	0.05	0.06	0.06	---	0.09
3	0.08	---	0.06	0.09	0.06	0.08	0.09
4	---	0.08	0.03	0.06	---	0.16	0.16
5	---	---	0.07	---	0.10	---	0.10
6	0.10	---	0.06	0.06	0.05	---	0.10
7	0.09	---	0.03	0.05	---	0.07	0.09
8	0.05	---	---	0.08	0.04	0.04	0.08
9	---	---	---	0.06	0.05	0.07	0.07
10	---	0.07	0.05	0.06	0.06	0.08	0.08
11	---	---	0.06	0.10	0.08	0.09	0.10
12	0.14	---	0.08	---	0.07	0.13	0.16
13	---	0.09	0.05	0.09	0.10	0.10	0.10
14	0.08	---	0.08	---	0.12	0.09	0.12
15	---	---	0.08	0.14	0.08	0.10	0.14
16	---	---	0.08	0.11	0.09	0.10	0.11
17	---	0.08	0.09	---	---	---	0.09
18	---	---	---	---	---	---	0.00
19	---	---	---	---	0.13	0.07	0.13
20	---	---	---	---	---	---	0.00
21	---	---	---	---	---	---	0.00
22	---	---	---	---	---	---	0.00
23	---	---	---	---	---	---	0.00
24	---	---	---	---	---	---	0.00
25	---	---	---	---	---	---	0.00
26	---	---	0.09	0.20	---	---	0.20
27	---	---	---	---	---	---	0.00
28	---	---	---	---	---	---	0.00
29	---	---	---	0.12	0.13	0.14	0.14
30	---	---	---	---	---	---	0.00
31	---	---	---	---	---	---	0.00

Conventional or Direct Filtration

Monthly Summary (Answer Yes or No)

95% of 4-hour turbidity readings $\leq$ 0.3 NTU?

Yes / No

All 4-hour turbidity readings $\leq$ 1 NTU?

Yes / No

All turbidity readings < IFE² triggers

Yes / No

CT's met everyday?
(see back)

Yes / No

All Cl2 residual at entry point
 $\geq$ 0.2 mg/l?

Yes / No

* The PLC that records data to the SCADA was OFF from 2140 hrs 11/5/25 - 0710 hrs on 11/6/25 - Determined with our controls engineer the data we were seeing was interpolated and not actual. Once the interpolation was removed there was no data.

PRINTED NAME: Michael Bollweg

SIGNATURE: Michael Bollweg

DATE: 1.8.25

PHONE #: (541) 415-1117

CERT #: 5296

¹ Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in columns 12 AM through 8 PM may not correspond to continuous readings' maximum. ² IFE = Individ. Filter Effl. (333-061-0040(1)(d)(B&C))

OHA - Drinking Water Program - Surface Water Quality Data Form

WTP - :

WTP-A

System Name: City of Rogue River

ID#: 41-00712

Month/Year:

Dec-25

Disinfection *Giardia*
Log Inactive:

0.5

Date / Time	Minimum Cl ₂ Residual at 1st User (C) ³	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? ³	Peak Hourly Demand Flow
	[ppm or mg/L]	[minutes]	C X T	[° C]		formula	Yes / No	[GPM]
1	0.70	76	53	7.8	7.8	29	YES	656
2	1.02	76	78	7.2	8.0	33	YES	650
3	1.22	76	93	7.3	7.9	33	YES	662
4	1.23	76	93	7.0	7.9	33	YES	655
5	1.14	76	87	8.9	7.8	28	YES	647
6	1.22	76	93	8.9	7.9	29	YES	653
7	1.44	76	109	9.5	7.9	29	YES	650
8	1.06	76	81	9.1	7.9	28	YES	653
9	1.26	76	96	10.1	7.9	27	YES	650
10	1.13	76	86	10.2	7.9	27	YES	662
11	1.09	76	83	10.3	7.9	26	YES	658
12	1.32	76	100	9.6	7.9	28	YES	663
13	1.52	76	116	8.8	8.0	31	YES	655
14	1.63	76	124	8.1	8.0	34	YES	656
15	1.40	76	106	8.1	7.9	32	YES	661
16	1.36	76	103	8.9	7.9	29	YES	660
17	1.63	76	124	10.8	7.9	27	YES	647
18								Off
19	1.92	76	146	10.5	7.8	28	YES	647
20								Off
21								Off
22								Off
23								Off
24								Off
25								Off
26	1.48	76	112	11.4	7.7	24	YES	649
27								Off
28								Off
29	0.77	76	59	8.0	7.8	29	YES	656
30								Off
31								Off

³ If Cl₂ at entry point < 0.2 mg/l or CT not met, notify DWS within 24 hours.

Revised July 2018

Return by 10th of following month by email, fax, or mail to:

dwp.dmce@state.or.us; 971-673-0694; or Drinking Water Services, PO Box 14350, Portland, OR 97293-0350