

OHA - Drinking Water Services -Turbidity Monitoring Report Form
Conventional or Direct Filtration

County: **Jackson**
 Month/Year: **Feb-26**

System Name: **City of Rogue River** ID#: **41-00712** WTP : TP - **WTP-A**

Day	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the Day ¹ [NTU]
1	---	---	---	0.04	0.08	0.07	0.08
2	0.07	0.06	0.10	0.09	0.08	0.08	0.10
3	0.07	0.08	0.07	0.06	0.08	0.07	0.08
4	0.07	0.06	0.08	0.07	0.06	0.07	0.08
5	0.06	0.07	0.08	0.10	---	0.07	0.10
6	0.07	0.06	0.07	0.09	---	0.07	0.09
7	0.07	0.07	0.07	0.06	0.07	0.06	0.07
8	---	0.06	0.06	0.06	0.07	0.07	0.07
9	---	---	---	---	---	---	0.00
10	---	---	---	---	---	---	0.00
11	---	---	---	---	---	---	0.00
12	---	---	---	---	---	---	0.00
13	---	---	---	---	---	---	0.00
14	---	---	---	---	---	---	0.00
15	---	---	---	---	---	---	0.00
16	---	---	---	---	---	---	0.00
17	---	---	---	0.15	0.07	---	0.15
18	---	---	0.22	0.15	0.21	---	0.22
19	---	---	---	---	---	---	0.00
20	---	---	---	---	---	---	0.00
21	---	---	---	---	---	---	0.00
22	---	---	---	---	---	---	0.00
23	---	---	---	---	---	---	0.00
24	---	---	---	---	---	---	0.00
25	---	---	---	---	---	---	0.00
26	---	---	---	---	---	---	0.00
27	---	---	---	---	---	---	0.00
28	---	---	---	---	---	---	0.00

Conventional or Direct Filtration	Monthly Summary (Answer Yes or No)
-----------------------------------	------------------------------------

95% of 4-hour turbidity readings ≤ 0.3 NTU? Yes / No All 4-hour turbidity readings ≤ 1 NTU? Yes / No All turbidity readings < IFE ² triggers Yes / No	CT's met everyday? (see back) Yes / No All Cl2 residual at entry point ≥ 0.2 mg/l? Yes / No
---	--

PRINTED NAME: Michael Bollweg SIGNATURE: <i>Michael Bollweg</i> PHONE #: (541) 415-1117	DATE: 3.9.26 CERT #: 5296
---	--

¹ Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in columns 12 AM through 8 PM may not correspond to continuous readings' maximum. ² IFE = Individ. Filter Effl. (333-061-0040(1)(d)(B&C))

