

OHA - Drinking Water Services - Surface Water Quality Data Form

County: Douglas

Cartridge or Bag Filtration

Month/Year: Oct. 2021

System Name:	Umpqua Ranch Cooperative		ID#:	41	00714	WTP ID:	TP-	A
Day	PSI Before Filter	PSI After Filter	PSID	PSID When to Change Filter	Daily Turbidity Reading (NTU)	Highest Reading of the day ¹ (NTU)		
1	45	40	5	30.00	.01	.01		
2	44	39	5	30.00	.01	.01		
3	43	38	5	30.00	.01	.01		
4	44	39	5	30.00	.01	.01		
5	46	40	6	30.00	.02	.02		
6	45	39	6	30.00	.01	.01		
7	48	40	8	30.00	.01	.01		
8	44	38	6	30.00	.01	.01		
9	46	40	6	30.00	.01	.01		
10	44	38	6	30.00	.01	.01		
11	43	38	5	30.00	.01	.01		
12	43	38	5	30.00	.01	.01		
13	47	42	5	30.00	.01	.01		
14	45	40	5	30.00	.01	.01		
15	44	39	5	30.00	.01	.01		
16	43	38	5	30.00	.01	.01		
17	43	38	5	30.00	.01	.01		
18	44	41	3	30.00	.01	.01		
19	42	39	3	30.00	.01	.01		
20	41	38	3	30.00	.01	.01		
21	42	38	4	30.00	.01	.01		
22	45	43	2	30.00	.01	.01		
23	44	40	4	30.00	.01	.01		
24	43	39	4	30.00	.01	.01		
25	41	37	4	30.00	.01	.01		
26	41	38	3	30.00	.01	.01		
27	41	37	4	30.00	.01	.01		
28	48	46	2	30.00	.01	.01		
29	40	48	2	30.00	.01	.01		
30	43	40	3	30.00	.03	.03		
31	44	41	3	30.00	.02	.02		

Cartridge & Bag Filtration		Monthly Summary (Answer Yes or No)	
95% of daily turbidity readings ≤ 1 NTU?	(Yes) / No	CT's met everyday? (see back)	All Cl2 residual at entry point ≥ 0.2 mg/l?
All daily turbidity readings ≤ 5 NTU?	(Yes) / No	(Yes) / No	(Yes) / No
Note: PSI = pounds per square inch PSID = pounds per square inch difference (before filter - after filter) PSID When to Change Filter = look in manual for manufacturer's specifications when to change the filter at what PSID.		PRINTED NAME: Jonathan Woody SIGNATURE: <i>Jonathan Woody</i> PHONE #: (541) 648-6187 DATE: 11-7-21 CERT #: 7232	

¹including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in Daily Turbidity Reading column may not correspond to continuous readings' maximum.

OHA - Drinking Water Services - Surface Water Quality Data Form

WTP: A

System Name: Umpqua Ranch Cooperative

ID#: 41

00714

Month/Year: Oct. 2021

Disinfection GARDOL
Log Inactiv: 0.5

Date / Time	Minimum Or Residual at 1st User (C) ² [ppm or mg/L]	Contact Time (T) [minutes]	Actual CT C X T	Temp [° C]	pH	Required CT formula	CT Met? ² Yes / No	Peak Hourly Demand [GPM]
1	.80	105	.84	16	8.68	22	Yes	70
2	.89	105	.93	15	8.13	33	Yes	70
3	.86	105	.90	15	8.23	33	Yes	70
4	.84	105	.88	15	8.31	33	Yes	70
5	.83	105	.87	15	8.15	33	Yes	70
6	.84	105	.88	14	8.31	33	Yes	70
7	.80	105	.84	13	8.32	33	Yes	70
8	.81	105	.85	13	8.31	33	Yes	70
9	.86	105	.90	13	8.26	33	Yes	70
10	.83	105	.87	13	8.33	33	Yes	70
11	.80	105	.84	13	8.24	33	Yes	70
12	.84	105	.88	12	8.39	33	Yes	70
13	.81	105	.85	13	8.43	33	Yes	70
14	.85	105	.89	13	8.56	33	Yes	70
15	.84	105	.88	14	8.41	33	Yes	70
16	.89	105	.93	14	8.39	33	Yes	70
17	.82	105	.86	13	8.43	33	Yes	70
18	.80	105	.84	13	8.26	33	Yes	70
19	.82	105	.86	13	8.18	33	Yes	70
20	.84	105	.88	13	8.24	33	Yes	70
21	.83	105	.87	13	8.38	33	Yes	70
22	.79	105	.82	13	8.34	33	Yes	70
23	.81	105	.85	14	8.41	33	Yes	70
24	.83	105	.87	14	8.31	33	Yes	70
25	.85	105	.89	14	8.36	33	Yes	70
26	.83	105	.87	14	8.42	33	Yes	70
27	.81	105	.85	14	8.47	33	Yes	70
28	.84	105	.88	14	8.13	33	Yes	70
29	.83	105	.87	15	8.22	33	Yes	70
30	.82	105	.86	15	8.29	33	Yes	70
31	.78	105	.81	15	8.33	33	Yes	70

² If Cl2 at entry point < 0.2 mg/l or CT not met, notify DWS within 24 hours.

Return by 10th of following month by email, fax, or mail to:

Two DWS Contacts or Us: 971-673-0694; or Drinking Water Services, PO Box 14360, Portland, OR 97293-0360

Revised July 2018