

OHA - Drinking Water Services - Surface Water Quality Data Form

County: Douglas

Cartridge or Bag Filtration

Month/Year: Nov-21

System Name: Umpqua Ranch Cooperative		ID#: 41 00714		WTP ID: TP- A		
Day	PSI Before Filter	PSI After Filter	PSID	PSID When to Change Filter	Daily Turbidity Reading [NTU]	Highest Reading of the day ¹ [NTU]
1	41.00	38.00	3.00	30.00	0.02	0.02
2	44.00	41.00	3.00	30.00	0.02	0.02
3	43.00	38.00	5.00	30.00	0.01	0.01
4	42.00	37.00	5.00	30.00	0.01	0.01
5	44.00	39.00	5.00	30.00	0.01	0.01
6	41.00	36.00	5.00	30.00	0.02	0.02
7	45.00	41.00	4.00	30.00	0.06	0.06
8	45.00	40.00	5.00	30.00	0.02	0.02
9	44.00	39.00	5.00	30.00	0.01	0.01
10	45.00	40.00	5.00	30.00	0.01	0.01
11	42.00	37.00	5.00	30.00	0.01	0.01
12	42.00	37.00	5.00	30.00	0.01	0.01
13	42.00	37.00	5.00	30.00	0.01	0.01
14	43.00	38.00	5.00	30.00	0.01	0.01
15	42.00	37.00	5.00	30.00	0.01	0.01
16	42.00	38.00	4.00	30.00	0.01	0.01
17	50.00	46.00	4.00	30.00	0.10	0.01
18	42.00	38.00	4.00	30.00	0.01	0.01
19	42.00	38.00	4.00	30.00	0.02	0.02
20	44.00	38.00	6.00	30.00	0.02	0.02
21	44.00	38.00	6.00	30.00	0.02	0.02
22	40.00	39.00	1.00	30.00	0.02	0.02
23	44.00	40.00	4.00	30.00	0.02	0.02
24	40.00	38.00	2.00	30.00	0.01	0.01
25	42.00	39.00	3.00	30.00	0.02	0.02
26	46.00	42.00	4.00	30.00	0.01	0.01
27	45.00	41.00	4.00	30.00	0.01	0.01
28	42.00	38.00	4.00	30.00	0.01	0.01
29	41.00	38.00	3.00	30.00	0.02	0.02
30	46.00	42.00	4.00	30.00	0.02	0.02
31						

Cartridge & Bag Filtration 95% of daily turbidity readings ≤ 1 NTU? <input checked="" type="radio"/> Yes / No All daily turbidity readings ≤ 5 NTU? <input checked="" type="radio"/> Yes / No		Monthly Summary (Answer Yes or No) CT's met everyday? (see back) <input checked="" type="radio"/> Yes / No All Cl2 residual at entry point ≥ 0.2 mg/l? <input checked="" type="radio"/> Yes / No	
Notes: PSI = pounds per square inch PSID = pounds per square inch difference (before filter - after filter) PSID When to Change Filter = look in manual for manufacturer's specifications when to change the filter at what PSID.		PRINTED NAME: <i>Jonathan Woody</i> SIGNATURE: <i>John Woody</i> DATE: 12-7-21 PHONE #: (541) 643-6137 CERT #: 7232	

¹ Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in Daily Turbidity Reading column may not correspond to continuous readings' maximum.

OHA - Drinking Water Services - Surface Water Quality Data Form

WTP- : A

System Name: Umpqua Ranch Cooperative	ID#: 41 00714	Month/Year: Nov-21	Disinfection Giardia Log Inactiv: 0.5
---------------------------------------	---------------	--------------------	---

Date / Time	Minimum Cl ₂ Residual at 1st User (C) ²	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? ²	Peak Hourly Demand Flow
	[ppm or mg/L]	[minutes]	C X T	[° C]		formula	Yes / No	[GPM]
1	0.8	105	84.0	15.0	8.41	22.4	YES	70
2	0.83	105	87.2	15.0	8.48	23.1	YES	70
3	0.79	105	83.0	16.0	8.39	20.8	YES	70
4	0.77	105	80.9	16.0	8.56	22.1	YES	70
5	0.79	105	83.0	16.0	8.39	20.8	YES	70
6	0.8	105	84.0	16.0	8.44	21.2	YES	70
7	0.79	105	83.0	15.0	8.41	22.4	YES	70
8	0.8	105	84.0	11.0	8.06	25.6	YES	70
9	0.83	105	87.2	12.0	8.14	24.8	YES	70
10	0.81	105	85.1	12.0	8.24	25.6	YES	70
11	0.84	105	88.2	12.0	8.36	26.8	YES	70
12	0.42	105	44.1	12.0	8.08	23.1	YES	70
13	0.68	105	71.4	12.0	8.11	24.1	YES	70
14	0.74	105	77.7	13.0	8.08	22.5	YES	70
15	0.62	105	65.1	12.0	8.26	25.2	YES	70
16	0.7	105	73.5	12.0	8.32	26.0	YES	70
17	0.69	105	72.5	12.0	8.41	26.8	YES	70
18	0.74	105	77.7	11.0	8.36	28.4	YES	70
19	0.81	105	85.1	11.0	8.24	27.4	YES	70
20	0.9	105	94.5	10.0	8.08	27.9	YES	70
21	0.93	105	97.7	10.0	8.16	28.9	YES	70
22	0.92	105	96.6	10.0	8.11	28.3	YES	70
23	0.9	105	94.5	10.0	8.26	29.8	YES	70
24	0.85	105	89.3	9.0	8.32	32.4	YES	70
25	0.88	105	92.4	10.0	8.41	31.4	YES	70
26	1.02	105	107.1	11.0	8.10	26.7	YES	70
27	1.07	105	112.4	11.0	8.12	27.0	YES	70
28	1.09	105	114.5	10.0	8.21	29.9	YES	70
29	0.96	105	100.8	10.0	8.29	30.3	YES	70
30	0.91	105	95.6	11.0	8.36	28.9	YES	70
31								

² If Cl₂ at entry point < 0.2 mg/l or CT not met, notify DWS within 24 hours.

Return by 10th of following month by email, fax, or mail to:

dwp.dmsc@state.or.us; 971-673-0694; or Drinking Water Services, PO Box 14350, Portland, OR 97293-0350

Revised July 2018