

OHA - Drinking Water Services - Surface Water Quality Data Form

County: Douglas

Cartridge or Bag Filtration

Month/Year: Jan-22

System Name: Umpqua Ranch Cooperative		ID#: 41	00714	WTP ID: TP- A		
Day	PSI Before Filter	PSI After Filter	PSID	PSID When to Change Filter	Daily Turbidity Reading [NTU]	Highest Reading of the day ¹ [NTU]
1	42.00	38.00	4.00	30.00	0.01	0.02
2	42.00	38.00	4.00	30.00	0.01	0.02
3	42.00	38.00	4.00	30.00	0.01	0.01
4	42.00	38.00	4.00	30.00	0.02	0.02
5	60.00	30.00	30.00	30.00	0.26	0.26
6	44.00	40.00	4.00	30.00	0.02	0.02
7	43.00	40.00	3.00	30.00	0.03	0.03
8	43.00	40.00	3.00	30.00	0.06	0.06
9	44.00	40.00	4.00	30.00	0.03	0.03
10	45.00	41.00	4.00	30.00	0.02	0.02
11	53.00	50.00	3.00	30.00	0.03	0.03
12	42.00	38.00	4.00	30.00	0.02	0.02
13	42.00	38.00	4.00	30.00	0.02	0.02
14	43.00	38.00	5.00	30.00	0.01	0.01
15	42.00	38.00	4.00	30.00	0.02	0.02
16	42.00	38.00	4.00	30.00	0.02	0.02
17	50.00	45.00	5.00	30.00	0.02	0.02
18	43.00	38.00	5.00	30.00	0.02	0.02
19	43.00	38.00	5.00	30.00	0.01	0.01
20	43.00	38.00	5.00	30.00	0.02	0.02
21	43.00	39.00	4.00	30.00	0.01	0.01
22	35.00	30.00	5.00	30.00	0.02	0.02
23	43.00	38.00	5.00	30.00	0.02	0.02
24	43.00	38.00	5.00	30.00	0.02	0.02
25	43.00	38.00	5.00	30.00	0.02	0.02
26	46.00	41.00	5.00	30.00	0.01	0.01
27	45.00	40.00	5.00	30.00	0.01	0.01
28	47.00	42.00	5.00	30.00	0.03	0.03
29	45.00	40.00	5.00	30.00	0.02	0.02
30	43.00	38.00	5.00	30.00	0.01	0.02
31	42.00	37.00	5.00	30.00	0.02	0.02

Cartridge & Bag Filtration	Monthly Summary (Answer Yes or No)	
95% of daily turbidity readings ≤ 1 NTU? <input checked="" type="radio"/> Yes / <input type="radio"/> No	CT's met everyday? (see back) <input checked="" type="radio"/> Yes / <input type="radio"/> No	All Cl2 residual at entry point ≥ 0.2 mg/l? <input checked="" type="radio"/> Yes / <input type="radio"/> No
All daily turbidity readings ≤ 5 NTU? <input checked="" type="radio"/> Yes / <input type="radio"/> No		
Notes: PSI = pounds per square inch	PRINTED NAME: <i>Jonathan Woody</i>	
PSID = pounds per square inch difference (before filter - after filter)	SIGNATURE: <i>John E. Woody</i>	DATE: 2-8-22
PSID When to Change Filter = look in manual for manufacturer's specifications when to change the filter at what PSID	PHONE #: (541) 643-6137	CERT #: 7252

¹ Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in Daily Turbidity Reading column may not correspond to continuous readings' maximum.

OHA - Drinking Water Services - Surface Water Quality Data Form

WTP: A

System Name: Umpqua Ranch Cooperative ID#: 41 00714 Month/Year: Jan-22

Disinfection
Giardia Log
Inactiv:

0.5

Date / Time	Minimum Cl ₂ Residual at 1st User (C) ²	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? ²	Peak Hourly Demand Flow
	[ppm or mg/L]	[minutes]	C X T	[° C]		formula	Yes / No	[GPM]
1	0.84	105	88.2	6.0	8.21	38.2	YES	70
2	0.98	105	102.9	10.0	8.05	27.9	YES	70
3	0.84	105	88.2	10.0	8.13	28.3	YES	70
4	0.9	105	94.5	10.0	8.24	29.6	YES	70
5	0.86	105	90.3	10.0	8.42	31.4	YES	70
6	0.81	105	85.1	11.0	8.31	28.1	YES	70
7	0.85	105	89.3	10.0	8.48	32.1	YES	70
8	0.8	105	84.0	11.0	8.32	28.1	YES	70
9	0.66	105	69.3	12.0	8.20	24.8	YES	70
10	0.85	105	89.3	12.0	8.24	25.7	YES	70
11	0.9	105	94.5	12.0	8.26	26.1	YES	70
12	0.88	105	92.4	12.0	8.03	23.9	YES	70
13	0.68	105	71.4	11.0	8.04	25.1	YES	70
14	0.6	105	63.0	10.0	8.06	26.8	YES	70
15	0.74	105	77.7	10.0	8.21	28.7	YES	70
16	0.79	105	83.0	10.0	8.26	29.4	YES	70
17	0.83	105	87.2	11.0	8.29	27.9	YES	70
18	0.82	105	86.1	11.0	8.34	28.4	YES	70
19	0.81	105	85.1	11.0	8.41	29.1	YES	70
20	0.84	105	88.2	11.0	8.38	28.9	YES	70
21	0.81	105	85.1	11.0	8.49	30.0	YES	70
22	0.83	105	87.2	11.0	8.53	30.5	YES	70
23	0.86	105	90.3	11.0	8.43	29.5	YES	70
24	0.95	105	99.8	11.0	8.44	29.9	YES	70
25	0.91	105	95.6	11.0	8.41	29.4	YES	70
26	0.93	105	97.7	10.0	8.39	31.4	YES	70
27	0.75	105	78.8	9.0	8.13	29.9	YES	70
28	0.78	105	81.9	9.0	8.22	31.0	YES	70
29	0.8	105	84.0	9.0	8.29	31.9	YES	70
30	0.79	105	83.0	9.0	8.39	33.0	YES	70
31	0.83	105	87.2	9.0	8.11	30.0	YES	70

² If Cl₂ at entry point < 0.2 mg/l or CT not met, notify DWS within 24 hours.

Revised July 2018

Return by 10th of following month by email, fax, or mail to:

dwp.dnce@state.or.us; 971-873-0694; or Drinking Water Services, PO Box 14350, Portland, OR 97293-0350