


OHA - Drinking Water Program - Surface Water Quality Data Form
Slow Sand, Membrane, Diatomaceous Earth Filtration, or Unfiltered Systems(Douglas County)

System Name: G.A.W.S.A. ID#: 41 00717 "A" Mar-22

Day	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the day ¹ [NTU]
1	0.050	0.050	0.051	0.050	0.050	OFF	0.058
2	OFF	OFF	0.051	0.051	0.051	OFF	0.053
3	OFF	OFF	0.051	0.052	OFF	0.053	0.062
4	0.052	0.052	0.052	0.052	0.052	0.052	0.053
5	OFF	OFF	OFF	0.053	0.052	0.053	0.054
6	OFF	OFF	OFF	0.053	0.052	0.053	0.054
7	OFF	OFF	0.053	0.053	0.053	OFF	0.053
8	OFF	OFF	0.054	0.053	0.053	0.054	0.055
9	0.054	0.054	0.057	OFF	0.054	0.054	0.059
10	0.055	OFF	OFF	OFF	0.055	0.055	0.055
11	0.056	OFF	OFF	0.056	0.056	OFF	0.057
12	OFF	OFF	0.057	0.057	0.058	0.057	0.058
13	OFF	OFF	0.057	OFF	OFF	OFF	0.060
14	OFF	OFF	OFF	0.038	0.037	0.037	0.038
15	0.037	0.037	0.038	OFF	0.038	0.038	0.038
16	0.038	0.037	OFF	0.037	0.037	OFF	0.041
17	OFF	OFF	0.038	0.038	0.038	0.038	0.042
18	OFF	OFF	0.038	0.038	0.038	OFF	0.038
19	OFF	OFF	0.038	0.038	OFF	OFF	0.038
20	OFF	0.039	0.039	0.038	OFF	0.039	0.039
21	0.039	0.039	0.039	0.039	0.039	0.039	0.048
22	OFF	OFF	OFF	0.039	0.039	OFF	0.040
23	OFF	OFF	0.040	0.040	0.039	OFF	0.042
24	0.040	0.040	0.040	0.040	0.041	OFF	0.043
25	0.041	0.041	0.040	0.040	0.041	OFF	0.041
26	0.041	0.041	0.041	0.042	OFF	0.041	0.042
27	0.042	0.042	OFF	OFF	0.042	0.042	0.044
28	0.042	OFF	OFF	0.042	0.042	0.042	0.045
29	OFF	OFF	OFF	0.042	0.042	0.043	0.045
30	OFF	OFF	0.043	0.043	0.043	OFF	0.045
31	OFF	0.043	0.043	0.044	0.043	0.044	0.044

Slow Sand/Membrane/DE Filtration/Unfiltered 95% of daily turbidity readings ≤ 1 NTU? ² <u>Yes</u> / No All daily turbidity readings ≤ 5 NTU? <u>Yes</u> / No		Monthly Summary (Answer Yes or No) CT's met everyday? (see back) <u>Yes</u> / No All Cl2 residual at entry point ≥ 0.2 mg/l? <u>Yes</u> / No	
Notes:		PRINTED NAME: Jeremy Wolford	
		SIGNATURE: 	DATE: 4/4/2022
		PHONE #: 541-679-6321	CERT #: T-7231

¹ Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in columns 12 AM through 8 PM may not correspond to continuous readings' maximum. ² Filtered systems only.

OHA - Drinking Water Program - Surface Water Quality Data Form(Douglas County)

System Name: G.A.W.S.A. ID#: 41 00717 "A" Mar-22

Date / Time	Residual at 1st User (C) ³	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? ³	Peak Hourly Demand Flow
	[ppm or mg/L]	[minutes]	C X T	[° C]		formula	Yes / No	[GPM]
1/ 18:00	1.416	14.79	20.9	15.1	7.59	3.8	YES	1139
2/ 23:00	1.402	14.79	20.7	9.8	7.48	5.2	YES	1139
3/ 19:00	1.185	14.58	17.3	10.2	7.23	4.5	YES	1156
4/ 18:00	1.269	14.18	18.0	10.5	7.34	4.6	YES	1188
5/ 22:00	1.273	14.58	18.6	9.6	7.45	5.1	YES	1156
6/ 13:00	1.389	14.38	20.0	9.7	7.31	4.9	YES	1172
7/ 22:00	1.246	14.38	17.9	11.7	7.81	5.0	YES	1172
8/ 3:00	1.341	15.45	20.7	7.1	7.71	6.7	YES	1090
9/ 16:00	1.399	14.79	20.7	18.6	7.52	2.9	YES	1139
10/ 21:00	1.277	15.00	19.2	13.1	8.05	5.0	YES	1123
11/ 23:00	1.182	14.58	17.2	12.4	8.01	5.1	YES	1156
12/ 20:00	1.271	15.68	19.9	11.7	7.79	5.0	YES	1074
13/ 8:00	1.243	15.68	19.5	7.9	7.47	5.8	YES	1074
14/ 22:00	1.281	15.00	19.2	10.9	7.61	5.0	YES	1123
15/ 17:00	1.282	14.38	18.4	18.9	7.41	2.7	YES	1172
16/ 22:00	1.279	14.38	18.4	14.1	7.63	4.1	YES	1172
17/ 16:00	1.344	14.79	19.9	15.6	7.27	3.2	YES	1139
18/ 18:00	1.300	14.58	19.0	18.6	7.58	2.9	YES	1156
19/ 8:00	1.196	14.58	17.4	10.2	7.35	4.7	YES	1156
20/ 13:00	1.258	15.00	18.9	8.6	7.18	4.9	YES	1123
21/ 17:00	1.322	15.00	19.8	12.3	7.36	4.2	YES	1123
22/ 11:00	1.347	15.00	20.2	11.6	7.31	4.3	YES	1123
23/ 19:00	1.209	15.22	18.4	16.9	7.53	3.2	YES	1107
24/ 18:00	1.111	13.81	15.3	25.0	7.37	1.7	YES	1221
25/ 23:00	1.139	15.22	17.3	15.8	7.66	3.6	YES	1107
26/ 4:00	1.134	14.79	16.8	12.4	7.56	4.4	YES	1139
27/ 21:00	1.170	15.00	17.6	15.1	7.39	3.4	YES	1123
28/ 15:00	1.266	14.38	18.2	17.8	7.13	2.6	YES	1172
29/ 7:00	1.197	14.58	17.4	13.0	7.19	3.7	YES	1156
30/ 18:00	1.180	14.38	17.0	17.2	7.32	2.9	YES	1172
31/ 8:00	1.166	14.38	16.8	9.2	7.18	4.7	YES	1172

³ If Cl2 at entry point < 0.2 mg/l or CT not met, DWP to be notified by end of next business day.

Oregon DHS - Drinking Water Program – Surface Water Quality Data

System Name: G. A. W. S. A.


PWS ID#: 41 00717 Month/Year: 3/2022

Minimum UVT [%] during month: 99.8%

Duty sensor variation from reference sensor: 5.1 %

Minimum Validated UVT: 99.8% {Insert Req'd Value}

Date	Peak Hourly Demand Flow	Minimum Intensity	All Lamps On?	Daily Water Produced {A}	Water outside Validated Conditions {B}	Cumulative % Off-Spec Water Produced
	[gpm]	[^{mW} /cm ²]	[Y or N]	[gal]	[gal]	(Mo. Sum {B}) ÷ (Mo. Sum {A}) * 100 [%]
1	2900	18.2	Y	984,068	0	0
2	2900	20.1	Y	1,020,649	0	0
3	2900	17.3	Y	1,085,759	0	0
4	2900	16.7	Y	959,002	0	0
5	2900	17.9	Y	1,012,719	0	0
6	2900	18.3	Y	1,020,586	0	0
7	2900	17.1	Y	1,050,888	0	0
8	2900	17.1	Y	1,168,802	0	0
9	2900	16.0	Y	1,193,724	0	0
10	2900	19.5	Y	1,055,825	0	0
11	2900	17.5	Y	1,023,012	0	0
12	2900	19.5	Y	1,001,303	0	0
13	2900	10.8	Y	729,976	0	0
14	2900	17.8	Y	1,108,024	0	0
15	2900	19.6	Y	1,495,310	0	0
16	2900	19.8	Y	1,312,835	0	0
17	2900	17.4	Y	1,121,983	0	0
18	2900	18.9	Y	1,059,217	0	0
19	2900	19.4	Y	1,006,537	0	0
20	2900	19.5	Y	974,019	0	0
21	2900	19.6	Y	1,260,800	0	0
22	2900	19.5	Y	1,077,309	0	0
23	2900	18.6	Y	1,051,538	0	0
24	2900	12.6	Y	1,069,323	0	0
25	2900	17.5	Y	1,204,469	0	0
26	2900	17.4	Y	1,034,445	0	0
27	2900	19.2	Y	1,048,279	0	0
28	2900	19.5	Y	1,167,580	0	0
29	2900	21.5	Y	1,029,087	0	0
30	2900	19.7	Y	1,033,861	0	0
31	2900	19.5	Y	1,099,729	0	0
Monthly Cumulative % Off-Spec Water Produced						

Signature: 

Op Cert #: J-7231 Date: 4/4/22