


OHA - Drinking Water Program - Surface Water Quality Data Form
Slow Sand, Membrane, Diatomaceous Earth Filtration, or Unfiltered Systems(Douglas County)

System Name: G.A.W.S.A. ID#: 41 00717 "A" Jul-22

Day	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the day ¹ [NTU]
1	0.038	0.038	0.037	0.037	0.038	0.038	0.046
2	0.038	OFF	OFF	OFF	0.038	0.038	0.039
3	0.038	OFF	OFF	0.038	0.038	0.038	0.042
4	0.039	0.038	0.038	OFF	OFF	OFF	0.042
5	OFF	0.040	0.039	0.039	0.039	OFF	0.040
6	OFF	0.039	0.039	OFF	OFF	0.040	0.041
7	0.040	OFF	OFF	0.040	0.040	OFF	0.045
8	OFF	0.041	0.040	0.027	0.027	0.027	0.041
9	0.027	0.027	0.027	0.027	0.027	0.028	0.033
10	0.027	0.027	0.028	0.027	0.027	OFF	0.030
11	0.028	0.028	0.028	0.028	0.028	0.028	0.034
12	0.028	0.028	0.028	OFF	0.028	0.028	0.031
13	0.028	0.029	0.028	0.028	0.029	0.029	0.029
14	0.029	0.029	0.029	0.029	0.029	0.029	0.029
15	0.029	0.029	0.029	0.029	0.029	0.029	0.031
16	0.029	0.029	0.029	0.030	0.029	0.030	0.037
17	0.030	OFF	0.030	0.029	OFF	0.030	0.041
18	OFF	OFF	0.030	0.030	0.030	0.030	0.034
19	0.030	0.030	0.030	0.030	0.030	0.031	0.034
20	0.030	0.031	0.030	0.031	0.031	0.031	0.061
21	0.031	0.031	0.031	OFF	0.031	0.031	0.033
22	0.031	0.032	0.031	0.031	0.032	0.031	0.040
23	0.031	0.031	0.031	0.032	0.031	0.031	0.033
24	0.031	0.031	0.031	0.031	0.032	OFF	0.052
25	0.032	0.032	0.032	0.032	0.033	0.032	0.034
26	0.033	0.033	0.033	0.033	0.033	0.033	0.035
27	0.033	0.033	0.033	OFF	0.034	0.033	0.036
28	0.036	0.033	0.033	0.034	0.034	0.034	0.036
29	0.034	OFF	0.034	0.035	0.038	0.035	0.051
30	0.035	0.037	0.035	0.036	0.036	0.036	0.038
31	0.036	OFF	0.035	OFF	0.037	0.053	0.062

Slow Sand/Membrane/DE Filtration/Unfiltered		Monthly Summary (Answer Yes or No)	
95% of daily turbidity readings ≤ 1 NTU? ²	<u>Yes</u> / No	CT's met everyday? (see back)	All Cl2 residual at entry point ≥ 0.2 mg/l?
All daily turbidity readings ≤ 5 NTU?	<u>Yes</u> / No	<u>Yes</u> / No	<u>Yes</u> / No

Notes:	PRINTED NAME: Jeremy Wolford	
	SIGNATURE: 	DATE: 8/1/2022
	PHONE #: 541-679-6321	CERT #: T-7231

¹ Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in columns 12 AM through 8 PM may not correspond to continuous readings' maximum. ² Filtered systems only.

Oregon DHS - Drinking Water Program – Surface Water Quality Data

System Name: G. A. U. S. A.

PWS ID#: 4100717 Month/Year: 7/2022

Minimum UVT [%] during month: 99.8%

Duty sensor variation from reference sensor: 5.8%

Minimum Validated UVT : 99.8% {Insert Req'd Value}

Date	Peak Hourly Demand Flow	Minimum Intensity	All Lamps On?	Daily Water Produced {A}	Water outside Validated Conditions {B}	Cumulative % Off-Spec Water Produced
	[gpm]	[^{mW} /cm ²]	[Y or N]	[gal]	[gal]	(Mo. Sum {B}) ÷ (Mo. Sum {A}) * 100 [%]
1	2900	17.7	Y	1,792,024	0	0
2	2900	18.6	Y	1,723,325	0	0
3	2900	17.8	Y	1,725,527	0	0
4	2900	18.4	Y	1,745,463	0	0
5	2900	18.5	Y	1,757,785	0	0
6	2900	17.9	Y	1,367,202	0	0
7	2900	24.4	Y	1,533,215	0	0
8	2900	17.7	Y	1,730,559	0	0
9	2900	17.0	Y	1,739,280	0	0
10	2900	18.4	Y	1,609,607	0	0
11	2900	17.5	Y	1,485,018	0	0
12	2900	17.6	Y	2,176,408	0	0
13	2900	17.0	Y	2,035,118	0	0
14	2900	17.3	Y	2,219,339	0	0
15	2900	10.6	Y	2,333,765	0	0
16	2900	10.1	Y	2,052,487	0	0
17	2900	10.5	Y	1,783,030	0	0
18	2900	19.0	Y	1,902,329	0	0
19	2900	17.6	Y	2,246,337	0	0
20	2900	16.6	Y	1,718,564	0	0
21	2900	16.9	Y	1,901,767	0	0
22	2900	17.4	Y	2,208,357	0	0
23	2900	17.4	Y	2,503,640	0	0
24	2900	17.8	Y	2,702,998	0	0
25	2900	18.4	Y	1,965,157	0	0
26	2900	16.8	Y	2,528,364	0	0
27	2900	17.4	Y	2,044,065	0	0
28	2900	17.9	Y	2,530,308	0	0
29	2900	18.1	Y	2,009,991	0	0
30	2900	16.9	Y	2,537,507	0	0
31	2900	17.3	Y	2,317,795	0	0
Monthly Cumulative % Off-Spec Water Produced						0

Signature: 

Op Cert #: T-7231 Date: 8/1/22