


OHA - Drinking Water Program - Surface Water Quality Data Form
Slow Sand, Membrane, Diatomaceous Earth Filtration, or Unfiltered Systems(Douglas County)

System Name: G.A.W.S.A.		ID#: 41 00717			"A"		Feb-23
Day	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the day ¹ [NTU]
1	0.041	OFF	OFF	0.044	OFF	0.036	0.044
2	0.036	OFF	OFF	0.036	0.036	OFF	0.036
3	OFF	0.036	0.036	0.036	0.037	0.037	0.037
4	OFF	OFF	0.036	0.037	OFF	OFF	0.038
5	0.037	0.037	0.037	OFF	0.037	0.037	0.037
6	0.037	OFF	OFF	0.037	0.037	0.037	0.037
7	0.037	OFF	OFF	0.037	0.037	0.039	0.041
8	OFF	OFF	0.038	0.037	0.038	0.038	0.038
9	OFF	OFF	0.038	OFF	0.038	0.038	0.038
10	0.038	OFF	OFF	0.040	0.038	OFF	0.040
11	OFF	0.039	0.040	0.039	OFF	OFF	0.040
12	0.040	0.040	OFF	OFF	0.040	0.040	0.043
13	OFF	OFF	OFF	0.041	0.041	OFF	0.053
14	0.041	OFF	0.041	OFF	OFF	0.042	0.042
15	0.042	OFF	OFF	0.043	0.042	0.043	0.060
16	OFF	OFF	0.043	0.043	OFF	0.043	0.043
17	0.043	0.043	OFF	OFF	0.060	OFF	0.060
18	0.044	0.044	0.044	OFF	0.044	0.044	0.045
19	0.044	OFF	OFF	0.044	0.044	0.044	0.045
20	OFF	OFF	0.045	0.046	OFF	0.045	0.046
21	0.046	0.045	0.046	0.045	0.046	0.046	0.046
22	OFF	OFF	0.046	OFF	0.046	0.046	0.053
23	0.046	OFF	OFF	0.048	OFF	0.047	0.048
24	0.047	0.047	0.048	OFF	0.047	0.048	0.049
25	0.047	OFF	OFF	0.048	0.048	0.048	0.049
26	OFF	OFF	0.048	0.048	OFF	0.048	0.048
27	0.048	0.048	OFF	0.048	0.049	OFF	0.055
28	OFF	0.049	0.049	0.049	0.049	OFF	0.052
29							
30							
31							

Slow Sand/Membrane/DE Filtration/Unfiltered		Monthly Summary (Answer Yes or No)	
95% of daily turbidity readings ≤ 1 NTU? ²	Yes / No	CT's met everyday? (see back)	Yes / No
All daily turbidity readings ≤ 5 NTU?	Yes / No	All Cl2 residual at entry point ≥ 0.2 mg/l?	Yes / No
Notes:		PRINTED NAME: Jeremy Wolford	
		SIGNATURE: 	DATE: 3/1/23
		PHONE #: 541-679-6321	CERT #: T-7231

¹ Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in columns 12 AM through 8 PM may not correspond to continuous readings' maximum. ² Filtered systems only.

OHA - Drinking Water Program - Surface Water Quality Data Form (Douglas County)

System Name: G.A.W.S.A. ID#: 41 00717 "A" Feb-23

Date / Time	Residual at 1st User (C) ³	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? ³	Peak Hourly Demand Flow
	[ppm or mg/L]	[minutes]	C X T	[° C]		formula	Yes / No	[GPM]
1/ 21:00	1.293	14.79	19.1	8.7	7.57	5.7	YES	1139
2/ 16:00	1.361	13.99	19.0	4.6	7.42	7.2	YES	1204
3/ 3:00	1.383	14.38	19.9	1.4	7.54	9.4	YES	1172
4/ 13:00	1.408	14.58	20.5	11.3	7.50	4.7	YES	1156
5/ 9:00	1.206	14.58	17.6	6.5	7.62	6.6	YES	1156
6/ 11:00	1.245	13.99	17.4	6.6	7.10	5.5	YES	1204
7/ 11:00	1.125	14.58	16.4	5.9	7.45	6.5	YES	1156
8/ 22:00	1.452	14.79	21.5	7.7	7.95	7.1	YES	1139
9/ 7:00	1.258	15.22	19.1	5.4	7.95	8.1	YES	1107
10/ 12:00	1.427	14.58	20.8	8.8	7.15	4.9	YES	1156
11/ 18:00	1.303	14.58	19.0	17.5	7.80	3.4	YES	1156
12/ 14:00	1.404	14.58	20.5	19.9	7.58	2.7	YES	1156
13/ 2:00	1.126	15.22	17.1	7.6	8.15	7.4	YES	1107
14/ 19:00	1.254	15.00	18.8	10.5	7.68	5.2	YES	1123
15/ 22:00	1.018	15.22	15.5	8.1	8.01	6.7	YES	1107
16/ 14:00	1.415	14.18	20.1	10.5	7.23	4.5	YES	1188
17/ 11:00	1.428	14.58	20.8	3.7	7.62	8.3	YES	1156
18/ 10:00	1.493	15.00	22.4	3.6	7.48	8.0	YES	1123
19/ 21:00	1.209	14.38	17.4	11.3	8.08	5.7	YES	1172
20/ 13:00	1.506	14.38	21.7	9.3	7.62	5.7	YES	1172
21/ 5:00	1.277	15.00	19.2	8.9	7.97	6.5	YES	1123
22/ 20:00	1.322	14.79	19.5	5.0	7.62	7.5	YES	1139
23/ 20:00	1.453	15.00	21.8	3.8	7.53	8.0	YES	1123
24/ 21:00	1.348	15.00	20.2	8.0	7.68	6.3	YES	1123
25/ 16:00	1.491	14.58	21.7	19.7	7.65	2.9	YES	1156
26/ 20:00	1.437	14.79	21.2	7.9	7.87	6.8	YES	1139
27/ 17:00	1.442	14.18	20.5	6.4	7.50	6.6	YES	1188
28/ 17:00	1.600	14.18	22.7	7.2	7.31	5.9	YES	1188

³ If Cl2 at entry point < 0.2 mg/l or CT not met, DWP to be notified by end of next business day.

Oregon DHS - Drinking Water Program – Surface Water Quality Data

System Name: G.A.W.S.A.

PWS ID#: 41 00717 Month/Year: 2/2023

Minimum UVT [%] during month: 59.9%

Duty sensor variation from reference sensor: 65%

Minimum Validated UVT: 97.8 {Insert Req'd Value}

Date	Peak Hourly Demand Flow	Minimum Intensity	All Lamps On?	Daily Water Produced {A}	Water outside Validated Conditions {B}	Cumulative % Off-Spec Water Produced
	[gpm]	[^{mW} /cm ²]	[Y or N]	[gal]	[gal]	(Mo. Sum {B}) ÷ (Mo. Sum {A}) * 100 [%]
1	2900	19.1	Y	1,191,640	0	0
2	2900	17.9	Y	1,100,937	0	0
3	2900	17.6	Y	1,180,319	0	0
4	2900	17.7	Y	1,074,171	0	0
5	2900	19.7	Y	1,105,782	0	0
6	2900	21.2	Y	1,086,436	0	0
7	2900	17.5	Y	998,242	0	0
8	2900	18.1	Y	1,037,483	0	0
9	2900	17.3	Y	1,083,118	0	0
10	2900	19.7	Y	1,000,593	0	0
11	2900	17.4	Y	1,027,297	0	0
12	2900	17.8	Y	1,033,844	0	0
13	2900	18.9	Y	1,031,426	0	0
14	2900	18.6	Y	954,676	0	0
15	2900	19.1	Y	1,019,037	0	0
16	2900	16.8	Y	1,063,501	0	0
17	2900	16.6	Y	1,001,625	0	0
18	2900	18.9	Y	1,064,031	0	0
19	2900	19.2	Y	1,130,758	0	0
20	2900	16.8	Y	960,988	0	0
21	2900	19.4	Y	1,120,384	0	0
22	2900	16.6	Y	1,047,071	0	0
23	2900	19.5	Y	987,308	0	0
24	2900	18.1	Y	1,070,237	0	0
25	2900	18.2	Y	972,211	0	0
26	2900	18.9	Y	1,029,497	0	0
27	2900	16.6	Y	1,120,253	0	0
28	2900	16.8	Y	1,015,759	0	0
29						
30						
31						
Monthly Cumulative % Off-Spec Water Produced						0

Signature:

Op Cert #: 7-7231
Page 2 of 3

Date: 3/1/23