


OHA - Drinking Water Program - Surface Water Quality Data Form
Slow Sand, Membrane, Diatomaceous Earth Filtration, or Unfiltered Systems(Douglas County)

System Name: G.A.W.S.A. ID#: 41 00717 "A" Aug-24

Day	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the day ¹ [NTU]
1	OFF	0.033	0.034	0.034	0.034	0.034	0.039
2	OFF	0.034	0.034	0.034	OFF	0.034	0.049
3	OFF	0.034	OFF	0.035	OFF	0.034	0.040
4	OFF	0.034	0.034	0.034	0.034	0.034	0.036
5	0.034	0.034	0.034	0.034	0.034	0.034	0.046
6	OFF	0.034	OFF	0.034	0.034	0.024	0.048
7	0.034	OFF	0.034	0.034	0.034	0.034	0.041
8	0.038	0.033	0.034	0.034	0.034	0.033	0.036
9	OFF	0.034	0.034	0.025	0.034	OFF	0.044
10	0.034	OFF	0.034	0.034	0.034	0.034	0.045
11	OFF	OFF	0.034	0.034	0.024	0.033	0.039
12	0.033	0.034	0.034	0.034	0.034	0.034	0.041
13	OFF	0.034	OFF	0.034	OFF	0.034	0.047
14	OFF	0.034	0.034	0.025	0.034	OFF	0.048
15	0.034	OFF	0.034	0.034	0.034	0.034	0.041
16	OFF	OFF	0.034	0.034	0.025	0.034	0.042
17	0.034	OFF	0.034	OFF	0.034	OFF	0.041
18	OFF	0.029	0.026	OFF	OFF	0.033	0.039
19	OFF	0.034	0.033	0.034	0.034	OFF	0.041
20	0.034	0.034	0.034	0.034	0.034	0.034	0.038
21	0.035	OFF	0.033	OFF	0.033	OFF	0.037
22	0.033	0.034	0.033	OFF	0.033	OFF	0.042
23	OFF	0.026	OFF	0.033	OFF	0.033	0.038
24	OFF	OFF	0.033	OFF	0.033	0.033	0.038
25	OFF	0.033	0.033	OFF	0.033	0.033	0.038
26	OFF	0.032	0.033	0.033	OFF	0.034	0.048
27	OFF	0.028	OFF	0.033	OFF	0.032	0.037
28	0.032	OFF	0.032	0.033	0.032	0.032	0.042
29	OFF	0.032	0.032	0.032	0.029	OFF	0.037
30	0.032	0.033	0.032	0.032	0.032	0.032	0.036
31	OFF	0.032	0.033	0.032	0.032	OFF	0.039

Slow Sand/Membrane/DE Filtration/Unfiltered 95% of daily turbidity readings ≤ 1 NTU? ² <input checked="" type="radio"/> Yes / <input type="radio"/> No All daily turbidity readings ≤ 5 NTU? <input checked="" type="radio"/> Yes / <input type="radio"/> No		Monthly Summary (Answer Yes or No) CT's met everyday? (see back) <input checked="" type="radio"/> Yes / <input type="radio"/> No All Cl2 residual at entry point ≥ 0.2 mg/l? <input checked="" type="radio"/> Yes / <input type="radio"/> No	
Notes:		PRINTED NAME: Jeremy Wolford	
		SIGNATURE: 	DATE: 9/3/24
		PHONE #: 541-679-6321	CERT #: T-7231

¹ Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in columns 12 AM through 8 PM may not correspond to continuous readings' maximum. ² Filtered systems only.

Oregon DHS - Drinking Water Program - Surface Water Quality Data

System Name: G.A.U.S.A.

PWS ID#: 41 00717 Month/Year: 8/2024

Minimum UVT [%] during month: 99.9%

Duty sensor variation from reference sensor: 5.0%

Minimum Validated UVT: 99.9% (insert Req'd Value)

Date	Peak Hourly Demand Flow	Minimum Intensity	All Lamps On?	Daily Water Produced {A}	Water outside Validated Conditions {B}	Cumulative % Off-Spec Water Produced
	[gpm]	[mW/cm ²]	[Y or N]	[gal]	[gal]	(Mo. Sum {B}) ÷ (Mo. Sum {A}) * 100 [%]
1	2900	16.8	Y	2,243,788	0	0
2	2900	14.9	Y	2,259,187	0	0
3	2900	16.6	Y	1,599,214	0	0
4	2900	14.6	Y	2,447,650	0	0
5	2900	14.5	Y	2,188,359	0	0
6	2900	17.8	Y	2,268,541	0	0
7	2900	14.2	Y	2,027,451	0	0
8	2900	13.6	Y	2,297,542	0	0
9	2900	16.4	Y	2,133,715	0	0
10	2900	16.6	Y	2,008,027	0	0
11	2900	14.2	Y	2,260,510	0	0
12	2900	14.1	Y	2,177,041	0	0
13	2900	16.7	Y	2,066,219	0	0
14	2900	14.1	Y	2,030,261	0	0
15	2900	14.0	Y	1,849,872	0	0
16	2900	14.0	Y	2,019,354	0	0
17	2900	16.3	Y	1,762,816	0	0
18	2900	16.6	Y	1,445,217	0	0
19	2900	16.7	Y	1,753,413	0	0
20	2900	16.0	Y	1,658,931	0	0
21	2900	16.6	Y	2,005,388	0	0
22	2900	13.8	Y	1,756,468	0	0
23	2900	14.9	Y	1,464,480	0	0
24	2900	14.5	Y	1,462,731	0	0
25	2900	14.0	Y	1,530,686	0	0
26	2900	14.5	Y	1,719,737	0	0
27	2900	16.4	Y	1,636,660	0	0
28	2900	16.6	Y	1,818,361	0	0
29	2900	14.5	Y	1,866,474	0	0
30	2900	14.1	Y	1,902,374	0	0
31	2900	17.0	Y	1,756,632	0	0
Monthly Cumulative % Off-Spec Water Produced						0

Signature: 

Op Cert #: T-7231

Date: 9/3/24