


OHA - Drinking Water Program - Surface Water Quality Data Form
Slow Sand, Membrane, Diatomaceous Earth Filtration, or Unfiltered Systems(Douglas County)

System Name: G.A.W.S.A.		ID#: 41 00717			"A"		Oct-24
Day	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the day ¹ [NTU]
1	0.031	0.032	0.031	0.032	0.033	0.032	0.034
2	0.031	0.031	0.031	0.032	0.032	0.032	0.034
3	0.031	OFF	0.032	0.032	0.032	0.032	0.037
4	0.032	0.033	0.032	0.033	0.033	0.032	0.039
5	0.033	0.032	0.033	OFF	OFF	OFF	0.033
6	OFF	OFF	OFF	0.032	0.032	0.032	0.038
7	0.032	OFF	OFF	0.032	0.032	0.032	0.045
8	0.032	0.032	0.032	0.032	0.032	0.032	0.036
9	OFF	0.033	0.033	0.033	0.033	0.033	0.033
10	0.033	0.033	0.033	0.033	OFF	0.033	0.033
11	0.033	OFF	OFF	0.033	0.033	0.032	0.038
12	0.032	OFF	0.033	OFF	0.033	OFF	0.033
13	0.032	0.032	OFF	0.032	0.032	0.033	0.033
14	0.033	0.033	0.033	0.033	0.033	0.033	0.035
15	0.033	OFF	OFF	0.033	0.032	0.032	0.033
16	0.032	0.032	0.032	0.032	0.032	0.032	0.032
17	0.032	0.032	0.032	OFF	0.032	0.032	0.045
18	OFF	0.032	0.032	OFF	0.033	OFF	0.037
19	0.032	0.032	0.032	OFF	0.032	OFF	0.032
20	0.032	0.032	0.032	0.032	0.032	0.032	0.033
21	OFF	OFF	0.032	0.033	0.033	OFF	0.036
22	0.033	0.033	0.033	OFF	0.033	OFF	0.039
23	0.033	0.032	0.032	OFF	0.032	0.032	0.033
24	OFF	OFF	0.033	0.036	0.033	0.033	0.037
25	OFF	0.032	0.032	0.032	0.032	0.032	0.037
26	OFF	0.032	0.032	0.032	OFF	0.032	0.032
27	0.032	OFF	OFF	0.032	0.032	0.033	0.033
28	OFF	0.033	0.033	0.034	0.034	0.033	0.035
29	OFF	OFF	0.033	0.033	0.033	OFF	0.035
30	0.033	0.033	0.033	0.034	0.033	OFF	0.034
31	OFF	0.034	0.034	0.034	OFF	OFF	0.034

Slow Sand/Membrane/DE Filtration/Unfiltered		Monthly Summary (Answer Yes or No)	
95% of daily turbidity readings \leq 1 NTU? ²	<input checked="" type="radio"/> Yes / <input type="radio"/> No	CT's met everyday? (see back)	All Cl2 residual at entry point \geq 0.2 mg/l?
All daily turbidity readings \leq 5 NTU?	<input checked="" type="radio"/> Yes / <input type="radio"/> No	<input checked="" type="radio"/> Yes / <input type="radio"/> No	<input checked="" type="radio"/> Yes / <input type="radio"/> No
Notes:		PRINTED NAME: Jeremy Wolford	
		SIGNATURE: 	DATE: 11/4/24
		PHONE # 541-679-6321	CERT #: T-7231

¹ Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in columns 12 AM through 8 PM may not correspond to continuous readings' maximum. ² Filtered systems only.

OHA - Drinking Water Program - Surface Water Quality Data Form (Douglas County)

System Name: G.A.W.S.A. ID#: 41 00717 "A" Oct-24

Date / Time	Residual at 1st User (C) ³	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? ³	Peak Hourly Demand Flow
	[ppm or mg/L]	[minutes]	C X T	[° C]		formula	Yes / No	[GPM]
1/ 20:00	1.577	14.38	22.7	26.2	7.65	1.9	YES	1172
2/ 23:00	1.568	14.18	22.2	18.6	7.68	3.2	YES	1188
3/ 22:00	1.511	13.99	21.1	19.2	7.76	3.1	YES	1204
4/ 21:00	1.599	14.38	23.0	18.1	7.88	3.5	YES	1172
5/ 7:00	1.628	14.79	24.1	14.5	7.63	4.1	YES	1139
6/ 23:00	1.714	9.69	16.6	17.3	7.81	3.7	YES	1742
7/ 7:00	1.891	9.69	18.3	15.6	7.74	4.1	YES	1742
8/ 19:00	1.480	14.79	21.9	18.6	7.78	3.2	YES	1139
9/ 22:00	1.601	14.58	23.3	17.6	7.75	3.5	YES	1156
10/ 4:00	1.545	17.84	27.6	16.9	7.64	3.5	YES	944
11/ 20:00	1.522	14.79	22.5	17.4	7.76	3.5	YES	1139
12/ 17:00	1.612	14.79	23.8	18.3	7.74	3.3	YES	1139
13/ 17:00	1.581	9.69	15.3	18.6	7.70	3.2	YES	1742
14/ 20:00	1.196	10.79	12.9	18.3	7.72	3.1	YES	1563
15/ 20:00	1.610	14.58	23.5	18.0	7.53	3.1	YES	1156
16/ 21:00	1.610	9.02	14.5	17.5	7.53	3.2	YES	1872
17/ 16:00	1.610	9.02	14.5	17.1	7.53	3.3	YES	1872
18/ 22:00	1.610	9.02	14.5	14.8	7.53	3.9	YES	1872
19/ 22:00	1.610	9.02	14.5	15.1	7.53	3.8	YES	1872
20/ 21:00	1.610	9.02	14.5	15.1	7.53	3.8	YES	1872
21/ 23:00	1.601	9.09	14.6	15.0	7.56	3.8	YES	1855
22/ 9:00	1.669	9.02	15.0	14.6	7.54	3.9	YES	1872
23/ 23:00	1.694	8.86	15.0	13.2	7.63	4.5	YES	1904
24/ 3:00	1.720	8.94	15.4	12.9	7.63	4.6	YES	1888
25/ 23:00	1.689	8.94	15.1	11.8	7.67	5.0	YES	1888
26/ 13:00	1.736	9.02	15.6	12.6	7.68	4.8	YES	1872
27/ 15:00	1.681	8.94	15.0	13.9	7.64	4.3	YES	1888
28/ 23:00	1.611	8.86	14.3	14.0	7.68	4.3	YES	1904
29/ 23:00	1.792	8.94	16.0	16.3	7.67	3.8	YES	1888
30/ 11:00	1.717	8.79	15.1	12.6	7.80	5.0	YES	1921
31/ 18:00	1.790	9.02	16.1	11.4	7.74	5.3	YES	1872

³ If Cl2 at entry point < 0.2 mg/l or CT not met, DWP to be notified by end of next business day.

Oregon DHS - Drinking Water Program – Surface Water Quality Data

System Name: G. A. W. S. A.

PWS ID#: 41 00717 Month/Year: 10/2024

Minimum UVT [%] during month: 99.5%

Duty sensor variation from reference sensor: 9.1%

Minimum Validated UVT: 92.7% {insert Req'd Value}

Date	Peak Hourly Demand Flow	Minimum Intensity	All Lamps On?	Daily Water Produced {A}	Water outside Validated Conditions {B}	Cumulative % Off-Spec Water Produced
	[gpm]	[mW/cm^2]	[Y or N]	[gal]	[gal]	$(Mo. Sum \{B\}) \div (Mo. Sum \{A\}) * 100$ [%]
1	2900	14.2	Y	1,388,271	0	0
2	2900	13.6	Y	1,611,061	0	0
3	2900	13.8	Y	1,594,123	0	0
4	2900	16.6	Y	1,477,691	0	0
5	2900	13.8	Y	684,234	0	0
6	2900	17.1	Y	1,772,209	0	0
7	2900	16.5	Y	1,864,228	0	0
8	2900	13.8	Y	1,699,048	0	0
9	2900	14.2	Y	1,514,103	0	0
10	2900	13.8	Y	1,320,336	0	0
11	2900	13.5	Y	1,501,089	0	0
12	2900	14.0	Y	1,431,963	0	0
13	2900	14.1	Y	1,442,731	0	0
14	2900	13.8	Y	1,368,648	0	0
15	2900	14.4	Y	1,492,932	0	0
16	2900	16.3	Y	1,433,869	0	0
17	2900	16.8	Y	1,259,398	0	0
18	2900	16.7	Y	1,312,375	0	0
19	2900	16.4	Y	1,316,891	0	0
20	2900	16.8	Y	1,294,833	0	0
21	2900	14.3	Y	1,385,991	0	0
22	2900	14.8	Y	1,268,789	0	0
23	2900	15.0	Y	1,235,548	0	0
24	2900	14.7	Y	1,286,662	0	0
25	2900	17.3	Y	1,214,968	0	0
26	2900	17.0	Y	1,155,460	0	0
27	2900	16.6	Y	1,184,036	0	0
28	2900	14.5	Y	1,256,833	0	0
29	2900	14.0	Y	1,200,109	0	0
30	2900	19.9	Y	1,147,811	0	0
31	2900	13.9	Y	1,115,134	0	0
Monthly Cumulative % Off-Spec Water Produced						0

Signature:

Op Cert #: T-7231 Date: 11/4/24