




OHA - Drinking Water Program - Surface Water Quality Data Form
Slow Sand, Membrane, Diatomaceous Earth Filtration, or Unfiltered Systems(Douglas County)

System Name: GAWSA		ID#: 41 00717			"A"		Nov-24
Day	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the day ¹ [NTU]
1	0.034	0.034	0.034	0.034	OFF	0.033	0.034
2	0.034	0.034	0.034	OFF	0.034	0.033	0.034
3	OFF	OFF	OFF	0.033	0.033	0.033	0.034
4	OFF	OFF	0.033	0.033	0.033	0.033	0.036
5	OFF	OFF	0.033	0.033	OFF	0.033	0.033
6	0.033	0.033	0.034	OFF	OFF	0.034	0.034
7	0.034	OFF	OFF	0.034	0.033	0.034	0.035
8	0.034	0.034	0.034	OFF	0.033	0.033	0.034
9	OFF	OFF	OFF	0.034	0.033	OFF	0.042
10	0.034	0.034	0.034	OFF	0.034	0.034	0.036
11	0.034	0.034	OFF	OFF	0.034	0.034	0.034
12	OFF	OFF	0.034	0.033	0.034	OFF	0.034
13	0.034	0.034	0.035	OFF	OFF	0.035	0.035
14	0.035	0.035	OFF	0.035	OFF	0.035	0.041
15	0.034	OFF	OFF	0.035	OFF	0.034	0.036
16	0.034	0.034	OFF	OFF	0.034	0.034	0.035
17	OFF	OFF	OFF	0.034	0.034	0.034	0.035
18	OFF	OFF	0.035	0.034	0.034	0.034	0.035
19	OFF	OFF	OFF	0.034	0.034	0.034	0.053
20	OFF	OFF	0.034	OFF	0.034	0.035	0.036
21	OFF	OFF	0.036	0.034	0.034	OFF	0.036
22	0.035	0.035	0.035	0.034	OFF	0.035	0.036
23	0.037	0.036	0.037	OFF	0.034	0.034	0.038
24	0.034	OFF	OFF	OFF	0.034	0.034	0.035
25	OFF	OFF	OFF	0.035	0.035	0.035	0.037
26	OFF	OFF	OFF	0.036	0.037	0.035	0.037
27	OFF	OFF	0.036	0.035	0.035	0.036	0.044
28	OFF	OFF	0.036	0.036	OFF	0.036	0.039
29	0.036	0.036	0.037	OFF	0.036	0.036	0.037
30	0.036	OFF	OFF	0.037	0.036	OFF	0.037
31							

<p align="center">Slow Sand/Membrane/DE Filtration/Unfiltered</p> <p>95% of daily turbidity readings ≤ 1 NTU? ² Yes / No</p> <p>All daily turbidity readings ≤ 5 NTU? Yes / No</p>	<p align="center">Monthly Summary (Answer Yes or No)</p> <table border="1" style="width:100%; border-collapse: collapse;"> <tr> <td style="width:50%;">CT's met everyday? (see back)</td> <td style="width:50%;">All Cl2 residual at entry point ≥ 0.2 mg/l?</td> </tr> <tr> <td align="center">Yes / No</td> <td align="center">Yes / No</td> </tr> </table>	CT's met everyday? (see back)	All Cl2 residual at entry point ≥ 0.2 mg/l?	Yes / No	Yes / No
CT's met everyday? (see back)	All Cl2 residual at entry point ≥ 0.2 mg/l?				
Yes / No	Yes / No				
<p>Notes:</p>	<p>PRINTED NAME: Jeremy Wolford</p> <table border="1" style="width:100%; border-collapse: collapse;"> <tr> <td style="width:70%;">SIGNATURE: </td> <td style="width:30%;">DATE: 12/3/2024</td> </tr> <tr> <td>PHONE #: 541-679-6321</td> <td>CERT #: T-7231</td> </tr> </table>	SIGNATURE: 	DATE: 12/3/2024	PHONE #: 541-679-6321	CERT #: T-7231
SIGNATURE: 	DATE: 12/3/2024				
PHONE #: 541-679-6321	CERT #: T-7231				

¹ Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in columns 12 AM through 8 PM may not correspond to continuous readings' maximum. ² Filtered systems only.

Oregon DHS - Drinking Water Program – Surface Water Quality Data

System Name: G. A. W. S. A.

PWS ID#: 41 00717 Month/Year: Nov 2024

Minimum UVT [%] during month: 99.9%

Duty sensor variation from reference sensor: 5.2%

Minimum Validated UVT: 99.9% (insert Req'd Value)

Date	Peak Hourly Demand Flow	Minimum Intensity	All Lamps On?	Daily Water Produced {A}	Water outside Validated Conditions {B}	Cumulative % Off-Spec Water Produced
	[gpm]	[^{mW} /cm ²]	[Y or N]	[gal]	[gal]	(Mo. Sum {B}) ÷ (Mo. Sum {A}) * 100 [%]
1	2900	23.9	Y	1,064,301	0	0
2	2900	22.1	Y	1,153,494	0	0
3	2900	18.8	Y	1,191,399	0	0
4	2900	18.1	Y	1,175,665	0	0
5	2900	17.9	Y	1,079,871	0	0
6	2900	13.5	Y	1,090,176	0	0
7	2900	13.5	Y	1,100,671	0	0
8	2900	20.2	Y	1,146,163	0	0
9	2900	13.7	Y	1,170,323	0	0
10	2900	15.2	Y	1,037,609	0	0
11	2900	20.9	Y	1,218,789	0	0
12	2900	20.8	Y	1,082,281	0	0
13	2900	14.7	Y	1,052,208	0	0
14	2900	17.5	Y	1,118,691	0	0
15	2900	17.1	Y	1,090,586	0	0
16	2900	13.8	Y	1,079,819	0	0
17	2900	13.9	Y	1,136,932	0	0
18	2900	20.6	Y	1,349,662	0	0
19	2900	19.9	Y	1,189,461	0	0
20	2900	20.8	Y	1,054,181	0	0
21	2900	17.9	Y	1,075,467	0	0
22	2900	17.1	Y	1,072,633	0	0
23	2900	18.3	Y	1,033,948	0	0
24	2900	20.8	Y	1,138,003	0	0
25	2900	21.0	Y	1,167,839	0	0
26	2900	17.9	Y	1,017,031	0	0
27	2900	14.3	Y	1,139,960	0	0
28	2900	15.1	Y	1,088,328	0	0
29	2900	14.8	Y	1,068,766	0	0
30	2900	22.4	Y	1,179,555	0	0
31						
Monthly Cumulative % Off-Spec Water Produced						0

Signature:

Op Cert #: T-7231 Date: 12/3/24