


OHA - Drinking Water Program - Surface Water Quality Data Form
Slow Sand, Membrane, Diatomaceous Earth Filtration, or Unfiltered Systems(Douglas County)

System Name: GAWSA		ID#: 41 00717			"A"		Dec-24
Day	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the day ¹ [NTU]
1	OFF	0.036	0.036	0.036	OFF	0.036	0.039
2	0.036	OFF	OFF	0.037	OFF	0.037	0.040
3	OFF	0.036	OFF	0.038	0.037	0.037	0.045
4	OFF	OFF	0.037	0.037	OFF	0.037	0.080
5	0.037	0.037	OFF	OFF	OFF	0.037	0.038
6	0.037	OFF	OFF	OFF	0.037	0.037	0.038
7	0.037	OFF	OFF	0.037	0.037	0.037	0.037
8	OFF	OFF	0.037	0.037	0.037	0.037	0.037
9	0.037	0.037	0.037	0.037	0.038	0.037	0.048
10	OFF	OFF	0.037	0.037	0.037	OFF	0.038
11	0.037	0.037	0.037	0.037	OFF	0.038	0.038
12	0.038	0.039	0.039	OFF	0.039	0.039	0.039
13	0.039	OFF	OFF	0.042	0.039	OFF	0.044
14	0.039	OFF	OFF	0.039	0.039	0.039	0.040
15	0.039	OFF	OFF	0.040	0.039	OFF	0.041
16	0.039	0.038	0.039	OFF	OFF	0.039	0.039
17	0.039	OFF	OFF	0.039	0.040	0.039	0.040
18	OFF	OFF	0.039	0.039	0.039	0.038	0.041
19	0.039	OFF	OFF	0.039	0.041	OFF	0.044
20	OFF	0.039	0.039	0.039	OFF	OFF	0.041
21	0.040	0.039	0.039	OFF	OFF	0.040	0.040
22	0.040	OFF	OFF	OFF	0.041	0.041	0.041
23	OFF	OFF	OFF	0.043	OFF	0.041	0.069
24	0.042	0.041	OFF	0.042	0.043	OFF	0.047
25	OFF	OFF	0.044	0.042	0.041	OFF	0.046
26	OFF	OFF	0.042	0.042	0.041	OFF	0.042
27	0.042	0.044	0.042	0.041	OFF	0.041	0.044
28	0.041	0.040	OFF	OFF	0.041	0.042	0.043
29	0.040	OFF	OFF	0.041	0.043	0.040	0.044
30	OFF	OFF	0.043	0.049	0.041	0.040	0.049
31	OFF	OFF	0.045	0.041	0.040	OFF	0.046

Slow Sand/Membrane/DE Filtration/Unfiltered		Monthly Summary (Answer Yes or No)	
95% of daily turbidity readings \leq 1 NTU? ²	Yes / No	CT's met everyday? (see back)	All Cl ₂ residual at entry point \geq 0.2 mg/l?
All daily turbidity readings \leq 5 NTU?	Yes / No	Yes / No	Yes / No

Notes:	PRINTED NAME: Jeremy Wolford	
	SIGNATURE: 	DATE: 1/3/25
	PHONE #: 541-679-6321	CERT #: T-7231

¹ Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in columns 12 AM through 8 PM may not correspond to continuous readings' maximum. ² Filtered systems only.

OHA - Drinking Water Program - Surface Water Quality Data Form (Douglas County)

System Name: **GAWSA** ID#: **41 00717** "A" Dec-24

Date / Time	Residual at 1st User (C) ³	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? ³	Peak Hourly Demand Flow
	[ppm or mg/L]	[minutes]	C X T	[° C]		formula	Yes / No	[GPM]
1/ 19:00	1.806	8.71	15.7	9.8	7.39	5.3	YES	1937
2/ 1:00	1.908	8.64	16.5	5.6	7.40	7.1	YES	1953
3/ 20:00	1.748	9.02	15.8	5.6	7.43	7.0	YES	1872
4/ 7:00	1.738	8.79	15.3	5.0	7.46	7.4	YES	1921
5/ 21:00	1.567	8.86	13.9	9.3	7.54	5.6	YES	1904
6/ 1:00	1.631	8.94	14.6	7.1	7.52	6.5	YES	1888
7/ 12:00	1.638	8.94	14.6	6.2	7.50	6.8	YES	1888
8/ 17:00	1.572	9.02	14.2	11.3	7.50	4.8	YES	1872
9/ 16:00	1.504	8.79	13.2	13.6	7.13	3.6	YES	1921
10/ 17:00	1.574	8.86	13.9	9.1	7.48	5.5	YES	1904
11/ 20:00	1.705	8.94	15.2	5.4	7.53	7.3	YES	1888
12/ 21:00	1.748	8.79	15.4	10.9	7.60	5.2	YES	1921
13/ 13:00	1.732	9.42	16.3	6.2	7.34	6.5	YES	1790
14/ 14:00	1.347	8.86	11.9	7.2	7.63	6.5	YES	1904
15/ 1:00	1.458	9.02	13.1	6.9	7.40	6.2	YES	1872
16/ 10:00	1.442	8.86	12.8	7.2	6.61	4.5	YES	1904
17/ 16:00	1.478	9.02	13.3	12.2	7.33	4.2	YES	1872
18/ 16:00	1.572	9.02	14.2	19.1	7.22	2.6	YES	1872
19/ 22:00	1.604	8.94	14.3	8.5	7.22	5.3	YES	1888
20/ 13:00	1.595	9.17	14.6	8.3	7.26	5.4	YES	1839
21/ 20:00	1.594	9.09	14.5	8.8	7.36	5.4	YES	1855
22/ 10:00	1.543	8.94	13.8	8.5	7.36	5.5	YES	1888
23/ 15:00	1.426	8.64	12.3	8.8	7.23	5.1	YES	1953
24/ 5:00	1.483	9.02	13.4	9.6	7.24	4.9	YES	1872
25/ 12:00	1.391	9.02	12.5	8.9	7.06	4.7	YES	1872
26/ 19:00	1.520	8.86	13.5	8.7	7.18	5.1	YES	1904
27/ 8:00	1.372	9.51	13.1	9.3	7.15	4.7	YES	1774
28/ 21:00	1.561	9.02	14.1	9.2	7.13	4.8	YES	1872
29/ 12:00	1.442	9.09	13.1	9.4	6.99	4.5	YES	1855
30/ 3:00	1.494	8.86	13.2	9.2	7.00	4.6	YES	1904
31/ 12:00	1.420	8.79	12.5	8.2	7.03	4.9	YES	1921

³ If Cl2 at entry point < 0.2 mg/l or CT not met, DWP to be notified by end of next business day.

Oregon DHS - Drinking Water Program - Surface Water Quality Data

System Name: GAWSA

PWS ID#: 41 00717 Month/Year: 12/2024

Minimum UVT [%] during month: 99.9

Duty sensor variation from reference sensor: 5.0 %

Minimum Validated UVT: 99.9 (insert Req'd Value)

Date	Peak Hourly Demand Flow	Minimum Intensity	All Lamps On?	Daily Water Produced {A}	Water outside Validated Conditions {B}	Cumulative % Off-Spec Water Produced
	[gpm]	[mW/cm^2]	[Y or N]	[gal]	[gal]	(Mo. Sum {B}) ÷ (Mo. Sum {A}) * 100 [%]
1	2900	15.1	Y	1,067,056	0	0
2	2900	17.3	Y	1,106,961	0	0
3	2900	14.9	Y	1,052,416	0	0
4	2900	22.7	Y	1,040,203	0	0
5	2900	15.9	Y	1,077,718	0	0
6	2900	19.9	Y	1,114,228	0	0
7	2900	15.5	Y	1,136,698	0	0
8	2900	22.9	Y	1,085,154	0	0
9	2900	24.3	Y	1,164,969	0	0
10	2900	22.7	Y	1,082,312	0	0
11	2900	15.7	Y	1,077,713	0	0
12	2900	23.1	Y	1,074,390	0	0
13	2900	17.5	Y	1,150,764	0	0
14	2900	16.1	Y	940,224	0	0
15	2900	17.9	Y	1,264,736	0	0
16	2900	14.5	Y	1,083,506	0	0
17	2900	17.9	Y	1,174,861	0	0
18	2900	21.0	Y	1,127,767	0	0
19	2900	17.1	Y	1,068,453	0	0
20	2900	21.6	Y	1,040,119	0	0
21	2900	15.4	Y	999,775	0	0
22	2900	22.4	Y	1,068,489	0	0
23	2900	15.3	Y	1,020,898	0	0
24	2900	20.6	Y	1,116,641	0	0
25	2900	13.3	Y	1,002,587	0	0
26	2900	19.1	Y	1,009,718	0	0
27	2900	18.7	Y	1,027,056	0	0
28	2900	19.4	Y	1,043,995	0	0
29	2900	19.3	Y	1,156,109	0	0
30	2900	21.3	Y	1,080,895	0	0
31	2900	23.9	Y	1,092,418	0	0
Monthly Cumulative % Off-Spec Water Produced						0

Signature:

Op Cert #: T-7231 Date: 1/3/25