


**OHA - Drinking Water Program - Surface Water Quality Data Form**  
**Slow Sand, Membrane, Diatomaceous Earth Filtration, or Unfiltered Systems(Douglas County)**

**System Name: GAWSA** **ID#: 41 00717** **"A"** **25-Jan**

Day	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the day <sup>1</sup> [NTU]
1	OFF	0.040	0.040	0.040	OFF	0.040	0.041
2	0.040	0.040	0.040	OFF	OFF	0.040	0.041
3	0.040	OFF	OFF	0.042	0.041	0.040	0.047
4	OFF	OFF	OFF	0.040	0.040	0.040	0.041
5	OFF	OFF	0.040	0.040	0.040	0.040	0.041
6	0.040	0.040	OFF	0.038	0.038	0.038	0.040
7	OFF	OFF	0.038	0.038	0.037	OFF	0.038
8	OFF	0.037	0.037	0.036	0.037	0.036	0.038
9	OFF	OFF	OFF	0.037	0.036	0.036	0.037
10	OFF	OFF	0.036	0.036	0.036	0.036	0.037
11	OFF	OFF	OFF	0.036	0.035	OFF	0.036
12	0.035	0.036	0.035	0.035	OFF	0.035	0.036
13	0.035	OFF	OFF	0.035	0.035	OFF	0.035
14	OFF	0.035	0.035	0.035	0.034	0.034	0.035
15	0.034	0.035	0.035	0.035	OFF	0.034	0.035
16	0.034	0.034	0.034	0.034	0.034	0.034	0.035
17	0.034	OFF	OFF	0.034	0.034	0.034	0.035
18	OFF	OFF	0.035	0.035	0.034	OFF	0.035
19	OFF	0.035	0.035	0.035	OFF	0.035	0.035
20	0.035	0.035	0.035	OFF	0.035	0.035	0.035
21	OFF	OFF	0.034	0.035	0.034	0.035	0.036
22	0.035	OFF	0.035	0.035	0.035	0.035	0.038
23	OFF	OFF	0.035	0.035	0.035	OFF	0.035
24	0.037	0.035	0.035	0.035	OFF	0.035	0.036
25	0.035	0.035	0.035	OFF	0.035	0.035	0.035
26	0.035	OFF	OFF	0.036	0.036	0.035	0.036
27	0.035	0.036	0.036	0.036	OFF	0.037	0.037
28	OFF	0.036	0.036	0.036	0.037	OFF	0.037
29	0.036	0.036	0.036	0.036	OFF	0.036	0.037
30	0.036	OFF	OFF	0.036	0.036	0.036	0.040
31	OFF	OFF	OFF	0.036	0.036	0.036	0.043

Slow Sand/Membrane/DE Filtration/Unfiltered	Monthly Summary (Answer Yes or No)	
95% of daily turbidity readings ≤ 1 NTU? <sup>2</sup> <u>Yes</u> /No	CT's met everyday? (see back) <u>Yes</u> /No	All Cl <sub>2</sub> residual at entry point ≥ 0.2 mg/l? <u>Yes</u> /No
All daily turbidity readings ≤ 5 NTU? <u>Yes</u> /No		

Notes:	PRINTED NAME: Jeremy Wolford	
	SIGNATURE: 	DATE: 2/3/25
	PHONE #: 541-679-6371	CERT #: T-7231

<sup>1</sup> Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in columns 12 AM through 8 PM may not correspond to continuous readings' maximum. <sup>2</sup> Filtered systems only.



Oregon DHS - Drinking Water Program - Surface Water Quality Data

System Name: G. A. W. S. A.

PWS ID#: 41 00717 Month/Year: Jan 2025

Minimum UVT [%] during month: 99.9 %

Duty sensor variation from reference sensor: 5.0 %

Minimum Validated UVT: 99.8 % [Insert Req'd Value]

Date	Peak Hourly Demand Flow	Minimum Intensity	All Lamps On?	Daily Water Produced {A}	Water outside Validated Conditions {B}	Cumulative % Off-Spec Water Produced
	[gpm]	[ $mW/cm^2$ ]	[Y or N]	[gal]	[gal]	(Mo. Sum {B}) ÷ (Mo. Sum {A}) * 100 [%]
1	2900	15.0	Y	1,023,690	0	0
2	2900	21.7	Y	1,053,521	0	0
3	2900	22.4	Y	1,144,054	0	0
4	2900	17.1	Y	1,105,237	0	0
5	2900	15.0	Y	1,067,217	0	0
6	2900	21.5	Y	1,129,226	0	0
7	2900	22.0	Y	1,086,417	0	0
8	2900	22.4	Y	1,071,905	0	0
9	2900	16.1	Y	1,108,878	0	0
10	2900	21.7	Y	1,065,940	0	0
11	2900	26.7	Y	1,102,092	0	0
12	2900	16.7	Y	1,062,477	0	0
13	2900	19.1	Y	1,235,335	0	0
14	2900	15.2	Y	1,193,867	0	0
15	2900	15.4	Y	1,224,789	0	0
16	2900	22.9	Y	1,051,648	0	0
17	2900	24.1	Y	1,169,522	0	0
18	2900	21.1	Y	1,076,306	0	0
19	2900	15.9	Y	1,035,788	0	0
20	2900	15.9	Y	1,127,250	0	0
21	2900	23.3	Y	934,892	0	0
22	2900	15.9	Y	1,167,260	0	0
23	2900	23.0	Y	1,692,363	0	0
24	2900	15.8	Y	1,049,117	0	0
25	2900	15.8	Y	1,167,260	0	0
26	2900	23.0	Y	1,063,145	0	0
27	2900	16.1	Y	1,314,797	0	0
28	2900	15.9	Y	1,262,715	0	0
29	2900	16.0	Y	1,177,845	0	0
30	2900	23.2	Y	1,095,165	0	0
31	2900	24.4	Y	1,167,456	0	0
Monthly Cumulative % Off-Spec Water Produced						0

Signature: 

Op Cert #: T-7231 Date: 2/3/25