

**OHA - Drinking Water Program - Surface Water Quality Data Form**  
**Slow Sand, Membrane, Diatomaceous Earth Filtration, or Unfiltered Systems(Douglas County)**

<b>System Name: GAWSA</b>		<b>ID#: 41 00717</b>			<b>"A"</b>		<b>Feb-25</b>
Day	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the day <sup>1</sup> [NTU]
1	0.036	OFF	OFF	OFF	OFF	0.036	0.037
2	0.036	OFF	OFF	0.037	0.037	OFF	0.039
3	0.036	0.036	0.036	OFF	OFF	0.036	0.037
4	0.035	OFF	OFF	OFF	0.036	0.036	0.036
5	OFF	OFF	OFF	0.036	0.035	0.036	0.037
6	OFF	OFF	0.036	0.035	0.035	OFF	0.036
7	0.036	0.036	0.036	0.035	OFF	0.036	0.036
8	0.035	0.035	0.035	OFF	0.035	0.036	0.037
9	0.035	OFF	OFF	OFF	0.035	0.034	0.036
10	OFF	OFF	0.035	0.034	OFF	0.034	0.035
11	0.034	0.034	OFF	0.035	OFF	OFF	0.035
12	0.034	0.034	0.034	OFF	0.034	0.034	0.035
13	0.034	OFF	OFF	0.035	0.034	0.034	0.037
14	OFF	OFF	0.034	0.034	0.034	0.034	0.035
15	0.034	OFF	OFF	0.036	0.036	0.035	0.038
16	OFF	OFF	0.036	0.035	0.033	OFF	0.037
17	OFF	0.034	0.034	0.033	OFF	0.033	0.034
18	0.033	0.033	OFF	0.033	0.033	0.033	0.035
19	OFF	OFF	0.033	0.032	0.032	OFF	0.034
20	0.032	0.032	0.032	OFF	OFF	0.031	0.033
21	0.029	OFF	OFF	OFF	0.029	0.029	0.030
22	OFF	OFF	OFF	0.029	0.029	0.029	0.030
23	OFF	OFF	OFF	0.029	OFF	0.029	0.030
24	0.029	0.029	0.030	OFF	0.032	OFF	0.033
25	OFF	0.030	0.030	0.029	0.029	OFF	0.031
26	OFF	OFF	0.030	0.029	OFF	0.029	0.030
27	0.029	0.029	0.030	OFF	0.029	0.029	0.031
28	OFF	OFF	OFF	0.029	OFF	0.029	0.030
29							
30							
31							

<p align="center"><b>Slow Sand/Membrane/DE Filtration/Unfiltered</b></p> <p>95% of daily turbidity readings ≤ 1 NTU? <sup>2</sup>      <u>Yes</u> / No</p> <p>All daily turbidity readings ≤ 5 NTU?              <u>Yes</u> / No</p>	<p align="center"><b>Monthly Summary (Answer Yes or No)</b></p> <p>CT's met everyday? (see back)      All Cl<sub>2</sub> residual at entry point ≥ 0.2 mg/l?</p> <p align="center"><u>Yes</u> / No                              <u>Yes</u> / No</p>
<p><b>Notes:</b></p>	<p>PRINTED NAME: Jeremy Wolford</p> <p>SIGNATURE: </p> <p>PHONE #: 541-679-6321</p> <p>DATE: 3/10/25</p> <p>CERT #: T-7231</p>

<sup>1</sup> Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in columns 12 AM through 8 PM may not correspond to continuous readings' maximum. <sup>2</sup> Filtered systems only.

**OHA - Drinking Water Program - Surface Water Quality Data Form (Douglas County)**

**System Name: GAWSA** **ID#: 41 00717** **"A"** **Feb-25**

Date / Time	Residual at 1st User (C) <sup>3</sup>	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? <sup>3</sup>	Peak Hourly Demand Flow
	[ppm or mg/L]	[minutes]	C X T	[° C]		formula	Yes / No	[GPM]
1/ 11:00	1.436	15.68	22.5	4.6	7.61	7.7	YES	1074
2/ 23:00	1.349	14.58	19.7	6.4	7.50	6.5	YES	1156
3/ 21:00	1.453	15.22	22.1	5.6	7.46	6.9	YES	1107
4/ 11:00	1.305	14.58	19.0	4.9	7.45	7.0	YES	1156
5/ 11:00	1.791	15.68	28.1	4.2	7.26	7.3	YES	1074
6/ 13:00	1.787	14.79	26.4	4.9	7.56	7.8	YES	1139
7/ 14:00	1.507	15.45	23.3	7.5	7.54	6.3	YES	1090
8/ 20:00	1.500	15.00	22.5	5.8	7.57	7.1	YES	1123
9/ 10:00	1.436	14.58	20.9	5.3	7.55	7.2	YES	1156
10/ 15:00	1.411	14.58	20.6	5.3	7.47	7.0	YES	1156
11/ 6:00	1.093	14.38	15.7	4.3	7.52	7.4	YES	1172
12/ 22:00	1.485	15.22	22.6	7.2	7.61	6.5	YES	1107
13/ 21:00	1.460	14.79	21.6	6.6	7.62	6.8	YES	1139
14/ 21:00	1.382	15.22	21.0	6.2	7.63	6.9	YES	1107
15/ 16:00	1.289	15.45	19.9	7.8	7.48	5.8	YES	1090
16/ 22:00	1.318	15.00	19.8	9.4	7.45	5.2	YES	1123
17/ 8:00	1.374	14.79	20.3	7.5	7.45	5.9	YES	1139
18/ 10:00	1.481	14.79	21.9	7.1	6.98	5.2	YES	1139
19/ 10:00	1.401	13.99	19.6	8.9	7.03	4.7	YES	1204
20/ 20:00	1.294	14.58	18.9	12.8	7.25	3.8	YES	1156
21/ 11:00	1.470	14.58	21.4	7.2	7.29	5.8	YES	1156
22/ 17:00	1.530	14.58	22.3	11.8	7.31	4.4	YES	1156
23/ 9:00	1.436	14.78	19.7	11.1	7.36	4.6	YES	1125
24/ 23:00	1.416	15.00	21.2	10.0	7.07	4.4	YES	1123
25/ 23:00	1.368	13.99	19.1	13.3	7.11	3.5	YES	1204
26/ 14:00	1.448	14.58	21.1	10.0	7.14	4.6	YES	1156
27/ 21:00	1.400	14.58	20.4	17.1	7.18	2.8	YES	1156
28/ 18:00	1.429	15.45	22.1	20.7	7.14	2.2	YES	1090

<sup>3</sup> If Cl2 at entry point < 0.2 mg/l or CT not met, DWP to be notified by end of next business day.

Oregon DHS - Drinking Water Program – Surface Water Quality Data

System Name: G. A. U. S. A.

PWS ID#: 41 00717 Month/Year: 2/2025

Minimum UVT [%] during month: 99.9%

Duty sensor variation from reference sensor: 9.0%

Minimum Validated UVT: 99.9% {Insert Req'd Value}

Date	Peak Hourly Demand Flow	Minimum Intensity	All Lamps On?	Daily Water Produced {A}	Water outside Validated Conditions {B}	Cumulative % Off-Spec Water Produced
	[gpm]	[ $mW/cm^2$ ]	[Y or N]	[gal]	[gal]	$\frac{(Mo. Sum \{B\})}{(Mo. Sum \{A\})} * 100$ [%]
1	2900	15.5	Y	1,086,254	0	0
2	2900	14.3	Y	1,133,331	0	0
3	2900	21.1	Y	1,067,723	0	0
4	2900	21.1	Y	1,123,627	0	0
5	2900	14.8	Y	1,118,900	0	0
6	2900	15.1	Y	1,119,913	0	0
7	2900	21.0	Y	1,056,356	0	0
8	2900	15.0	Y	1,056,466	0	0
9	2900	21.0	Y	1,054,394	0	0
10	2900	22.0	Y	1,128,362	0	0
11	2900	15.9	Y	1,165,521	0	0
12	2900	15.4	Y	1,069,248	0	0
13	2900	16.2	Y	1,103,716	0	0
14	2900	22.0	Y	1,070,362	0	0
15	2900	14.7	Y	1,042,316	0	0
16	2900	14.9	Y	1,100,551	0	0
17	2900	20.8	Y	1,057,322	0	0
18	2900	15.7	Y	1,103,372	0	0
19	2900	15.5	Y	925,154	0	0
20	2900	22.6	Y	1,226,158	0	0
21	2900	15.4	Y	1,031,182	0	0
22	2900	15.7	Y	1,082,921	0	0
23	2900	17.2	Y	1,062,550	0	0
24	2900	15.2	Y	996,002	0	0
25	2900	14.8	Y	1,693,363	0	0
26	2900	22.0	Y	1,081,155	0	0
27	2900	15.8	Y	1,048,473	0	0
28	2900	20.1	Y	1,160,297	0	0
29						
30						
31						
Monthly Cumulative % Off-Spec Water Produced						0

Signature: 

Op Cert #: T-7231 Date: 3/10/25