


**OHA - Drinking Water Program - Surface Water Quality Data Form**  
**Slow Sand, Membrane, Diatomaceous Earth Filtration, or Unfiltered Systems(Douglas County)**

**System Name: GAWSA** **ID#: 41 00717** **"A"** **Mar-25**

Day	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the day <sup>1</sup> [NTU]
1	0.029	0.029	0.029	OFF	OFF	0.029	0.031
2	0.029	0.029	OFF	0.029	0.029	OFF	0.030
3	0.029	OFF	0.030	OFF	OFF	0.029	0.030
4	0.030	0.029	0.030	OFF	0.030	0.029	0.059
5	OFF	OFF	OFF	0.030	0.029	0.029	0.031
6	OFF	OFF	0.030	0.030	0.030	0.029	0.031
7	OFF	OFF	OFF	0.030	0.030	OFF	0.030
8	0.030	0.030	0.030	0.030	OFF	0.030	0.031
9	0.030	OFF	OFF	0.030	0.030	0.030	0.030
10	OFF	OFF	0.030	0.030	OFF	0.030	0.052
11	0.030	OFF	OFF	0.030	OFF	0.030	0.031
12	OFF	OFF	0.030	0.029	0.031	0.031	0.031
13	OFF	OFF	OFF	0.031	0.031	0.031	0.034
14	OFF	OFF	0.032	0.032	OFF	0.031	0.033
15	0.032	0.031	0.032	OFF	OFF	0.032	0.033
16	0.032	0.032	OFF	OFF	0.038	0.035	0.043
17	0.038	0.048	0.033	0.033	0.031	OFF	0.057
18	0.033	0.034	0.035	0.032	OFF	OFF	0.036
19	0.033	0.032	0.032	OFF	0.032	0.031	0.037
20	OFF	OFF	0.032	0.031	OFF	OFF	0.034
21	OFF	OFF	0.032	0.032	0.032	OFF	0.033
22	0.032	OFF	0.033	OFF	0.032	0.032	0.034
23	OFF	0.033	OFF	0.033	OFF	0.032	0.035
24	0.032	OFF	0.032	OFF	0.032	0.032	0.035
25	OFF	0.032	OFF	0.032	OFF	0.032	0.065
26	0.032	0.032	0.031	OFF	OFF	0.031	0.036
27	0.031	0.031	OFF	OFF	0.031	0.031	0.032
28	0.031	OFF	OFF	0.031	0.031	OFF	0.032
29	OFF	OFF	0.032	0.032	0.031	OFF	0.034
30	0.031	0.031	0.031	0.031	0.031	0.031	0.032
31	0.031	0.031	0.031	0.031	0.032	0.032	0.034

<b>Slow Sand/Membrane/DE Filtration/Unfiltered</b>		<b>Monthly Summary (Answer Yes or No)</b>	
95% of daily turbidity readings $\leq$ 1 NTU? <sup>2</sup>	<input checked="" type="radio"/> Yes / <input type="radio"/> No	CT's met everyday? (see back)	All Cl <sub>2</sub> residual at entry point $\geq$ 0.2 mg/l?
All daily turbidity readings $\leq$ 5 NTU?	<input checked="" type="radio"/> Yes / <input type="radio"/> No	<input checked="" type="radio"/> Yes / <input type="radio"/> No	<input checked="" type="radio"/> Yes / <input type="radio"/> No
Notes:	PRINTED NAME: Jeremy Wolford		
	SIGNATURE: 		DATE: 4/2/25
	PHONE #: 541-679-6321		CERT #: T-7231

<sup>1</sup> Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in columns 12 AM through 8 PM may not correspond to continuous readings' maximum. <sup>2</sup> Filtered systems only.

### OHA - Drinking Water Program - Surface Water Quality Data Form (Douglas County)

**System Name: GAWSA** **ID#: 41 00717** **"A"** **Mar-25**

Date / Time	Residual at 1st User (C) <sup>3</sup>	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? <sup>3</sup>	Peak Hourly Demand Flow
	[ppm or mg/L]	[minutes]	C X T	[° C]		formula	Yes / No	[GPM]
1/ 15:00	1.384	14.18	19.6	13.1	7.23	3.8	YES	1188
2/ 1:00	1.449	15.22	22.1	12.7	7.27	3.9	YES	1107
3/ 19:00	1.431	15.22	21.8	11.5	7.29	4.4	YES	1107
4/ 20:00	1.364	15.00	20.5	15.8	7.29	3.2	YES	1123
5/ 12:00	1.459	15.22	22.2	9.3	7.30	5.1	YES	1107
6/ 21:00	1.383	14.79	20.4	15.0	7.45	3.6	YES	1139
7/ 19:00	1.391	14.79	20.6	17.6	7.46	3.0	YES	1139
8/ 20:00	1.320	14.79	19.5	16.9	7.51	3.2	YES	1139
9/ 22:00	1.439	14.58	21.0	13.9	7.56	4.0	YES	1156
10/ 20:00	1.258	14.79	18.6	15.6	7.55	3.5	YES	1139
11/ 22:00	1.374	15.45	21.2	12.5	7.62	4.5	YES	1090
12/ 22:00	1.282	15.00	19.2	8.7	7.53	5.6	YES	1123
13/ 21:00	1.311	15.00	19.7	10.4	7.54	5.0	YES	1123
14/ 14:00	1.370	15.00	20.5	7.8	7.41	5.7	YES	1123
15/ 10:00	1.267	14.58	18.5	7.3	7.36	5.8	YES	1156
16/ 10:00	1.337	15.00	20.1	8.2	7.20	5.2	YES	1123
17/ 17:00	1.312	14.38	18.9	10.5	6.88	4.0	YES	1172
18/ 19:00	1.384	15.22	21.1	11.5	7.03	3.9	YES	1107
19/ 21:00	1.364	14.79	20.2	9.5	7.12	4.6	YES	1139
20/ 2:00	1.410	15.45	21.8	7.8	7.14	5.3	YES	1090
21/ 23:00	1.316	14.38	18.9	10.5	7.19	4.4	YES	1172
22/ 19:00	1.300	14.18	18.4	9.9	7.18	4.6	YES	1188
23/ 3:00	1.307	14.58	19.1	9.3	7.16	4.7	YES	1156
24/ 17:00	1.348	14.58	19.7	15.9	7.05	2.9	YES	1156
25/ 19:00	1.304	15.22	19.8	19.8	7.10	2.3	YES	1107
26/ 20:00	1.329	15.00	19.9	21.3	7.07	2.0	YES	1123
27/ 20:00	1.346	14.58	19.6	12.7	7.13	3.7	YES	1156
28/ 23:00	1.342	15.00	20.1	10.4	7.16	4.4	YES	1123
29/ 13:00	1.334	14.18	18.9	9.6	7.16	4.7	YES	1188
30/ 19:00	1.358	14.38	19.5	11.5	7.19	4.2	YES	1172
31/ 5:00	1.331	15.92	21.2	8.9	7.23	5.0	YES	1058

<sup>3</sup> If Cl2 at entry point < 0.2 mg/l or CT not met, DWP to be notified by end of next business day.

Oregon DHS - Drinking Water Program – Surface Water Quality Data

System Name: GAUSA

PWS ID#: 41 00717 Month/Year: 3/2025

Minimum UVT [%] during month: 99.9

Duty sensor variation from reference sensor: 5.1%

Minimum Validated UVT: 99.9 {Insert Req'd Value}

Date	Peak Hourly Demand Flow	Minimum Intensity	All Lamps On?	Daily Water Produced {A}	Water outside Validated Conditions {B}	Cumulative % Off-Spec Water Produced
	[gpm]	[ $mW/cm^2$ ]	[Y or N]	[gal]	[gal]	(Mo. Sum (B)) ÷ (Mo. Sum (A)) * 100 [%]
1	2900	24.5	Y	1,030,923	0	0
2	2900	15.8	Y	1,095,628	0	0
3	2900	17.9	Y	1,069,161	0	0
4	2900	17.2	Y	1,014,488	0	0
5	2900	17.3	Y	1,134,895	0	0
6	2900	16.9	Y	1,052,500	0	0
7	2900	22.5	Y	1,133,623	0	0
8	2900	22.0	Y	1,025,937	0	0
9	2900	17.1	Y	1,062,081	0	0
10	2900	15.7	Y	1,167,284	0	0
11	2900	17.9	Y	963,039	0	0
12	2900	15.9	Y	1,007,897	0	0
13	2900	21.4	Y	991,346	0	0
14	2900	15.0	Y	1,101,656	0	0
15	2900	19.5	Y	1,016,814	0	0
16	2900	13.8	Y	611,461	0	0
17	2900	18.5	Y	1,439,275	0	0
18	2900	20.4	Y	1,062,313	0	0
19	2900	14.8	Y	976,268	0	0
20	2900	15.2	Y	1,086,264	0	0
21	2900	15.2	Y	1,086,282	0	0
22	2900	21.5	Y	841,309	0	0
23	2900	14.5	Y	1,154,507	0	0
24	2900	15.3	Y	939,997	0	0
25	2900	19.7	Y	1,258,412	0	0
26	2900	22.4	Y	1,047,413	0	0
27	2900	15.8	Y	1,049,052	0	0
28	2900	22.3	Y	972,199	0	0
29	2900	15.2	Y	1,090,468	0	0
30	2900	22.5	Y	1,086,529	0	0
31	2900	22.2	Y	1,026,006	0	0
Monthly Cumulative % Off-Spec Water Produced						0

Signature: 

Op Cert #: T-7231

Date: 4/2/25