

OHA - Drinking Water Program - Surface Water Quality Data Form
Slow Sand, Membrane, Diatomaceous Earth Filtration, or Unfiltered Systems(Douglas County)

System Name: GAWSA			ID#: 41 00717		"A"		Apr-25
Day	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the day ¹ [NTU]
1	0.032	0.032	0.033	OFF	0.033	0.031	0.042
2	0.031	OFF	OFF	0.031	0.032	0.031	0.032
3	OFF	OFF	0.031	0.031	OFF	0.031	0.031
4	0.031	0.030	0.030	0.030	OFF	0.030	0.032
5	0.030	0.030	OFF	OFF	0.030	0.030	0.031
6	OFF	OFF	OFF	0.030	0.030	0.030	0.030
7	OFF	OFF	0.030	0.030	OFF	OFF	0.037
8	0.030	0.030	0.030	0.030	0.031	0.031	0.039
9	OFF	0.031	0.031	0.031	OFF	0.030	0.031
10	0.030	0.030	0.030	OFF	OFF	0.030	0.031
11	0.030	0.030	0.030	0.030	OFF	0.030	0.031
12	0.030	0.030	OFF	OFF	OFF	0.030	0.032
13	0.030	OFF	OFF	OFF	0.030	0.030	0.030
14	OFF	OFF	0.030	OFF	0.029	0.029	0.055
15	OFF	OFF	OFF	0.029	OFF	0.029	0.029
16	0.029	0.029	0.029	OFF	0.029	0.029	0.029
17	OFF	OFF	0.029	0.029	0.029	0.029	0.030
18	0.029	0.029	0.029	0.029	0.029	0.029	0.031
19	OFF	OFF	0.029	0.029	OFF	0.029	0.029
20	0.028	0.029	OFF	OFF	0.028	0.028	0.029
21	OFF	OFF	0.028	0.028	OFF	0.028	0.031
22	0.029	OFF	OFF	0.029	0.029	0.029	0.032
23	OFF	0.028	0.028	0.290	0.029	0.029	0.029
24	OFF	0.029	0.029	0.029	0.028	0.028	0.030
25	0.028	0.028	0.028	OFF	0.028	0.028	0.029
26	OFF	OFF	0.028	0.028	0.028	OFF	0.029
27	0.028	0.028	0.028	OFF	0.028	0.028	0.029
28	0.028	0.028	0.028	0.028	0.028	0.028	0.030
29	0.028	0.028	0.029	0.028	0.028	0.028	0.029
30	0.028	OFF	0.028	0.028	0.028	OFF	0.029
31							

Slow Sand/Membrane/DE Filtration/Unfiltered 95% of daily turbidity readings $\leq$ 1 NTU? ² <u>Yes</u> / No All daily turbidity readings $\leq$ 5 NTU? <u>Yes</u> / No Notes:	Monthly Summary (Answer Yes or No) <table border="1" style="width:100%; border-collapse: collapse;"> <tr> <td style="width:50%;">CT's met everyday? (see back)</td> <td style="width:50%;">All Cl2 residual at entry point $\geq$ 0.2 mg/l?</td> </tr> <tr> <td align="center"><u>Yes</u> / No</td> <td align="center"><u>Yes</u> / No</td> </tr> </table> PRINTED NAME: Jeremy Wolford <table border="1" style="width:100%; border-collapse: collapse;"> <tr> <td style="width:70%;">SIGNATURE: </td> <td style="width:30%;">DATE: 5/1/25</td> </tr> <tr> <td>PHONE #: 541-679-6321</td> <td>CERT #: T-7231</td> </tr> </table>	CT's met everyday? (see back)	All Cl2 residual at entry point $\geq$ 0.2 mg/l?	<u>Yes</u> / No	<u>Yes</u> / No	SIGNATURE: 	DATE: 5/1/25	PHONE #: 541-679-6321	CERT #: T-7231
CT's met everyday? (see back)	All Cl2 residual at entry point $\geq$ 0.2 mg/l?								
<u>Yes</u> / No	<u>Yes</u> / No								
SIGNATURE: 	DATE: 5/1/25								
PHONE #: 541-679-6321	CERT #: T-7231								

¹ Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in columns 12 AM through 8 PM may not correspond to continuous readings' maximum. ² Filtered systems only.

OHA - Drinking Water Program - Surface Water Quality Data Form (Douglas County)

System Name: GAWSA

ID#: 41 00717

"A"

Apr-25

Date / Time	Residual at 1st User (C) ³	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? ³	Peak Hourly Demand Flow
	[ppm or mg/L]	[minutes]	C X T	[° C]		formula	Yes / No	[GPM]
1/ 15:00	1.306	14.18	18.5	9.3	7.13	4.7	YES	1188
2/ 12:00	1.436	14.79	21.2	8.7	7.15	5.0	YES	1139
3/ 14:00	1.442	14.58	21.0	10.2	7.11	4.4	YES	1156
4/ 19:00	1.424	14.58	20.8	16.3	7.19	3.0	YES	1156
5/ 11:00	1.527	14.79	22.6	10.6	7.26	4.6	YES	1139
6/ 11:00	1.474	14.58	21.5	13.6	7.23	3.7	YES	1156
7/ 13:00	1.400	15.00	21.0	12.4	7.11	3.8	YES	1123
8/ 23:00	1.550	14.79	22.9	13.4	7.30	3.9	YES	1139
9/ 18:00	1.415	14.38	20.3	16.4	7.25	3.0	YES	1172
10/ 9:00	1.396	14.58	20.4	11.8	7.30	4.3	YES	1156
11/ 14:00	1.340	14.58	19.5	13.1	7.02	3.5	YES	1156
12/ 10:00	1.397	15.22	21.3	11.5	7.33	4.4	YES	1107
13/ 11:00	1.449	14.79	21.4	11.1	7.33	4.5	YES	1139
14/ 22:00	1.415	14.38	20.3	20.0	7.46	2.6	YES	1172
15/ 20:00	1.322	15.22	20.1	21.3	7.43	2.3	YES	1107
16/ 10:00	1.434	14.58	20.9	14.1	7.31	3.6	YES	1156
17/ 2:00	1.412	14.79	20.9	16.6	7.54	3.4	YES	1139
18/ 17:00	1.270	14.38	18.3	18.0	7.53	3.0	YES	1172
19/ 20:00	1.317	14.79	19.5	19.7	7.99	3.2	YES	1139
20/ 17:00	1.325	14.58	19.3	15.3	7.73	3.9	YES	1156
21/ 18:00	1.288	14.58	18.8	16.5	7.69	3.5	YES	1156
22/ 1:00	1.299	15.68	20.4	15.5	7.94	4.1	YES	1074
23/ 20:00	1.380	15.00	20.7	19.9	7.87	3.0	YES	1123
24/ 20:00	1.269	14.79	18.8	16.8	7.86	3.7	YES	1139
25/ 22:00	1.325	14.18	18.8	13.6	7.64	4.2	YES	1188
26/ 13:00	1.299	14.38	18.7	12.9	7.40	4.0	YES	1172
27/ 15:00	1.372	14.18	19.5	13.4	7.45	4.0	YES	1188
28/ 15:00	1.346	14.58	19.6	14.2	7.51	3.8	YES	1156
29/ 19:00	1.354	14.79	20.0	19.8	7.74	2.9	YES	1139
30/ 19:00	1.331	14.79	19.7	20.3	7.65	2.7	YES	1139

³ If Cl2 at entry point < 0.2 mg/l or CT not met, DWP to be notified by end of next business day.

Oregon DHS - Drinking Water Program - Surface Water Quality Data

System Name: GAWSA


PWS ID#: 41 00717 Month/Year: 4/2025

Minimum UVT [%] during month: 99.9%

Duty sensor variation from reference sensor: 5.8%

Minimum Validated UVT: 99.9% Insert Req'd Value!

Date	Peak Hourly Demand Flow	Minimum Intensity	All Lamps On?	Daily Water Produced {A}	Water outside Validated Conditions {B}	Cumulative % Off-Spec Water Produced
	[gpm]	[mW/cm ²]	[Y or N]	[gal]	[gal]	(Mo. Sum {B}) ÷ (Mo. Sum {A}) * 100 [%]
1	2900	14.2	Y	969,667	0	0
2	2900	15.1	Y	1,118,863	0	0
3	2900	15.7	Y	1,086,090	0	0
4	2900	22.3	Y	1,055,121	0	0
5	2900	15.7	Y	1,029,536	0	0
6	2900	16.2	Y	1,102,366	0	0
7	2900	22.1	Y	1,100,457	0	0
8	2900	16.1	Y	1,151,778	0	0
9	2900	22.0	Y	1,033,613	0	0
10	2900	15.1	Y	1,034,981	0	0
11	2900	22.4	Y	1,049,084	0	0
12	2900	22.4	Y	1,048,044	0	0
13	2900	22.5	Y	1,137,085	0	0
14	2900	23.2	Y	1,165,512	0	0
15	2900	24.3	Y	1,121,125	0	0
16	2900	19.8	Y	1,165,376	0	0
17	2900	15.8	Y	1,224,506	0	0
18	2900	22.1	Y	1,255,406	0	0
19	2900	17.1	Y	1,136,476	0	0
20	2900	22.2	Y	1,187,751	0	0
21	2900	22.1	Y	1,147,484	0	0
22	2900	24.1	Y	1,101,297	0	0
23	2900	16.1	Y	1,304,702	0	0
24	2900	21.8	Y	1,342,348	0	0
25	2900	15.7	Y	1,245,054	0	0
26	2900	24.0	Y	1,147,905	0	0
27	2900	16.0	Y	1,262,662	0	0
28	2900	15.7	Y	1,352,456	0	0
29	2900	23.3	Y	1,239,353	0	0
30	2900	15.7	Y	1,452,283	0	0
31						
Monthly Cumulative % Off-Spec Water Produced						0

Signature: 

Op Cert #: T-7231
Page 2 of 3

Date: 5/1/25