

**OHA - Drinking Water Program - Surface Water Quality Data Form**  
**Slow Sand, Membrane, Diatomaceous Earth Filtration, or Unfiltered Systems(Douglas County)**

| System Name: GAWSA |                | ID#: 41 00717 |               | "A"           |               | May-25        |                                       |
|--------------------|----------------|---------------|---------------|---------------|---------------|---------------|---------------------------------------|
| Day                | 12 AM<br>[NTU] | 4 AM<br>[NTU] | 8 AM<br>[NTU] | NOON<br>[NTU] | 4 PM<br>[NTU] | 8 PM<br>[NTU] | Highest Reading of the day<br>¹ [NTU] |
| 1                  | 0.028          | 0.028         | 0.028         | 0.028         | OFF           | 0.028         | 0.029                                 |
| 2                  | 0.028          | 0.028         | OFF           | 0.029         | 0.028         | 0.028         | 0.030                                 |
| 3                  | 0.028          | OFF           | 0.028         | OFF           | 0.028         | 0.028         | 0.028                                 |
| 4                  | OFF            | OFF           | 0.028         | 0.028         | 0.028         | 0.028         | 0.029                                 |
| 5                  | 0.028          | 0.028         | 0.028         | 0.028         | 0.027         | 0.027         | 0.037                                 |
| 6                  | 0.027          | 0.027         | 0.027         | OFF           | 0.027         | 0.028         | 0.031                                 |
| 7                  | OFF            | 0.027         | 0.029         | 0.027         | 0.027         | 0.027         | 0.031                                 |
| 8                  | 0.027          | 0.027         | 0.027         | 0.027         | 0.027         | 0.027         | 0.028                                 |
| 9                  | 0.027          | OFF           | 0.027         | 0.027         | 0.027         | 0.027         | 0.027                                 |
| 10                 | 0.027          | 0.027         | OFF           | 0.027         | 0.027         | 0.027         | 0.027                                 |
| 11                 | 0.027          | 0.027         | 0.027         | 0.027         | 0.027         | 0.027         | 0.032                                 |
| 12                 | 0.027          | OFF           | 0.027         | 0.027         | 0.027         | 0.027         | 0.028                                 |
| 13                 | 0.027          | OFF           | 0.027         | 0.027         | 0.027         | 0.027         | 0.027                                 |
| 14                 | 0.027          | OFF           | OFF           | 0.027         | 0.027         | 0.027         | 0.027                                 |
| 15                 | 0.026          | 0.026         | 0.026         | OFF           | 0.027         | 0.027         | 0.041                                 |
| 16                 | 0.026          | 0.026         | 0.026         | OFF           | 0.027         | 0.027         | 0.034                                 |
| 17                 | 0.027          | 0.027         | 0.027         | 0.026         | 0.026         | 0.026         | 0.028                                 |
| 18                 | OFF            | 0.026         | 0.026         | OFF           | 0.026         | 0.026         | 0.026                                 |
| 19                 | 0.026          | OFF           | 0.026         | 0.029         | 0.027         | 0.026         | 0.038                                 |
| 20                 | 0.026          | 0.026         | 0.026         | 0.026         | 0.026         | 0.026         | 0.034                                 |
| 21                 | OFF            | 0.026         | 0.026         | 0.026         | 0.026         | 0.026         | 0.027                                 |
| 22                 | OFF            | OFF           | 0.026         | 0.026         | 0.026         | 0.026         | 0.036                                 |
| 23                 | 0.026          | OFF           | 0.026         | 0.027         | 0.026         | 0.026         | 0.044                                 |
| 24                 | 0.026          | 0.026         | 0.026         | 0.026         | 0.026         | 0.026         | 0.030                                 |
| 25                 | 0.026          | 0.026         | 0.026         | 0.026         | 0.026         | 0.026         | 0.027                                 |
| 26                 | 0.026          | OFF           | 0.026         | 0.027         | 0.026         | 0.026         | 0.027                                 |
| 27                 | 0.026          | 0.026         | 0.026         | 0.027         | 0.027         | 0.026         | 0.034                                 |
| 28                 | 0.027          | 0.026         | 0.027         | 0.027         | 0.027         | 0.028         | 0.029                                 |
| 29                 | 0.028          | OFF           | 0.028         | 0.028         | 0.028         | 0.028         | 0.029                                 |
| 30                 | 0.028          | 0.027         | 0.028         | 0.028         | 0.028         | 0.028         | 0.032                                 |
| 31                 | 0.028          | 0.028         | OFF           | 0.028         | 0.028         | 0.029         | 0.031                                 |

|                                                                                                                                                                           |  |                                                                                                                                                           |  |
|---------------------------------------------------------------------------------------------------------------------------------------------------------------------------|--|-----------------------------------------------------------------------------------------------------------------------------------------------------------|--|
| <b>Slow Sand/Membrane/DE Filtration/Unfiltered</b><br>95% of daily turbidity readings ≤ 1 NTU? ² <u>Yes</u> / No<br>All daily turbidity readings ≤ 5 NTU? <u>Yes</u> / No |  | <b>Monthly Summary (Answer Yes or No)</b><br>CT's met everyday? (see back) <u>Yes</u> / No<br>All Cl₂ residual at entry point ≥ 0.2 mg/l? <u>Yes</u> / No |  |
| <b>Notes:</b><br><br><br>                                                                                                                                                 |  | PRINTED NAME: Jeremy Wolford                                                                                                                              |  |
|                                                                                                                                                                           |  | SIGNATURE:  DATE: 6/2/25                                              |  |
|                                                                                                                                                                           |  | PHONE #: 541-679-6321 CERT #: T-7231                                                                                                                      |  |

¹ Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in columns 12 AM through 8 PM may not correspond to continuous readings' maximum. ² Filtered systems only.

# OHA - Drinking Water Program - Surface Water Quality Data Form(Douglas County)

|                           |  |  |                      |  |            |  |               |  |
|---------------------------|--|--|----------------------|--|------------|--|---------------|--|
| <b>System Name: GAWSA</b> |  |  | <b>ID#: 41 00717</b> |  | <b>"A"</b> |  | <b>May-25</b> |  |
|---------------------------|--|--|----------------------|--|------------|--|---------------|--|

| Date / Time | Residual at<br>1st User<br>(C) <sup>3</sup> | Contact Time<br>(T) | Actual CT | Temp  | pH   | Required CT | CT Met? <sup>3</sup> | Peak Hourly<br>Demand<br>Flow |
|-------------|---------------------------------------------|---------------------|-----------|-------|------|-------------|----------------------|-------------------------------|
|             | [ppm or mg/L]                               | [minutes]           | C X T     | [° C] |      | formula     | Yes / No             | [GPM]                         |
| 1/ 11:00    | 1.406                                       | 14.38               | 20.2      | 14.4  | 7.35 | 3.6         | YES                  | 1172                          |
| 2/ 20:00    | 1.264                                       | 14.79               | 18.7      | 18.9  | 7.43 | 2.7         | YES                  | 1139                          |
| 3/ 16:00    | 1.390                                       | 14.58               | 20.3      | 16.4  | 7.24 | 3.0         | YES                  | 1156                          |
| 4/ 20:00    | 1.240                                       | 13.11               | 16.3      | 20.1  | 7.38 | 2.5         | YES                  | 1286                          |
| 5/ 4:00     | 1.429                                       | 15.22               | 21.7      | 15.3  | 7.33 | 3.4         | YES                  | 1107                          |
| 6/ 16:00    | 1.271                                       | 8.17                | 10.4      | 16.7  | 7.30 | 3.0         | YES                  | 2067                          |
| 7/ 4:00     | 1.343                                       | 9.69                | 13.0      | 16.8  | 7.26 | 3.0         | YES                  | 1742                          |
| 8/ 12:00    | 1.518                                       | 14.58               | 22.1      | 16.7  | 7.19 | 3.0         | YES                  | 1156                          |
| 9/ 18:00    | 1.427                                       | 14.79               | 21.1      | 20.3  | 7.29 | 2.4         | YES                  | 1139                          |
| 10/ 11:00   | 1.358                                       | 14.38               | 19.5      | 17.9  | 7.08 | 2.6         | YES                  | 1172                          |
| 11/ 22:00   | 1.386                                       | 14.58               | 20.2      | 17.5  | 7.14 | 2.7         | YES                  | 1156                          |
| 12/ 21:00   | 1.326                                       | 14.79               | 19.6      | 16.4  | 7.47 | 3.3         | YES                  | 1139                          |
| 13/ 20:00   | 1.336                                       | 14.79               | 19.8      | 16.2  | 7.42 | 3.3         | YES                  | 1139                          |
| 14/ 22:00   | 1.307                                       | 14.18               | 18.5      | 19.0  | 7.38 | 2.7         | YES                  | 1188                          |
| 15/ 17:00   | 1.385                                       | 13.45               | 18.6      | 18.5  | 6.99 | 2.4         | YES                  | 1253                          |
| 16/ 19:00   | 1.187                                       | 14.58               | 17.3      | 21.5  | 7.23 | 2.1         | YES                  | 1156                          |
| 17/ 15:00   | 1.326                                       | 14.18               | 18.8      | 18.6  | 7.26 | 2.6         | YES                  | 1188                          |
| 18/ 9:00    | 1.305                                       | 14.58               | 19.0      | 14.5  | 7.14 | 3.3         | YES                  | 1156                          |
| 19/ 2:00    | 1.222                                       | 14.79               | 18.1      | 16.0  | 7.24 | 3.1         | YES                  | 1139                          |
| 20/ 15:00   | 1.359                                       | 15.00               | 20.4      | 18.8  | 7.06 | 2.4         | YES                  | 1123                          |
| 21/ 15:00   | 1.442                                       | 14.18               | 20.5      | 19.6  | 7.18 | 2.4         | YES                  | 1188                          |
| 22/ 6:00    | 1.426                                       | 14.18               | 20.2      | 15.2  | 7.06 | 3.1         | YES                  | 1188                          |
| 23/ 22:00   | 1.467                                       | 15.00               | 22.0      | 22.6  | 7.25 | 2.0         | YES                  | 1123                          |
| 24/ 21:00   | 1.353                                       | 14.79               | 20.0      | 24.4  | 7.33 | 1.8         | YES                  | 1139                          |
| 25/ 14:00   | 1.387                                       | 14.58               | 20.2      | 19.3  | 7.02 | 2.3         | YES                  | 1156                          |
| 26/ 23:00   | 1.267                                       | 14.18               | 18.0      | 21.0  | 7.25 | 2.2         | YES                  | 1188                          |
| 27/ 2:00    | 1.394                                       | 14.18               | 19.8      | 17.8  | 7.16 | 2.7         | YES                  | 1188                          |
| 28/ 10:00   | 1.398                                       | 9.87                | 13.8      | 18.9  | 7.22 | 2.6         | YES                  | 1709                          |
| 29/ 22:00   | 1.139                                       | 17.25               | 19.6      | 25.2  | 7.48 | 1.8         | YES                  | 977                           |
| 30/ 17:00   | 1.348                                       | 9.97                | 13.4      | 28.6  | 7.33 | 1.4         | YES                  | 1693                          |
| 31/ 16:00   | 1.258                                       | 9.97                | 12.5      | 26.9  | 7.27 | 1.5         | YES                  | 1693                          |

<sup>3</sup> If Cl2 at entry point < 0.2 mg/l or CT not met, DWP to be notified by end of next business day.

# Oregon DHS - Drinking Water Program - Surface Water Quality Data

System Name: GAWSA


PWS ID#: 41 00717 Month/Year: 5/2025

Minimum UVT [%] during month: 99.9%

Duty sensor variation from reference sensor: 6.0%

Minimum Validated UVT 99.9% insert Req'd Value

| Date                                         | Peak Hourly Demand Flow | Minimum Intensity     | All Lamps On? | Daily Water Produced {A} | Water outside Validated Conditions {B} | Cumulative % Off-Spec Water Produced    |
|----------------------------------------------|-------------------------|-----------------------|---------------|--------------------------|----------------------------------------|-----------------------------------------|
|                                              | [gpm]                   | [mW/cm <sup>2</sup> ] | [Y or N]      | [gal]                    | [gal]                                  | (Mo. Sum {B}) ÷ (Mo. Sum {A}) * 100 [%] |
| 1                                            | 2900                    | 15.9                  | Y             | 1,466,090                | 0                                      | 0                                       |
| 2                                            | 2900                    | 15.1                  | Y             | 1,546,627                | 0                                      | 0                                       |
| 3                                            | 2900                    | 15.6                  | Y             | 1,397,619                | 0                                      | 0                                       |
| 4                                            | 2900                    | 15.9                  | Y             | 1,428,501                | 0                                      | 0                                       |
| 5                                            | 2900                    | 15.9                  | Y             | 1,211,032                | 0                                      | 0                                       |
| 6                                            | 2900                    | 16.0                  | Y             | 2,016,940                | 0                                      | 0                                       |
| 7                                            | 2900                    | 20.7                  | Y             | 1,655,145                | 0                                      | 0                                       |
| 8                                            | 2900                    | 21.9                  | Y             | 1,796,913                | 0                                      | 0                                       |
| 9                                            | 2900                    | 15.4                  | Y             | 1,550,299                | 0                                      | 0                                       |
| 10                                           | 2900                    | 21.9                  | Y             | 1,576,989                | 0                                      | 0                                       |
| 11                                           | 2900                    | 15.6                  | Y             | 1,453,181                | 0                                      | 0                                       |
| 12                                           | 2900                    | 22.1                  | Y             | 1,391,645                | 0                                      | 0                                       |
| 13                                           | 2900                    | 15.8                  | Y             | 1,422,383                | 0                                      | 0                                       |
| 14                                           | 2900                    | 22.1                  | Y             | 1,024,667                | 0                                      | 0                                       |
| 15                                           | 2900                    | 21.8                  | Y             | 1,435,831                | 0                                      | 0                                       |
| 16                                           | 2900                    | 21.3                  | Y             | 1,380,127                | 0                                      | 0                                       |
| 17                                           | 2900                    | 21.1                  | Y             | 1,549,089                | 0                                      | 0                                       |
| 18                                           | 2900                    | 24.5                  | Y             | 1,427,074                | 0                                      | 0                                       |
| 19                                           | 2900                    | 21.5                  | Y             | 1,232,329                | 0                                      | 0                                       |
| 20                                           | 2900                    | 21.1                  | Y             | 1,631,613                | 0                                      | 0                                       |
| 21                                           | 2900                    | 21.4                  | Y             | 1,552,423                | 0                                      | 0                                       |
| 22                                           | 2900                    | 21.5                  | Y             | 1,491,783                | 0                                      | 0                                       |
| 23                                           | 2900                    | 22.1                  | Y             | 1,409,305                | 0                                      | 0                                       |
| 24                                           | 2900                    | 21.4                  | Y             | 1,799,425                | 0                                      | 0                                       |
| 25                                           | 2900                    | 21.4                  | Y             | 1,798,412                | 0                                      | 0                                       |
| 26                                           | 2900                    | 21.9                  | Y             | 1,490,947                | 0                                      | 0                                       |
| 27                                           | 2900                    | 21.2                  | Y             | 1,735,870                | 0                                      | 0                                       |
| 28                                           | 2900                    | 21.0                  | Y             | 2,167,803                | 0                                      | 0                                       |
| 29                                           | 2900                    | 20.9                  | Y             | 1,482,678                | 0                                      | 0                                       |
| 30                                           | 2900                    | 20.1                  | Y             | 2,004,454                | 0                                      | 0                                       |
| 31                                           | 2900                    | 21.0                  | Y             | 2,128,990                | 0                                      | 0                                       |
| Monthly Cumulative % Off-Spec Water Produced |                         |                       |               |                          |                                        | 0                                       |

Signature: 

Op Cert #: T-7231

Date: 6/2/25