

OHA - Drinking Water Program - Surface Water Quality Data Form
Slow Sand, Membrane, Diatomaceous Earth Filtration, or Unfiltered Systems(Douglas County)

System Name: GAWSA		ID#: 41 00717		"A"		Jun-25	
Day	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the day ¹ [NTU]
1	0.028	0.028	0.028	0.028	OFF	0.028	0.029
2	OFF	0.028	0.028	0.031	0.028	0.028	0.035
3	0.028	OFF	0.028	OFF	0.028	0.028	0.030
4	OFF	0.028	0.028	0.028	0.028	0.028	0.037
5	0.028	OFF	0.028	0.029	0.029	0.028	0.036
6	OFF	0.028	0.028	0.028	0.028	0.028	0.031
7	0.028	OFF	0.028	0.028	OFF	0.028	0.031
8	0.028	OFF	0.028	0.028	0.032	0.028	0.029
9	0.029	0.028	0.028	0.029	0.029	0.029	0.035
10	0.029	0.028	0.029	0.029	0.028	0.029	0.030
11	0.029	OFF	0.029	0.029	0.029	0.029	0.029
12	0.029	OFF	0.029	0.029	0.029	0.029	0.034
13	0.029	OFF	0.029	0.029	0.030	0.029	0.030
14	OFF	0.029	0.029	0.029	OFF	0.029	0.030
15	OFF	0.029	OFF	0.029	0.029	0.029	0.031
16	0.029	OFF	0.029	0.029	0.029	0.029	0.035
17	OFF	0.029	OFF	0.029	0.029	0.029	0.031
18	OFF	0.029	0.033	0.036	0.030	0.030	0.039
19	0.030	OFF	0.030	OFF	0.023	OFF	0.061
20	0.022	OFF	0.022	0.022	OFF	0.022	0.024
21	OFF	0.022	OFF	0.022	0.023	OFF	0.023
22	0.022	OFF	0.022	OFF	0.022	OFF	0.023
23	0.022	OFF	0.022	0.022	0.023	0.022	0.024
24	0.022	OFF	0.022	0.022	0.022	0.022	0.026
25	0.022	OFF	0.022	0.022	0.023	0.022	0.024
26	OFF	0.022	0.023	0.023	OFF	0.022	0.031
27	0.023	0.023	0.023	0.023	0.023	0.023	0.025
28	OFF	0.023	0.023	0.023	OFF	0.023	0.025
29	OFF	0.023	OFF	0.023	0.023	0.023	0.028
30	OFF	0.023	0.023	0.025	0.023	0.022	0.067
31							

Slow Sand/Membrane/DE Filtration/Unfiltered 95% of daily turbidity readings ≤ 1 NTU? ² ☒ Yes ☐ No All daily turbidity readings ≤ 5 NTU? ☒ Yes ☐ No		Monthly Summary (Answer Yes or No) CT's met everyday? (see back) ☒ Yes ☐ No All Cl2 residual at entry point ≥ 0.2 mg/l? ☒ Yes ☐ No	
Notes: 		PRINTED NAME: Jeremy Wolford	
		SIGNATURE: 	
		DATE: 7/1/25	
		PHONE #: 541-679-6321	
		CERT #: T-7231	

¹ Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in columns 12 AM through 8 PM may not correspond to continuous readings' maximum. ² Filtered systems only.

OHA - Drinking Water Program - Surface Water Quality Data Form (DOUGLAS COUNTY)

System Name: GAWSA	ID#: 41 00717	"A"	Jun-25
---------------------------	----------------------	------------	---------------

Date / Time	Residual at 1st User (C) ³	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? ³	Peak Hourly Demand Flow
	[ppm or mg/L]	[minutes]	C X T	[° C]		formula	Yes / No	[GPM]
1/ 19:00	1.260	9.97	12.6	28.4	7.41	1.4	YES	1693
2/ 22:00	1.317	9.97	13.1	25.4	7.39	1.7	YES	1693
3/ 19:00	1.385	9.97	13.8	30.8	7.41	1.2	YES	1693
4/ 17:00	1.351	9.87	13.3	26.2	7.34	1.6	YES	1709
5/ 17:00	1.174	9.69	11.4	25.8	6.94	1.4	YES	1742
6/ 20:00	1.245	9.87	12.3	33.4	7.32	1.0	YES	1709
7/ 20:00	1.200	9.87	11.8	36.1	7.24	0.8	YES	1709
8/ 18:00	1.733	9.87	17.1	33.7	7.41	1.0	YES	1709
9/ 17:00	1.152	9.78	11.3	34.0	6.70	0.7	YES	1725
10/ 16:00	1.086	9.60	10.4	31.9	7.59	1.2	YES	1758
11/ 20:00	1.588	9.87	15.7	30.6	7.86	1.5	YES	1709
12/ 11:00	1.995	9.78	19.5	21.8	7.69	2.7	YES	1725
13/ 20:00	1.733	9.87	17.1	22.0	8.07	3.0	YES	1709
14/ 21:00	1.758	9.87	17.3	26.3	8.11	2.2	YES	1709
15/ 21:00	1.645	9.78	16.1	27.9	7.94	1.9	YES	1725
16/ 17:00	1.558	9.87	15.4	26.1	7.72	1.9	YES	1709
17/ 21:00	1.769	9.78	17.3	29.3	7.78	1.6	YES	1725
18/ 9:00	1.873	9.69	18.1	19.9	7.23	2.5	YES	1742
19/ 22:00	1.800	9.87	17.8	23.5	7.75	2.4	YES	1709
20/ 20:00	1.606	9.87	15.9	19.2	7.77	3.1	YES	1709
21/ 19:00	1.617	9.87	16.0	18.1	7.78	3.4	YES	1709
22/ 16:00	1.580	9.87	15.6	22.4	7.80	2.6	YES	1709
23/ 21:00	1.559	9.78	15.2	28.8	7.83	1.7	YES	1725
24/ 13:00	1.570	9.60	15.1	24.2	7.57	2.1	YES	1758
25/ 20:00	1.646	9.78	16.1	29.6	7.67	1.5	YES	1725
26/ 13:00	1.617	9.78	15.8	23.2	7.37	2.1	YES	1725
27/ 6:00	1.589	9.69	15.4	21.1	7.52	2.5	YES	1742
28/ 21:00	1.556	9.78	15.2	30.9	7.61	1.3	YES	1725
29/ 21:00	1.552	9.78	15.2	33.6	7.60	1.1	YES	1725
30/ 18:00	1.506	9.78	14.7	34.0	7.46	1.0	YES	1725

³ If Cl2 at entry point < 0.2 mg/l or CT not met, DWP to be notified by end of next business day.

Oregon DHS - Drinking Water Program - Surface Water Quality Data

System Name: GAWSA


PWS ID#: 41 00717 Month/Year: 6/2025

Minimum UVT [%] during month: 99.9%

Duty sensor variation from reference sensor: 4.1 %

Minimum Validated UVT: 99.9 [Insert Req'd Value]

Date	Peak Hourly Demand Flow	Minimum Intensity	All Lamps On?	Daily Water Produced {A}	Water outside Validated Conditions {B}	Cumulative % Off-Spec Water Produced
	[gpm]	[mW/cm ²]	[Y or N]	[gal]	[gal]	(Mo. Sum {B}) ÷ (Mo. Sum {A}) * 100 [%]
1	2900	18.0	Y	2,231,672	0	0
2	2900	20.2	Y	1,991,307	0	0
3	2900	20.7	Y	2,045,291	0	0
4	2900	22.5	Y	2,016,298	0	0
5	2900	15.5	Y	1,982,097	0	0
6	2900	20.5	Y	2,184,884	0	0
7	2900	15.4	Y	2,231,965	0	0
8	2900	15.3	Y	2,263,822	0	0
9	2900	15.1	Y	2,005,425	0	0
10	2900	15.2	Y	2,764,847	0	0
11	2900	15.3	Y	2,082,177	0	0
12	2900	20.1	Y	2,204,665	0	0
13	2900	22.1	Y	1,915,490	0	0
14	2900	20.2	Y	2,126,228	0	0
15	2900	20.1	Y	1,968,260	0	0
16	2900	20.0	Y	2,130,136	0	0
17	2900	20.4	Y	2,029,884	0	0
18	2900	20.1	Y	2,063,636	0	0
19	2900	20.1	Y	1,943,142	0	0
20	2900	19.2	Y	1,647,138	0	0
21	2900	21.0	Y	1,486,466	0	0
22	2900	20.0	Y	1,691,179	0	0
23	2900	20.2	Y	1,873,710	0	0
24	2900	20.7	Y	2,100,281	0	0
25	2900	20.2	Y	2,020,719	0	0
26	2900	20.5	Y	2,075,702	0	0
27	2900	15.0	Y	1,945,333	0	0
28	2900	19.8	Y	2,115,930	0	0
29	2900	15.2	Y	2,035,373	0	0
30	2900	15.4	Y	2,225,888	0	0
31						
Monthly Cumulative % Off-Spec Water Produced						0

Signature: 

Op Cert #: T-7231
Page 2 of 3

Date: 7/1/25