

OHA - DWS

Membrane Filter Monthly Operating Report

County: **Douglas**

System Name: **Green Area Water & Sanitary Authority**

Month/Year: **Feb 2026**

PWS ID#: 41 - **00717**

Minimum test pressure applied || req'd:

12.5 psi || 11.4 psi

Plant ID: WTP - **A** (e.g., "A")

DIT = Direct Integrity Test on filter(s) [Yes, No, or "off" if all filters are offline] ⇔

PDR = Pressure Decay Rate


LRC = Log Removal Credit

Day	CFE Daily Turbidity [NTU]	Highest CFE* [NTU]	Highest IFE [NTU] (>15 min duration)	PDR _{Max} [psi/min]	LRC [log removal]	DIT Daily
				1.500	4.00	
				Highest PDR of day [psi/min]	Lowest LRV _{ambient} of day [log removal]	[Y/N] or "off"
1	0.022	0.0225	0.048	1.04	4.22	Y
2	0.022	0.0228	0.051	1.04	4.23	Y
3	0.022	0.0224	0.046	0.99	4.28	Y
4	0.022	0.0289	0.045	0.99	4.27	Y
5	0.023	0.0234	0.056	1.02	4.26	Y
6	0.023	0.0231	0.045	1.03	4.25	Y
7	0.022	0.0224	0.047	1.03	4.24	Y
8	0.022	0.0227	0.057	1.03	4.23	Y
9	0.025	0.0292	0.057	1.03	4.22	Y
10	0.025	0.0253	0.061	1.03	4.22	Y
11	0.022	0.024	0.070	1.00	4.23	Y
12	0.022	0.0236	0.058	1.00	4.24	Y
13	0.022	0.0236	0.059	1.00	4.25	Y
14	0.023	0.0231	0.077	0.97	4.26	Y
15	0.022	0.0246	0.090	0.97	4.28	Y
16	0.022	0.0235	0.076	0.97	4.29	Y
17	0.022	0.0233	0.049	1.11	4.28	Y
18	0.022	0.023	0.054	0.96	4.27	Y
19	0.023	0.0226	0.054	0.96	4.27	Y
20	0.022	0.0245	0.060	0.96	4.27	Y
21	0.023	0.0228	0.048	1.00	4.27	Y
22	0.023	0.0229	0.059	1.00	4.26	Y
23	0.023	0.0252	0.041	1.00	4.25	Y
24	0.025	0.0273	0.079	1.00	4.25	Y
25	0.023	0.0268	0.058	1.41	4.25	Y
26	0.022	0.0246	0.070	1.41	4.26	Y
27	0.023	0.0237	0.074	1.41	4.27	Y
28	0.023	0.0233	0.062	1.41	4.28	Y
29						
30						
31						

Compliance summary (operator to complete any blank fields)

95% of daily turbidity readings ≤ 1 NTU? [Y/N]	All turbidity readings ≤ 5 NTU? [Y/N]	All IFE turbidity readings ≤ 0.15 NTU? [Y/N]	Performance std met? [Y/N] (PDR ≤ PDR _{Max} , LRV ≥ LRC)	DIT Daily?
Yes	Yes	Yes	Yes	Yes
CT's met daily? (p. 2)	All Cl ₂ residual at EP ≥ 0.2 mg/L?	PDR ≤ PDR _{Max} ?	LRV _{ambient} ≥ LRC?	
Yes	Yes	Yes	Yes	

PRINTED NAME: **Jeremy Wolford** DATE: **3/4/2026**

SIGNATURE:  WT CERT #: **T-7231**

Notes: PHONE #: **541-679-6321**

OHA-DWS

Disinfection Monthly Operating Report

System Name: Green Area Water & Sanitary Authority

Feb 2026

PWS ID#: 41 - 00717

0.5

↩ Log
Inactivation
Required via
Disinfection

Plant ID : WTP - A

Day	Minimum Cl ₂ Residual at 1 st User (C) * [mg/L = ppm]	Contact Time (T) [minutes]	Actual CT C x T (Formula)	Temp [° C]	pH	Required CT (Formula)	CT Met? * [Yes / No] (Formula)	Peak Hourly Demand Flow [GPM]	Notes (e.g. "Plant Off")
1	1.319	14.5808	19.2	14.9	7.69	18.4	YES	1,156	13:00
2	1.184	14.5808	17.3	17.2	7.93	17.0	YES	1,156	18:00
3	1.202	14.7885	17.8	18.2	7.79	15.1	YES	1,139	17:00
4	1.520	14.3789	21.9	15.8	7.98	19.7	YES	1,172	2:00
5	1.580	14.5808	23.0	13.1	7.83	22.4	YES	1,156	20:00
6	1.547	14.5808	22.6	16.5	7.72	17.2	YES	1,156	19:00
7	1.524	14.5808	22.2	16.1	7.55	16.4	YES	1,156	12:00
8	1.479	14.3789	21.3	16.8	7.42	14.9	YES	1,172	16:00
9	1.478	14.3789	21.3	20.6	7.09	10.2	YES	1,172	15:00
10	1.458	14.7885	21.6	18.4	7.33	12.9	YES	1,139	1:00
11	1.457	14.5808	21.2	15.2	7.38	16.3	YES	1,156	12:00
12	1.528	14.7885	22.6	15.8	7.36	15.7	YES	1,139	19:00
13	1.424	14.5808	20.8	15.7	7.44	16.1	YES	1,156	14:00
14	1.559	14.5808	22.7	15.9	7.55	16.8	YES	1,156	23:00
15	1.694	14.5808	24.7	15.7	7.52	17.0	YES	1,156	2:00
16	1.671	14.5808	24.4	15.9	7.53	16.8	YES	1,156	15:00
17	1.333	14.5808	19.4	16.8	7.60	15.7	YES	1,156	10:00
18	1.506	14.5808	22.0	16.9	7.61	15.9	YES	1,156	12:00
19	1.587	15.0022	23.8	17.1	7.77	16.8	YES	1,123	21:00
20	1.535	15.2221	23.4	15.8	7.68	17.6	YES	1,107	15:00
21	1.587	14.3789	22.8	16.5	7.65	16.8	YES	1,172	12:00
22	1.598	14.5808	23.3	16.2	7.79	18.0	YES	1,156	22:00
23	1.719	14.3789	24.7	16.8	7.70	17.0	YES	1,172	1:00
24	1.478	14.5808	21.6	16.4	7.06	13.4	YES	1,156	10:00
25	1.587	14.3789	22.8	16.8	7.07	13.3	YES	1,172	0:00
26	1.819	14.3789	26.2	15.7	7.19	15.3	YES	1,172	23:00
27	1.874	14.3789	26.9	14.8	6.93	14.9	YES	1,172	10:00
28	1.985	14.1825	28.2	11.3	7.25	21.6	YES	1,188	16:00
29									
30									
31									

* If chlorine concentration at entry point < 0.2 mg/L, or CT not met, notify DWS within 24 hours.

Submit this monthly report by the 10th of following month by

mail: Drinking Water Services
PO Box 14350
Portland, OR 97293-0350
email: dwp.dmce@odhsoha.oregon.gov
fax: 971-673-0458

p. 2 of 2

Oregon DHS - Drinking Water Program – Surface Water Quality Data

System Name: GAUSA


PWS ID#: 41 00717 Month/Year: 2/2026

Minimum UVT [%] during month: 92.9%

Duty sensor variation from reference sensor: 5.9%

Minimum Validated UVT : ~~92.9~~ [Insert Req'd Value]

Date	Peak Hourly Demand Flow	Minimum Intensity	All Lamps On?	Daily Water Produced {A}	Water outside Validated Conditions {B}	Cumulative % Off-Spec Water Produced
	[gpm]	[^{mW} /cm ²]	[Y or N]	[gal]	[gal]	(Mo. Sum {B}) ÷ (Mo. Sum {A}) * 100 [%]
1	2900	19.7	Y	938,922	0	0
2	2900	20.2	Y	1,197,424	0	0
3	2900	13.0	Y	925,833	0	0
4	2900	20.7	Y	1,064,405	0	0
5	2900	20.4	Y	1,153,074	0	0
6	2900	12.9	Y	1,163,099	0	0
7	2900	15.7	Y	928,894	0	0
8	2900	13.3	Y	959,556	0	0
9	2900	12.6	Y	1,066,400	0	0
10	2900	11.8	Y	1,032,941	0	0
11	2900	13.0	Y	1,031,676	0	0
12	2900	14.3	Y	1,097,428	0	0
13	2900	14.4	Y	923,744	0	0
14	2900	19.9	Y	963,681	0	0
15	2900	18.5	Y	992,773	0	0
16	2900	14.4	Y	1,080,265	0	0
17	2900	16.9	Y	1,111,567	0	0
18	2900	13.9	Y	979,271	0	0
19	2900	14.2	Y	1,004,442	0	0
20	2900	14.6	Y	982,949	0	0
21	2900	13.8	Y	1,015,334	0	0
22	2900	14.5	Y	1,075,067	0	0
23	2900	14.2	Y	943,821	0	0
24	2900	13.9	Y	1,049,791	0	0
25	2900	13.0	Y	1,041,649	0	0
26	2900	13.5	Y	1,108,534	0	0
27	2900	13.2	Y	964,595	0	0
28	2900	13.8	Y	955,280	0	0
29						
30						
31						
Monthly Cumulative % Off-Spec Water Produced						0

Signature: 

Op Cert #: T-7231 Date: 3/4/26