

OHA - Drinking Water Services -Turbidity Monitoring Report Form

Conventional or Direct Filtration

County:	Douglas
Month/Year:	Sep-22

System Name:		City of Roseburg		ID#: 41-00720			WTP : TP - A	
Day		12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the Day ¹ [NTU]
1		0.03	0.03	0.03	0.03	0.03	0.03	0.03
2		0.03	0.03	0.03	0.03	0.03	0.03	0.03
3		0.03	0.03	0.03	0.03	0.03	0.03	0.03
4		0.03	0.03	0.03	0.03	0.03	0.03	0.03
5		0.03	0.03	0.03	0.03	0.03	0.03	0.03
6		0.03	0.03	0.03	0.03	0.03	0.03	0.03
7		0.03	0.03	0.03	0.03	0.03	0.03	0.03
8		0.03	0.03	0.03	0.03	0.03	0.03	0.03
9		0.03	0.03	0.03	0.03	0.03	0.03	0.03
10		0.03	0.03	0.03	0.03	0.03	0.03	0.03
11		0.03	0.03	0.03	0.03	0.03	0.03	0.03
12		0.03	0.03	0.03	0.03	0.03	0.03	0.03
13		0.03	0.03	0.03	0.03	0.03	0.03	0.03
14		0.03	0.03	0.03	0.03	0.03	0.03	0.03
15		0.03	0.03	0.03	0.03	0.03	0.03	0.03
16		0.03	0.03	0.03	0.03	0.03	0.03	0.03
17		0.03	0.03	0.03	0.03	0.03	0.03	0.03
18		0.03	0.03	0.03	0.03	0.03	0.03	0.03
19		0.03	0.03	0.03	0.03	0.03	0.03	0.03
20		0.03	0.03	0.03	0.03	0.03	0.03	0.03
21		0.03	0.03	0.03	0.03	0.03	0.03	0.03
22		0.03	0.03	0.03	0.03	0.03	0.03	0.03
23		0.03	0.05	0.03	0.03	0.03	0.03	0.05
24		0.03	0.03	0.03	0.03	0.03	0.03	0.04
25		0.03	0.04	0.03	0.03	0.03	0.03	0.04
26		0.03	0.04	0.03	0.03	0.03	0.03	0.04
27		0.03	0.03	0.03	0.03	0.03	0.03	0.04
28		0.03	0.03	0.03	0.03	0.03	0.03	0.03
29		0.03	0.03	0.03	0.03	0.03	0.03	0.03
30		0.03	0.03	0.03	0.03	0.03	0.03	0.03
31								
Conventional or Direct Filtration					Monthly Summary (Answer Yes or No)			
95% of 4-hour turbidity readings \leq 0.3 NTU? <input checked="" type="checkbox"/> Yes / <input type="checkbox"/> No					CT's met everyday? (see back) <input checked="" type="checkbox"/> Yes / <input type="checkbox"/> No		All Cl2 residual at entry point \geq 0.2 mg/l? <input checked="" type="checkbox"/> Yes / <input type="checkbox"/> No	
All 4-hour turbidity readings \leq 1 NTU? <input checked="" type="checkbox"/> Yes / <input type="checkbox"/> No								
All turbidity readings < IFE ² triggers <input checked="" type="checkbox"/> Yes / <input type="checkbox"/> No								
Notes:					PRINTED NAME: Andrew Albee			
					SIGNATURE: Andrew Albee		DATE: 10/3/2022	
					PHONE #: (541) 492-7032		CERT #: 5221	

¹ Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in columns 12 AM through 8 PM may not correspond to continuous readings' maximum. ² IFE = Individ. Filter Efl. (333-061-0040(1)(e)(B&C))

OHA - Drinking Water Program - Surface Water Quality Data Form

WTP - :

System Name:	City of Roseburg	ID#: 41-00720	Month/Year:	Sep-22	Disinfection Giardia Log Inactiv:	0.5
--------------	------------------	---------------	-------------	--------	-----------------------------------	-----

Date / Time	Minimum Cl ₂ Residual at 1st User (C) ³	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? ³	Peak Hourly Demand Flow
	[ppm or mg/L]	[minutes]	C X T	[° C]		formula	Yes / No	[GPM]
1	1.17	67.5	79.0	20.6	7.92	13.4	Yes	6000
2	1.2	63.3	76.0	21.1	8.21	14.5	Yes	6400
3	1.18	70.5	83.2	20.6	8.32	15.6	Yes	5750
4	1.18	73.7	86.9	20.6	8.26	15.3	Yes	5500
5	1.17	73.7	86.2	20.6	8.13	14.5	Yes	5500
6	1.17	63.3	74.1	20.0	8.14	15.2	Yes	6400
7	1.15	63.3	72.8	20.0	8.21	15.5	Yes	6400
8	1.19	68.7	81.7	20.0	8.20	15.6	Yes	5900
9	1.09	63.0	68.7	18.9	8.10	15.9	Yes	6500
10	1.13	69.4	78.4	18.9	8.20	16.6	yes	5900
11	1.14	65.5	74.7	19.4	8.28	16.6	yes	6250
12	1.13	67.3	76.0	18.3	8.14	16.9	yes	5900
13	1.15	65.5	75.3	18.9	8.35	17.6	yes	6250
14	1.11	64.2	71.2	18.3	8.22	17.4	yes	6250
15	1.12	72.2	80.8	18.3	8.13	16.8	Yes	5500
16	1.13	67.5	76.3	17.2	8.30	19.3	Yes	6000
17	1.02	65.4	66.8	16.7	8.14	18.6	Yes	6000
18	1.02	82.7	84.3	16.1	8.10	19.1	Yes	4800
19	1.1	77.9	85.7	15.6	8.19	20.6	Yes	5200
20	1.15	89.1	102.5	16.1	8.16	19.8	Yes	4500
21	1.14	73.7	84.0	16.1	7.98	18.5	Yes	5500
22	1.13	79.4	89.7	16.1	7.86	17.7	yes	5000
23	1.11	77.7	86.3	16.1	8.07	19.0	yes	5000
24	1.08	81.9	88.4	16.7	8.21	19.2	Yes	5000
25	1.08	80.2	86.6	16.7	8.04	18.0	Yes	5000
26	1.13	67.5	76.3	16.7	8.20	19.2	Yes	6000
27	1.19	80.2	95.4	17.2	8.20	18.7	Yes	5000
28	1.15	79.4	91.3	17.2	8.18	18.5	Yes	5000
29	1.17	81.8	95.7	16.7	8.13	18.8	Yes	4800
30	1.15	98.2	112.9	16.7	8.06	18.3	Yes	4000
31		#DIV/0!						

³ If Cl₂ at entry point < 0.2 mg/l or CT not met, notify DWS within 24 hours.

Revised October 2013