

OHA - Drinking Water Services -Turbidity Monitoring Report Form

County: Douglas

Conventional or Direct Filtration

Month/Year: Aug-24

System Name: City of Roseburg ID#: 41-00720 WTP : TP - A

Day	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the Day ¹ [NTU]
1	0.03	0.03	0.03	0.03	0.03	0.03	0.03
2	0.03	0.03	0.03	0.03	0.03	0.03	0.03
3	0.03	0.03	0.03	0.03	0.03	0.03	0.03
4	0.03	0.03	0.00	0.03	0.03	0.03	0.03
5	0.03	0.03	0.03	0.03	0.03	0.03	0.03
6	0.03	0.03	0.03	0.03	0.03	0.03	0.03
7	0.03	0.03	0.03	0.03	0.03	0.03	0.03
8	0.03	0.03	0.03	0.03	0.03	0.03	0.03
9	0.03	0.03	0.03	0.03	0.03	0.03	0.03
10	0.03	0.03	0.03	0.03	0.03	0.03	0.03
11	0.03	0.03	0.03	0.00	0.03	0.03	0.03
12	0.03	0.03	0.03	0.03	0.03	0.03	0.03
13	0.03	0.03	0.03	0.03	0.03	0.03	0.03
14	0.00	0.00	0.03	0.03	0.03	0.03	0.03
15	0.03	0.03	0.03	0.03	0.03	0.03	0.03
16	0.03	0.03	0.03	0.03	0.03	0.03	0.03
17	0.03	0.03	0.03	0.03	0.03	0.03	0.03
18	0.03	0.03	0.03	0.03	0.03	0.03	0.03
19	0.03	0.03	0.03	0.03	0.03	0.03	0.03
20	0.03	0.03	0.03	0.03	0.03	0.03	0.03
21	0.03	0.03	0.03	0.03	0.03	0.03	0.03
22	0.03	0.03	0.03	0.03	0.03	0.03	0.03
23	0.03	0.03	0.03	0.03	0.03	0.03	0.03
24	0.03	0.03	0.03	0.03	0.03	0.03	0.03
25	0.03	0.03	0.03	0.03	0.03	0.03	0.03
26	0.03	0.03	0.03	0.03	0.03	0.03	0.03
27	0.03	0.03	0.03	0.03	0.03	0.03	0.03
28	0.03	0.03	0.03	0.03	0.03	0.03	0.03
29	0.03	0.03	0.03	0.03	0.03	0.03	0.03
30	0.03	0.03	0.03	0.03	0.03	0.03	0.03
31	0.03	0.03	0.03	0.03	0.03	0.03	0.03

Conventional or Direct Filtration		Monthly Summary (Answer Yes or No)	
95% of 4-hour turbidity readings ≤ 0.3 NTU?	Yes / No	CT's met everyday? (see back)	All Cl2 residual at entry point ≥ 0.2 mg/l?
All 4-hour turbidity readings ≤ 1 NTU?	Yes / No	Yes / No	Yes / No
All turbidity readings < IFE ² triggers	Yes / No		
Notes:	PRINTED NAME: Andrew Albee		
	SIGNATURE: Andrew Albee		DATE: 9/1/2024
	PHONE #: (541) 492-7032		CERT #: 5221

¹ Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in columns 12 AM through 8 PM may not correspond to continuous readings' maximum. ² IFE = Individ. Filter Effl. (333-061-0040(1)(e)(B&C))

OHA - Drinking Water Program - Surface Water Quality Data Form

WTP - :

System Name:	City of Roseburg	ID#: 41-00720	Month/Year:	Aug-22	Disinfection <i>Giardia</i> Log Inactiv:	0.5
--------------	------------------	---------------	-------------	--------	--	-----

Date / Time	Minimum Cl ₂ Residual at 1st User (C) ³	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? ³	Peak Hourly Demand Flow
	[ppm or mg/L]	[minutes]	C X T	[° C]		formula	Yes / No	[GPM]
1	1.1	59.6	65.6	22.2	7.80	11.4	Yes	6800
2	1.09	65.4	71.2	22.8	8.09	12.2	Yes	6200
3	1.11	59.6	66.1	22.8	8.16	12.6	Yes	6800
4	1.09	58.4	63.6	22.8	8.15	12.5	Yes	6800
5	1.1	63.3	69.6	22.8	8.15	12.5	Yes	6400
6	1.11	66.8	74.2	21.7	8.04	13.0	Yes	6000
7	1.12	61.7	69.1	22.2	8.10	12.8	Yes	6500
8	1.1	61.1	67.2	21.7	8.18	13.6	Yes	6500
9	1.12	62.3	69.8	21.7	7.90	12.3	Yes	6500
10	1.1	63.0	69.3	22.2	8.04	12.5	Yes	6500
11	1.09	63.0	68.7	22.2	7.88	11.8	Yes	6500
12	1.16	62.3	72.3	21.7	7.99	12.8	Yes	6500
13	1.18	62.3	73.6	20.6	7.81	12.9	Yes	6500
14	1.17	63.0	73.7	20.6	8.30	15.5	Yes	6500
15	1.16	64.6	75.0	21.1	8.28	14.8	Yes	6400
16	1.15	62.3	71.7	21.1	8.03	13.5	Yes	6500
17	1.16	66.8	77.5	20.6	7.92	13.4	Yes	6000
18	1.15	69.1	79.5	20.0	7.81	13.4	Yes	5800
19	1.12	69.1	77.4	20.0	8.13	15.0	Yes	5800
20	1.1	72.9	80.2	20.0	8.10	14.8	Yes	5500
21	1.1	61.1	67.2	20.0	8.12	14.9	Yes	6500
22	1.04	67.5	70.2	20.6	8.24	14.9	yes	6000
23	1.23	66.1	81.4	18.9	8.38	18.0	yes	6000
24	1.25	75.2	94.0	18.3	8.48	19.4	Yes	5000
25	1.27	69.9	88.7	18.3	8.51	19.7	Yes	5500
26	1.26	73.7	92.8	18.9	8.26	17.3	Yes	5500
27	1.25	68.2	85.3	19.4	8.25	16.6	Yes	6000
28	1.22	69.4	84.7	18.9	7.88	14.9	yes	5900
29	1.22	58.4	71.2	18.9	8.25	17.1	Yes	6800
30	1.2	61.1	73.3	20.0	8.10	15.0	Yes	6500
31	1.18	67.9	80.2	20.6	8.10	14.4	Yes	5750

³ If Cl₂ at entry point < 0.2 mg/l or CT not met, notify DWS within 24 hours.

Revised October 2013