

OHA - Drinking Water Services -Turbidity Monitoring Report Form

County: Douglas

Conventional or Direct Filtration

Month/Year: Jul-25

System Name:		City of Roseburg		ID#: 41-00720		WTP : TP - A	
Day	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the Day ¹ [NTU]
1	0.03	0.03	0.03	0.03	0.04	0.04	0.04
2	0.04	0.04	0.04	0.04	0.03	0.03	0.04
3	0.03	0.04	0.04	0.04	0.03	0.03	0.04
4	0.03	0.03	0.03	0.03	0.03	0.03	0.04
5	0.03	0.04	0.03	0.03	0.03	0.03	0.04
6	0.04	0.04	0.03	0.03	0.03	0.03	0.04
7	0.04	0.03	0.03	0.03	0.03	0.04	0.04
8	0.04	0.04	0.03	0.03	0.04	0.03	0.04
9	0.04	0.04	0.03	0.03	0.03	0.03	0.04
10	0.04	0.04	0.04	0.03	0.03	0.03	0.04
11	0.04	0.03	0.03	0.03	0.03	0.03	0.04
12	0.03	0.04	0.03	0.03	0.04	0.04	0.04
13	0.04	0.04	0.04	0.03	0.04	0.04	0.04
14	0.04	0.04	0.04	0.04	0.04	0.03	0.04
15	0.03	0.03	0.03	0.03	0.03	0.03	0.03
16	0.03	0.03	0.03	0.03	0.03	0.03	0.03
17	0.03	0.03	0.03	0.04	0.04	0.04	0.04
18	0.04	0.04	0.04	0.04	0.04	0.04	0.04
19	0.04	0.04	0.04	0.03	0.03	0.04	0.04
20	0.04	0.04	0.03	0.04	0.03	0.04	0.04
21	0.04	0.03	0.04	0.03	0.03	0.04	0.04
22	0.04	0.04	0.03	0.03	0.03	0.04	0.04
23	0.04	0.04	0.03	0.04	0.04	0.04	0.04
24	0.04	0.04	0.03	0.04	0.04	0.05	0.05
25	0.05	0.04	0.04	0.05	0.04	0.04	0.05
26	0.04	0.04	0.04	0.04	0.04	0.04	0.04
27	0.04	0.04	0.04	0.04	0.04	0.04	0.04
28	0.04	0.04	0.04	0.04	0.04	0.05	0.07
29	0.07	0.05	0.03	0.04	0.04	0.04	0.08
30	0.04	0.04	0.04	0.04	0.04	0.04	0.04
31	0.04	0.04	0.03	0.04	0.04	0.04	0.05

Conventional or Direct Filtration		Monthly Summary (Answer Yes or No)	
95% of 4-hour turbidity readings $\leq$ 0.3 NTU?	Yes / No	CT's met everyday? (see back)	All Cl ₂ residual at entry point $\geq$ 0.2 mg/l?
All 4-hour turbidity readings $\leq$ 1 NTU?	Yes / No	Yes / No	Yes / No
All turbidity readings < IFE ² triggers	Yes / No		
Notes:		PRINTED NAME: Andrew Albee	
		SIGNATURE: Andrew Albee	DATE: 8/1/25
		PHONE #: (541) 492-7032	CERT #: 5221

¹ Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in columns 12 AM through 8 PM may not correspond to continuous readings' maximum. ² IFE = Indiv. Filter Effl. (333-061-0040(1)(d)(B&C))

OHA - Drinking Water Program - Surface Water Quality Data Form

WTP - :

System Name:	City of Roseburg	ID#: 41-00720	Month/Year:	Jul-25	Disinfection <i>Giardia</i> Log Inactive:	0.5
---------------------	-------------------------	----------------------	--------------------	---------------	--	------------

Date / Time	Minimum Cl ₂ Residual at 1st User (C) ³	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? ³	Peak Hourly Demand Flow
	[ppm or mg/L]	[minutes]	C X T	[° C]		formula	Yes / No	[GPM]
1	1.06	60.1	63.7	22.8	7.77	10.8	YES	6600
2	1.05	64.0	67.2	23.3	8.05	11.6	YES	6200
3	1.08	60.5	65.4	21.7	8.43	14.9	YES	6500
4	1.12	65.5	73.4	20.0	8.31	16.1	YES	6000
5	1.11	63.5	70.5	20.0	8.41	16.7	YES	6250
6	1.1	63.5	69.8	20.6	8.42	16.0	YES	6250
7	1.13	66.1	74.7	21.7	8.46	15.2	YES	6000
8	1.11	63.5	70.5	22.2	8.46	14.7	YES	6250
9	1.1	64.2	70.6	22.2	8.52	15.0	YES	6250
10	1.07	62.8	67.2	22.2	8.20	13.2	YES	6250
11	1.11	59.2	65.8	22.2	8.04	12.5	YES	6700
12	1.09	65.4	71.3	22.8	8.17	12.6	YES	6000
13	1.08	63.5	68.6	23.9	8.30	12.3	YES	6250
14	1.1	63.5	69.8	23.9	8.31	12.4	YES	6250
15	1.12	63.5	71.1	23.3	8.32	12.9	YES	6250
16	1.13	60.8	68.7	23.3	8.29	12.8	YES	6600
17	1.09	59.5	64.9	23.3	8.43	13.4	YES	6600
18	1.1	59.2	65.2	23.3	8.37	13.2	YES	6700
19	1.08	65.4	70.7	22.8	8.33	13.4	YES	6000
20	1.07	62.8	67.2	22.2	8.28	13.6	YES	6250
21	1.09	63.3	69.0	21.7	8.22	13.8	YES	6250
22	1.11	67.5	74.9	21.1	8.21	14.4	YES	5800
23	1.05	55.7	58.5	21.7	8.67	16.3	YES	6500
24	1.06	57.7	61.2	22.2	8.54	15.0	YES	6950
25	1.06	57.1	60.5	22.8	8.51	14.3	YES	6950
26	1.07	60.1	64.3	22.2	8.41	14.3	YES	6600
27	1.07	66.1	70.8	22.2	8.44	14.5	YES	6000
28	1.08	60.1	64.9	22.2	8.36	14.1	YES	6600
29	1.11	60.8	67.4	22.2	8.47	14.7	YES	6600
30	1.11	60.8	67.4	22.8	8.54	14.5	YES	6600
31	1.08	60.4	65.2	22.2	8.42	14.4	YES	6500

³ If Cl₂ at entry point < 0.2 mg/l or CT not met, notify DWS within 24 hours.

Revised November 2022

Return by 10th of following month by email, fax, or mail to:

dwp.dmce@oha.oregon.gov; 971-673-0694; or Drinking Water Services, PO Box 14350, Portland, OR 97293-0350