

OHA - Drinking Water Services -Turbidity Monitoring Report Form

County: Douglas

Conventional or Direct Filtration

Month/Year: Aug-25

System Name:		City of Roseburg		ID#: 41-00720		WTP : TP - A	
Day	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the Day ¹ [NTU]
1	0.04	0.04	0.04	0.04	0.04	0.04	0.05
2	0.04	0.04	0.04	0.04	0.03	0.03	0.04
3	0.04	0.04	0.04	0.04	0.03	0.03	0.04
4	0.04	0.04	0.04	0.04	0.03	0.03	0.04
5	0.04	0.04	0.04	0.04	0.03	0.03	0.04
6	0.04	0.04	0.04	0.04	0.03	0.03	0.04
7	0.04	0.04	0.04	0.04	0.03	0.04	0.04
8	0.04	0.04	0.04	0.04	0.03	0.04	0.04
9	0.04	0.04	0.04	0.03	0.04	0.04	0.04
10	0.04	0.04	0.04	0.04	0.04	0.04	0.04
11	0.04	0.04	0.04	0.04	0.04	0.04	0.04
12	0.04	0.04	0.04	0.04	0.04	0.04	0.04
13	0.04	0.04	0.03	0.03	0.03	0.03	0.04
14	0.04	0.04	0.04	0.03	0.04	0.03	0.04
15	0.04	0.04	0.04	0.03	0.04	0.03	0.04
16	0.04	0.04	0.04	0.04	0.04	0.03	0.04
17	0.04	0.03	0.03	0.03	0.03	0.03	0.04
18	0.04	0.04	0.04	0.03	0.03	0.03	0.05
19	0.04	0.04	0.03	0.04	0.03	0.04	0.04
20	0.04	0.04	0.03	0.04	0.04	0.04	0.04
21	0.04	0.04	0.03	0.03	0.04	0.04	0.04
22	0.04	0.04	0.04	0.04	0.04	0.04	0.04
23	0.04	0.04	0.03	0.04	0.04	0.04	0.04
24	0.04	0.04	0.04	0.04	0.04	0.04	0.04
25	0.04	0.04	0.04	0.04	0.04	0.04	0.04
26	0.04	0.04	0.04	0.04	0.04	0.04	0.04
27	0.04	0.04	0.04	0.04	0.04	0.04	0.04
28	0.04	0.04	0.04	0.04	0.04	0.04	0.04
29	0.04	0.04	0.04	0.04	0.04	0.04	0.04
30	0.04	0.04	0.04	0.04	0.04	0.04	0.04
31	0.04	0.04	0.04	0.04	0.04	0.04	0.04

Conventional or Direct Filtration 95% of 4-hour turbidity readings ≤ 0.3 NTU? Yes / No All 4-hour turbidity readings ≤ 1 NTU? Yes / No All turbidity readings < IFE² triggers Yes / No		Monthly Summary (Answer Yes or No) CT's met everyday? (see back) Yes / No All Cl2 residual at entry point ≥ 0.2 mg/l? Yes / No	
Notes:		PRINTED NAME: Andrew Albee SIGNATURE: Andrew Albee 9/2/2025 PHONE #: (541) 492-7032 CERT #: 5221	

¹ Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in columns 12 AM through 8 PM may not correspond to continuous readings' maximum. ² IFE = Indiv. Filter Effl. (333-061-0040(1)(d)(B&C))

OHA - Drinking Water Program - Surface Water Quality Data Form

WTP - :

System Name:	City of Roseburg	ID#: 41-00720	Month/Year:	Aug-25	Disinfection <i>Giardia</i> Log Inactive:	0.5
---------------------	-------------------------	----------------------	--------------------	---------------	--	------------

Date / Time	Minimum Cl ₂ Residual at 1st User (C) ³	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? ³	Peak Hourly Demand Flow
	[ppm or mg/L]	[minutes]	C X T	[° C]		formula	Yes / No	[GPM]
1	1.08	60.5	65.4	22.8	8.45	14.0	YES	6500
2	1.07	66.1	70.8	22.8	8.45	14.0	YES	6000
3	1.06	69.7	73.9	22.2	8.61	15.4	YES	5750
4	1.08	63.5	68.6	21.7	8.37	14.6	YES	6250
5	1.08	69.7	75.3	21.1	8.64	16.8	YES	5750
6	1.09	63.7	69.4	21.7	8.41	14.8	YES	6300
7	1.1	70.4	77.4	21.7	8.41	14.9	YES	5700
8	1.04	60.8	63.2	21.1	8.63	16.7	YES	6600
9	1.08	59.5	64.3	21.7	8.67	16.3	YES	6600
10	1.08	60.8	65.6	22.2	8.59	15.3	YES	6600
11	1.07	60.1	64.3	22.8	8.60	14.8	YES	6600
12	1.09	56.7	61.8	23.3	8.51	13.8	YES	7000
13	1.05	54.5	57.3	23.3	8.27	12.6	YES	7200
14	1.03	66.8	68.8	22.8	8.22	12.8	YES	6000
15	1.08	66.8	72.2	22.8	8.22	12.8	YES	6000
16	1.17	69.0	80.8	22.2	8.11	13.0	YES	5750
17	1.17	71.4	83.5	21.1	7.92	13.0	YES	5500
18	1.12	64.7	72.4	21.1	8.17	14.2	YES	6000
19	1.2	68.6	82.3	20.6	8.24	15.2	YES	5750
20	1.2	68.9	82.7	21.1	8.25	14.7	YES	5750
21	1.18	60.8	71.7	21.7	8.22	14.0	YES	6600
22	1.19	60.8	72.3	21.7	8.55	15.8	YES	6600
23	1.19	64.2	76.4	22.2	8.44	14.7	YES	6250
24	1.17	60.8	71.1	22.8	8.18	12.8	YES	6600
25	1.12	63.5	71.1	22.8	8.39	13.7	YES	6250
26	1.17	61.4	71.8	22.8	8.41	13.9	YES	6600
27	1.2	64.8	77.8	22.8	8.44	14.1	YES	6250
28	1.16	65.9	76.5	22.2	8.43	14.6	YES	6000
29	1.16	65.9	76.4	21.7	8.45	15.2	YES	6000
30	1.16	77.2	89.5	21.1	8.40	15.5	YES	5250
31	1.15	69.0	79.4	21.1	8.44	15.7	YES	5750

³ If Cl₂ at entry point < 0.2 mg/l or CT not met, notify DWS within 24 hours.

Revised November 2022

Return by 10th of following month by email, fax, or mail to:

dwp.dmce@oha.oregon.gov; 971-673-0694; or Drinking Water Services, PO Box 14350, Portland, OR 97293-0350

PAGE 2 of 2