

OHA - Drinking Water Services -Turbidity Monitoring Report Form
Conventional or Direct Filtration

County: Douglas
Month/Year: Oct-25

System Name:		City of Roseburg		ID#: 41-00720		WTP : TP - A	
Day	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the Day ¹ [NTU]
1	0.03	0.03	0.03	0.03	0.03	0.03	0.03
2	0.03	0.03	0.03	0.03	0.03	0.03	0.03
3	0.03	0.03	0.03	0.03	0.03	0.03	0.03
4	0.03	0.03	0.03	0.03	0.03	0.03	0.03
5	0.03	0.03	0.03	0.03	0.03	0.03	0.03
6	0.03	0.03	0.03	0.03	0.03	0.03	0.03
7	0.03	0.03	0.03	0.03	0.03	0.03	0.03
8	0.03	0.03	0.03	0.03	0.03	0.03	0.03
9	0.03	0.03	0.03	0.03	0.03	0.03	0.04
10	0.03	0.03	0.03	0.03	0.03	0.03	0.03
11	0.03	0.03	0.03	0.03	0.03	0.03	0.04
12	0.03	0.03	0.03	0.03	0.03	0.03	0.04
13	0.03	0.03	0.03	0.03	0.03	0.03	0.04
14	0.03	0.03	0.03	0.03	0.03	0.03	0.04
15	0.03	0.03	0.03	0.03	0.03	0.03	0.04
16	0.03	0.03	0.04	0.03	0.03	0.03	0.04
17	0.03	0.03	0.03	0.03	0.03	0.03	0.03
18	0.03	0.03	0.00	0.03	0.03	0.03	0.03
19	0.03	0.03	0.03	0.03	0.03	0.03	0.03
20	0.03	0.03	0.03	0.03	0.03	0.03	0.03
21	0.03	0.03	0.03	0.03	0.03	0.03	0.03
22	0.03	0.03	0.03	0.03	0.03	0.03	0.03
23	0.03	0.03	0.03	0.03	0.03	0.03	0.05
24	0.03	0.03	0.03	0.03	0.03	0.03	0.05
25	0.03	0.03	0.03	0.03	0.03	0.03	0.03
26	0.03	0.03	0.03	0.03	0.03	0.03	0.03
27	0.03	0.03	0.03	0.03	0.03	0.03	0.03
28	0.03	0.03	0.03	0.03	0.03	0.03	0.03
29	0.03	0.03	0.03	0.03	0.03	0.03	0.03
30	0.03	0.03	0.03	0.03	0.03	0.03	0.03
31	0.03	0.03	0.03	0.03	0.03	0.03	0.03

Conventional or Direct Filtration		Monthly Summary (Answer Yes or No)	
95% of 4-hour turbidity readings ≤0.3 NTU?	Yes / No	CT's met everyday? (see back)	All Cl2 residual at entry point ≥0.2 mg/l?
All 4-hour turbidity readings ≤1 NTU?	Yes / No	Yes / No	Yes / No
All turbidity readings < IFE ² triggers	Yes / No		

Notes:

PRINTED NAME: Andrew Albee

SIGNATURE: Andrew Albee

PHONE #: (541) 492-7032

11/5/2025

CERT #:5221

¹ Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in columns 12 AM through 8 PM may not correspond to continuous readings' maximum. ² IFE = Individ. Filter Efl. (333-061-0040(1)(d)(B&C))
PAGE 1 of 2

Date / Time	Minimum Cl ₂ Residual at 1st User (C) ³	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? ³	Peak Hourly Demand Flow
	[ppm or mg/L]	[minutes]	C X T	[° C]		formula	Yes / No	[GPM]
1	1.1	85.4	93.9	14.4	7.88	19.9	YES	4500
2	1.14	88.2	100.5	14.4	7.94	20.4	YES	4500
3	1.22	88.2	107.6	15.0	8.09	20.9	YES	4500
4	1.23	89.1	109.6	15.0	8.01	20.3	YES	4500
5	1.22	105.5	128.8	15.0	8.01	20.3	YES	3800
6	1.04	78.5	81.7	15.0	7.95	19.4	YES	5000
7	1.01	79.4	80.2	15.0	7.96	19.5	YES	5000
8	1.01	78.3	79.1	14.4	8.06	21.0	YES	4800
9	1.13	64.2	72.5	12.2	8.03	24.3	YES	6250
10	1.06	100.3	106.3	12.2	8.12	24.9	YES	4000
11	1.11	118.0	130.9	11.7	7.91	24.0	YES	3400
12	1.03	117.2	120.7	12.2	7.88	22.8	YES	3400
13	1.14	99.0	112.9	11.1	7.78	24.0	YES	4000
14	1.18	107.9	127.4	11.1	7.76	23.9	YES	3700
15	1.19	101.9	121.2	11.1	7.74	23.8	YES	3900
16	1.13	108.8	123.0	11.1	7.80	24.1	YES	3800
17	1.16	104.4	121.2	11.1	7.78	24.0	YES	3800
18	1.16	126.6	146.9	11.7	7.80	23.2	YES	3200
19	1.16	99.2	115.1	11.7	7.93	24.3	YES	4000
20	1.16	98.2	113.9	11.7	7.92	24.3	YES	4000
21	1.14	126.6	144.3	11.1	7.97	25.6	YES	3300
22	1.17	105.5	123.5	11.1	8.01	26.1	YES	3800
23	1.16	117.3	136.1	11.1	8.04	26.4	YES	3400
24	1.16	123.6	143.4	10.6	7.99	26.8	YES	3200
25	1.15	132.3	152.1	10.0	7.84	26.4	YES	3000
26	1.09	132.3	144.2	10.0	7.89	26.7	YES	3000
27	1	136.5	136.5	9.4	7.78	26.4	YES	3000
28	1.1	125.3	137.9	9.4	7.73	26.3	YES	3200
29	1.1	124.0	136.4	10.6	7.69	23.9	YES	3200
30	1.17	118.0	138.0	10.0	7.66	24.8	YES	3400
31	1.18	129.4	152.7	10.0	7.77	25.8	YES	3100