

OHA - Drinking Water Services -Turbidity Monitoring Report Form

County: Douglas

Conventional or Direct Filtration

Month/Year: Feb-26

System Name: City of Roseburg ID#: 41-00720 WTP : TP - A

Day	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the Day ¹ [NTU]
1	0.03	0.03	0.03	0.03	0.03	0.03	0.04
2	0.03	0.03	0.03	0.03	0.03	0.03	0.04
3	0.03	0.03	0.03	0.03	0.03	0.03	0.04
4	0.03	0.03	0.03	0.03	0.03	0.03	0.04
5	0.03	0.03	0.03	0.03	0.03	0.03	0.03
6	0.03	0.03	0.03	0.03	0.03	0.03	0.03
7	0.03	0.03	0.03	0.03	0.03	0.03	0.03
8	0.03	0.03	0.03	0.03	0.03	0.03	0.03
9	0.03	0.03	0.03	0.03	0.03	0.03	0.03
10	0.03	0.03	0.03	0.03	0.03	0.03	0.03
11	0.03	0.03	0.03	0.03	0.03	0.03	0.03
12	0.03	0.03	0.03	0.03	0.03	0.03	0.04
13	0.03	0.03	0.03	0.03	0.03	0.03	0.04
14	0.03	0.03	0.03	0.03	0.03	0.03	0.04
15	0.03	0.03	0.03	0.03	0.03	0.03	0.04
16	0.03	0.03	0.03	0.03	0.03	0.03	0.04
17	0.03	0.03	0.03	0.03	0.03	0.03	0.05
18	0.03	0.03	0.03	0.03	0.03	0.03	0.04
19	0.03	0.03	n/a	0.03	0.03	0.06	0.07
20	0.05	0.03	0.03	n/a	0.03	0.06	0.17
21	0.21	0.16	0.05	0.03	0.03	0.03	0.22
22	0.03	0.03	0.03	0.03	0.03	0.03	0.03
23	0.03	0.03	0.03	0.03	0.03	0.03	0.03
24	0.03	0.03	0.05	0.17	0.28	0.23	0.31
25	0.21	0.21	0.56	0.63	0.29	0.06	0.64
26	0.03	0.03	0.04	0.03	0.03	0.03	0.04
27	0.03	0.04	0.04	0.04	0.05	0.04	0.05
28	0.03	0.03	0.03	0.04	0.03	0.04	0.05
29							
30							
31							

Conventional or Direct Filtration	Monthly Summary (Answer Yes or No)	
95% of 4-hour turbidity readings ≤0.3 NTU? <input checked="" type="radio"/> Yes / <input type="radio"/> No	CT's met everyday? (see back) <input checked="" type="radio"/> Yes / <input type="radio"/> No	All Cl2 residual at entry point ≥0.2 mg/l? <input checked="" type="radio"/> Yes / <input type="radio"/> No
All 4-hour turbidity readings ≤1 NTU? <input checked="" type="radio"/> Yes / <input type="radio"/> No		
All turbidity readings < IFE ² triggers <input checked="" type="radio"/> Yes / <input type="radio"/> No		

Notes:	PRINTED NAME: Jason Anderson	
	SIGNATURE: <i>Jason Anderson</i>	DATE: 3/2/2026
	PHONE #: (541) 492-7032	CERT #:7030

¹ Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in columns 12 AM through 8 PM may not correspond to continuous readings' maximum. ² IFE = Individ. Filter Effl. (333-061-0040(1)(e)(B&C))

OHA - Drinking Water Program - Surface Water Quality Data Form

System Name: City of Roseburg				ID#: 41-00720	Month/Year: Feb-26	WTP - : Disinfection <i>Giardia</i> Log Inactiv: 0.5	
-------------------------------	--	--	--	---------------	--------------------	--	--

Date / Time	Minimum Cl ₂ Residual at 1st User (C) ³	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? ³	Peak Hourly Demand Flow
	[ppm or mg/L]	[minutes]	C X T	[° C]		formula	Yes / No	[GPM]
1	1.07	129.8	138.9	6.7	7.79	32.1	Yes	3000
2	0.99	131.6	130.3	6.7	7.73	31.1	Yes	3000
3	1.14	129.5	147.6	6.7	7.56	29.8	Yes	3000
4	1.13	129.6	146.5	7.2	7.60	29.2	Yes	3000
5	1.11	133.7	148.4	6.7	7.57	29.8	Yes	3000
6	1.06	133.7	141.7	6.7	7.60	29.9	Yes	3000
7	1.06	132.3	140.2	6.7	7.58	29.7	yes	3000
8	1	125.3	125.3	6.7	7.64	30.2	yes	3100
9	0.96	128.0	122.9	7.8	7.57	27.2	yes	3100
10	1.09	126.7	138.1	7.8	7.57	27.6	yes	3100
11	1.12	132.3	148.2	7.8	7.63	28.3	yes	3000
12	1.09	128.3	139.8	7.2	7.69	30.0	Yes	3100
13	1.12	128.3	143.7	7.2	7.75	30.8	Yes	3100
14	1.05	129.1	135.5	7.8	7.72	29.0	Yes	3000
15	1.15	129.4	148.8	8.3	7.72	28.3	Yes	3000
16	1.18	131.3	155.0	8.3	7.73	28.5	Yes	3000
17	1.23	98.1	120.6	7.2	7.73	30.9	Yes	4000
18	1.25	98.8	123.5	6.7	7.78	32.7	Yes	4000
19	1.22	99.2	121.0	6.7	7.77	32.4	yes	4000
20	1.24	110.2	136.7	6.1	7.79	34.1	yes	3600
21	1.17	110.2	129.0	6.7	7.78	32.4	Yes	3600
22	1.17	133.7	156.4	6.7	7.79	32.5	Yes	3000
23	1.1	130.9	144.0	7.2	7.71	30.2	Yes	3000
24	0.9	128.1	115.3	8.3	7.71	27.4	No	3000
25	1.06	116.5	123.5	8.9	7.63	26.1	Yes	3300
26	1.24	105.8	131.2	8.3	7.61	27.5	Yes	3700
27	1.23	98.5	121.1	8.3	7.66	28.0	Yes	4000
28	1.17	112.9	132.1	7.8	7.30	25.3	Yes	3400
29		#DIV/0!						
30		#DIV/0!						
31		#DIV/0!						

³ If Cl₂ at entry point < 0.2 mg/l or CT not met, notify DWS within 24 hours.