

OHA - Drinking Water Services -Turbidity Monitoring Report Form

County: **Douglas**

Conventional or Direct Filtration

Month/Year: **Mar-26**

System Name: **City of Roseburg** ID#: **41-00720** WTP : TP - **A**

Day	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the Day ¹ [NTU]
1	0.03	0.03	0.03	0.03	0.03	0.04	0.05
2	0.03	0.04	0.03	0.03	0.04	0.05	0.06
3	0.04	0.03	0.03	0.03	0.03	0.04	0.06
4	0.03	0.03	0.03	0.03	0.03	0.03	0.05
5	0.03	0.03	0.03	0.03	0.03	0.03	0.04
6	0.03	0.03	0.03	0.03	0.03	0.04	0.04
7	0.04	0.03	0.03	0.03	0.03	0.04	0.04
8	0.03	0.03	0.03	0.03	0.03	0.03	0.03
9	0.03	0.03	0.03	0.03	0.03	0.03	0.03
10	0.03	0.03	0.03	0.03	0.03	0.03	0.03
11	0.03	0.03	0.03	0.03	0.03	0.03	0.03
12	0.03	0.03	0.03	0.03	0.03	0.03	0.06
13	0.03	0.03	0.03	0.03	0.03	0.03	0.05
14	0.03	0.03	0.03	0.03	0.03	0.03	0.03
15	0.03	0.03	0.03	0.03	0.03	0.03	0.03
16	0.03	0.03	0.03	0.03	0.03	0.03	0.04
17	0.03	0.03	0.03	0.03	0.03	0.03	0.03
18	0.03	0.03	0.03	0.03	0.03	0.03	0.03
19	0.03	0.03	0.03	0.03	0.03	0.03	0.03
20	0.03	0.03	0.03	0.03	0.03	0.03	0.03
21	0.03	0.03	0.03	0.03	0.03	0.03	0.03
22	0.03	0.03	0.03	0.03	0.03	0.03	0.03
23	0.03	0.03	0.03	0.03	0.03	0.03	0.03
24	0.03	0.03	0.03	0.03	0.03	0.03	0.03
25	0.03	0.03	0.03	0.03	0.03	0.03	0.03
26	0.03	0.03	0.03	0.03	0.03	0.03	0.03
27	0.03	0.03	0.03	0.03	0.03	0.03	0.03
28	0.03	0.03	0.03	0.03	0.03	0.03	0.03
29	0.03	0.03	0.03	0.03	0.03	0.03	0.03
30	0.03	0.03	0.03	0.03	0.03	0.03	0.03
31	0.03	0.03	0.03	0.03	0.03	0.03	0.03

Conventional or Direct Filtration

Monthly Summary (Answer Yes or No)

95% of 4-hour turbidity readings ≤ 0.3 NTU?

Yes / No

All 4-hour turbidity readings ≤ 1 NTU?

Yes / No

All turbidity readings $<$ IFE² triggers

Yes / No

CT's met everyday?
(see back)

Yes No

All Cl₂ residual at entry point
 ≥ 0.2 mg/l?

Yes / No

Notes:

PRINTED NAME: **Jason Anderson**

SIGNATURE: *Jason Anderson*

DATE: **4/1/26**

PHONE #: **(541) 492-7032**

CERT #: **7030**

¹ Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in columns 12 AM through 8 PM may not correspond to continuous readings' maximum. ² IFE = Individ. Filter Efl. (333-061-0040(1)(e)(B&C))

OHA - Drinking Water Program - Surface Water Quality Data Form

WTP - :

System Name:	City of Roseburg	ID#: 41-00720	Month/Year:	Mar-26	Disinfection <i>Giardia</i> Log Inactiv:	0.5
--------------	------------------	---------------	-------------	--------	--	-----

Date / Time	Minimum Cl ₂ Residual at 1st User (C) ³	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? ³	Peak Hourly Demand Flow
	[ppm or mg/L]	[minutes]	C X T	[° C]		formula	Yes / No	[GPM]
1	1.09	119.7	130.4	8.3	7.65	27.4	Yes	3250
2	1.01	118.0	119.2	8.9	7.61	25.7	Yes	3250
3	1.06	118.7	125.9	9.4	7.53	24.3	Yes	3300
4	1.18	118.0	139.2	9.4	7.73	26.5	Yes	3300
5	1.13	118.9	134.3	8.9	7.72	27.2	Yes	3300
6	1.17	117.1	137.0	8.3	7.62	27.4	Yes	3300
7	1.21	103.9	125.7	8.9	7.67	26.9	yes	3700
8	1.06	113.4	120.2	9.4	7.60	25.0	yes	3500
9	1.12	113.0	126.6	10.0	7.64	24.5	yes	3400
10	1.18	115.5	136.3	9.4	7.69	26.1	yes	3400
11	1.17	118.0	138.0	7.8	7.68	29.0	yes	3400
12	1.16	127.3	147.6	8.9	7.67	26.8	Yes	3000
13	1.16	121.0	140.4	9.4	7.72	26.3	Yes	3200
14	1.07	122.7	131.3	10.6	7.48	22.1	Yes	3200
15	1.08	129.5	139.9	9.4	7.70	25.9	Yes	3000
16	1.07	122.6	131.2	9.4	7.70	25.9	Yes	3100
17	1.23	121.4	149.3	10.0	7.60	24.4	Yes	3200
18	1.2	121.4	145.7	10.6	7.65	23.8	Yes	3200
19	1.2	111.0	133.2	11.1	7.63	22.9	yes	3500
20	1.15	112.2	129.0	12.8	7.64	20.3	Yes	3500
21	1.15	112.2	129.0	12.8	7.64	20.3	Yes	3500
22	1.15	122.7	141.1	12.2	7.59	20.9	Yes	3200
23	0.93	122.7	114.1	11.1	7.66	22.4	Yes	3200
24	0.92	111.0	102.1	11.1	7.50	21.2	Yes	3500
25	1.02	107.4	109.6	11.1	7.67	22.7	Yes	3500
26	1	120.2	120.2	10.6	7.74	24.0	Yes	3200
27	1.16	116.5	135.1	10.6	7.78	24.8	Yes	3300
28	1.16	129.6	150.4	11.1	7.76	23.9	Yes	3000
29	1.11	114.8	127.5	11.1	7.74	23.6	Yes	3300
30	1.23	96.8	119.1	11.1	7.79	24.3	Yes	4000
31	1.2	116.8	140.2	11.1	7.76	24.0	Yes	3300

³ If Cl₂ at entry point < 0.2 mg/l or CT not met, notify DWS within 24 hours.

Revised October 2013