

OHA - Drinking Water Services -Turbidity Monitoring Report Form

County: Douglas

Conventional or Direct Filtration

Month/Year: Feb-22

System Name: City of Roseburg ID#: 41-00720 WTP : TP - A

Day	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the Day <sup>1</sup> [NTU]
1	0.03	0.03	0.03	0.03	0.03	0.03	0.03
2	0.03	0.03	0.03	0.03	0.03	0.03	0.03
3	0.03	0.03	0.03	0.03	0.03	0.03	0.03
4	0.03	0.03	0.03	0.03	0.03	0.03	0.03
5	0.03	0.03	0.03	0.03	0.03	0.03	0.03
6	0.03	0.03	0.03	0.03	0.03	0.03	0.03
7	0.03	0.03	0.03	0.03	0.03	0.03	0.03
8	0.03	0.03	0.03	0.03	0.03	0.03	0.03
9	0.03	0.03	0.03	0.03	0.03	0.03	0.03
10	0.03	0.03	0.03	0.03	0.03	0.03	0.03
11	0.03	0.03	0.03	0.03	0.03	0.03	0.03
12	0.03	0.03	0.03	0.03	0.03	0.03	0.03
13	0.03	0.03	0.03	0.03	0.03	0.03	0.03
14	0.03	0.03	0.03	0.03	0.03	0.03	0.03
15	0.03	0.03	0.03	0.03	0.03	0.03	0.03
16	0.03	0.03	0.03	0.03	0.03	0.03	0.03
17	0.03	0.03	0.03	0.03	0.03	0.03	0.03
18	0.03	0.03	0.03	0.03	0.03	0.03	0.03
19	0.03	0.03	0.03	0.03	0.03	0.03	0.03
20	0.03	0.03	0.03	0.03	0.03	0.03	0.03
21	0.03	0.03	0.03	0.03	0.03	0.03	0.03
22	0.03	0.03	0.03	0.03	0.03	0.03	0.03
23	0.03	0.03	0.03	0.03	0.03	0.03	0.03
24	0.03	0.03	0.03	0.03	0.03	0.03	0.03
25	0.03	0.03	0.03	0.03	0.03	0.03	0.03
26	0.03	0.03	0.03	0.03	0.03	0.03	0.03
27	0.03	0.03	0.03	0.03	0.03	0.03	0.03
28	0.03	0.03	0.03	0.03	0.03	0.03	0.03
29							
30							
31							

<b>Conventional or Direct Filtration</b>		<b>Monthly Summary (Answer Yes or No)</b>	
95% of 4-hour turbidity readings ≤ 0.3 NTU?	<input checked="" type="radio"/> Yes / <input type="radio"/> No	CT's met everyday? (see back)	All Cl2 residual at entry point ≥ 0.2 mg/l?
All 4-hour turbidity readings ≤ 1 NTU?	<input checked="" type="radio"/> Yes / <input type="radio"/> No	<input checked="" type="radio"/> Yes / <input type="radio"/> No	<input checked="" type="radio"/> Yes / <input type="radio"/> No
All turbidity readings < IFE <sup>2</sup> triggers	<input checked="" type="radio"/> Yes / <input type="radio"/> No		
<b>Notes:</b>		<b>PRINTED NAME: Andrew Albee</b>	
		Signature: Andrew Albee	DATE: 3/2/2022
		PHONE #: (541) 492-7032	CERT #: 5221

<sup>1</sup> Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in columns 12 AM through 8 PM may not correspond to continuous readings' maximum. <sup>2</sup> IFE = Individ. Filter Effl. (333-061-0040(1)(e)(B&C))

OHA - Drinking Water Program - Surface Water Quality Data Form

WTP - :

System Name:	City of Roseburg	ID#: 41-00720	Month/Year:	Feb-22	Disinfection <i>Giardia</i> Log Inactiv:	0.5
--------------	------------------	---------------	-------------	--------	--	-----

Date / Time	Minimum Cl <sub>2</sub> Residual at 1st User ( C ) <sup>3</sup>	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? <sup>3</sup>	Peak Hourly Demand Flow
	[ppm or mg/L]	[minutes]	<b>C X T</b>	[° C]		formula	Yes / No	[GPM]
1	1.22	115.8	141.3	5.5	7.82	35.9	Yes	3500
2	1.21	148.5	179.7	5.0	7.69	35.3	Yes	2700
3	1.19	147.0	174.9	5.0	7.77	36.3	Yes	2700
4	1.14	144.3	164.5	4.4	7.77	37.6	Yes	2750
5	1.13	135.4	153.0	5.0	7.77	36.1	Yes	2900
6	1.12	138.3	154.9	5.0	7.76	35.9	Yes	2900
7	1.15	135.4	155.7	4.4	7.78	37.8	Yes	2900
8	1.18	145.4	171.6	4.4	7.74	37.4	Yes	2700
9	1.17	141.7	165.8	5.0	7.78	36.4	Yes	2800
10	1.17	143.2	167.6	5.6	7.81	35.3	yes	2800
11	1.18	133.7	157.7	5.6	7.68	33.7	yes	3000
12	1.13	174.4	197.0	6.1	7.77	33.4	Yes	2300
13	1.13	135.1	152.6	6.1	7.88	34.8	Yes	3000
14	1.13	135.1	152.6	6.1	7.71	32.7	Yes	3000
15	1.16	125.3	145.4	6.1	7.63	31.9	Yes	3200
16	1.21	125.3	151.6	6.7	7.72	31.8	Yes	3200
17	1.18	132.3	156.1	5.6	7.63	33.1	Yes	3000
18	1.17	145.8	170.6	5.6	7.76	34.6	Yes	2750
19	1.17	133.7	156.4	5.6	7.78	34.9	Yes	3000
20	1.12	141.7	158.7	6.1	7.78	33.5	Yes	2800
21	1.19	138.8	165.1	6.1	7.74	33.3	Yes	2800
22	1.23	144.3	177.5	5.6	7.71	34.2	Yes	2750
23	1.24	133.7	165.8	4.4	7.69	37.0	Yes	3000
24	1.25	130.9	163.6	3.9	7.66	37.9	yes	3000
25	1.25	138.3	172.9	2.8	7.63	40.4	yes	2900
26	1.22	130.9	159.7	3.3	7.58	38.2	Yes	3000
27	1.17	132.3	154.8	3.9	7.52	35.6	Yes	3000
28	1.18	135.1	159.4	5.6	7.60	32.7	Yes	3000
29		#DIV/0!						
30		#DIV/0!						
31		#DIV/0!						

<sup>3</sup> If Cl<sub>2</sub> at entry point < 0.2 mg/l or CT not met, notify DWS within 24 hours.

Revised October 2013