

OHA - Drinking Water Services -Turbidity Monitoring Report Form

County: Douglas

Conventional or Direct Filtration

Month/Year: Dec-22

System Name: City of Roseburg ID#: 41-00720 WTP : TP - A

Day	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the Day ¹ [NTU]
1	0.03	0.03	0.03	0.03	0.03	0.03	0.03
2	0.03	0.03	0.03	0.03	0.03	0.03	0.03
3	0.03	0.03	0.03	0.03	0.03	0.03	0.03
4	0.03	0.03	0.03	0.03	0.03	0.03	0.03
5	0.03	0.03	0.03	0.03	0.03	0.03	0.03
6	0.03	0.03	0.03	0.03	0.03	0.03	0.03
7	0.03	0.03	0.03	0.03	0.03	0.03	0.03
8	0.03	0.03	0.03	0.03	0.03	0.03	0.03
9	0.03	0.03	0.03	0.03	0.03	0.03	0.03
10	0.03	0.03	0.03	0.03	0.03	0.03	0.03
11	0.03	0.03	0.03	0.03	0.03	0.03	0.03
12	0.03	0.03	0.03	0.03	0.03	0.03	0.03
13	0.03	0.03	0.03	0.03	0.03	0.03	0.03
14	0.03	0.03	0.03	0.03	0.03	0.03	0.03
15	0.03	0.03	0.03	0.03	0.03	0.03	0.03
16	0.03	0.03	0.03	0.03	0.03	0.03	0.03
17	0.03	0.03	0.03	0.03	0.03	0.03	0.03
18	0.03	0.03	0.03	0.03	0.03	0.03	0.03
19	0.03	0.03	0.03	0.03	0.03	0.03	0.03
20	0.03	0.03	0.03	0.03	0.03	0.03	0.03
21	0.03	0.03	0.03	0.03	0.03	0.03	0.03
22	0.03	0.03	0.03	0.03	0.03	0.03	0.03
23	0.03	0.03	0.03	0.03	0.03	0.03	0.03
24	0.03	0.03	0.03	0.03	0.03	0.03	0.03
25	0.03	0.03	0.03	0.03	0.03	0.03	0.03
26	0.03	0.03	0.03	0.03	0.03	0.03	0.03
27	0.03	0.03	0.03	0.03	0.03	0.03	0.03
28	0.03	0.03	0.03	0.03	0.03	0.03	0.03
29	0.03	0.03	0.03	0.03	0.03	0.03	0.03
30	0.03	0.03	0.03	0.03	0.03	0.03	0.03
31	0.03	0.03	0.03	0.03	0.03	0.03	0.03

Conventional or Direct Filtration		Monthly Summary (Answer Yes or No)	
95% of 4-hour turbidity readings ≤ 0.3 NTU?	Yes / No	CT's met everyday? (see back)	All Cl2 residual at entry point ≥ 0.2 mg/l?
All 4-hour turbidity readings ≤ 1 NTU?	Yes / No	Yes / No	Yes / No
All turbidity readings < IFE ² triggers	Yes / No		
Notes:	PRINTED NAME: Andrew Albee		
	SIGNATURE: Andrew Albee		DATE:
	PHONE #: (541) 492-7032		CERT #: 5221

¹ Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in columns 12 AM through 8 PM may not correspond to continuous readings' maximum. ² IFE = Individ. Filter Effl. (333-061-0040(1)(e)(B&C))

OHA - Drinking Water Program - Surface Water Quality Data Form

WTP - :

System Name:	City of Roseburg	ID#: 41-00720	Month/Year:	Dec-22	Disinfection <i>Giardia</i> Log Inactiv:	0.5
--------------	------------------	---------------	-------------	--------	---	-----

Date / Time	Minimum Cl ₂ Residual at 1st User (C) ³	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? ³	Peak Hourly Demand Flow
	[ppm or mg/L]	[minutes]	C X T	[° C]		formula	Yes / No	[GPM]
1	1.12	129.4	144.9	6.7	7.64	30.6	Yes / No	3100
2	1.03	122.7	126.4	6.7	7.65	30.4	Yes / No	3200
3	1.07	124.0	132.7	6.1	7.71	32.5	Yes	3200
4	1.1	128.0	140.8	5.6	7.68	33.4	Yes	3100
5	1.15	114.6	131.8	6.1	7.77	33.5	Yes	3500
6	1.15	155.9	179.2	6.1	7.77	33.5	Yes	2600
7	1.16	151.0	175.2	6.1	7.81	34.0	Yes	2600
8	1.14	128.0	145.9	6.1	7.76	33.3	Yes	3100
9	1.16	144.3	167.4	5.6	7.77	34.7	Yes	2750
10	1.14	158.7	181.0	6.1	7.78	33.6	Yes	2500
11	1.12	138.8	155.4	6.7	7.76	31.9	Yes	2800
12	1.11	132.3	146.8	7.2	7.65	29.6	Yes	3000
13	1.09	132.3	144.2	6.7	7.66	30.7	Yes	3000
14	1.12	132.3	148.2	6.7	7.71	31.4	Yes	3000
15	1.12	129.5	145.0	6.1	7.81	33.9	yes	3000
16	1.14	125.3	142.9	5.0	7.79	36.4	yes	3100
17	1.11	128.0	142.1	4.4	7.82	38.2	Yes	3100
18	1.11	134.3	149.1	4.4	7.77	37.5	Yes	2800
19	1.15	122.7	141.1	3.9	7.78	39.1	Yes	3200
20	1.15	130.9	150.5	3.9	7.81	39.6	Yes	3000
21	1.17	143.2	167.6	4.4	7.81	38.3	Yes	2800
22	1.14	141.7	161.6	6.1	7.57	31.1	Yes	2800
23	1.13	119.0	134.5	6.1	7.61	31.5	Yes	3300
24	1.13	132.3	149.5	7.2	7.58	29.0	Yes	3000
25	1.08	140.2	151.5	8.3	7.60	26.9	Yes	2800
26	1.15	142.8	164.2	8.9	7.48	25.0	Yes	2750
27	1.13	144.3	163.1	9.4	7.54	24.6	Yes	2750
28	1.15	141.7	163.0	8.9	7.41	24.4	Yes	2800
29	1.17	141.7	165.8	8.9	7.55	25.7	yes	2800
30	1.15	130.9	150.5	8.9	7.40	24.3	yes	3000
31	1.15	133.7	153.7	9.4	7.50	24.3	Yes	3000

³ If Cl₂ at entry point < 0.2 mg/l or CT not met, notify DWS within 24 hours.

Revised October 2013