

OHA-Drinking Water Program- Surface Water Quality Form							County	Marion		
Salem Public Works		ID# OR4100731	WTP-A		Mo/Yr		February,2026			
DATE	Time 0000-2400	Minimum Cl2 Residual at first user (C) mg/L	Contact Time (T) Minutes	Actual CT C X T	Temp (Deg. C)	pH	Required CT	CT Met? Yes/No	Peak Hourly Demand Flow (MGD)	
1	31	0.99	533	528	7.7	7.5	60	Y	18.5	
2	2325	0.82	376	308	7.8	7.5	60	Y	26.3	
3	30	0.94	376	353	7.6	7.5	72	Y	26.3	
4	2347	1.09	395	430	7.8	7.4	61	Y	25.0	
5	30	1.05	395	414	8.8	7.6	74	Y	25.0	
6	2310	1.17	398	466	9.2	7.5	74	Y	24.8	
7	159	1.10	458	503	7.9	7.4	61	Y	21.6	
8	2359	1.21	461	558	7.8	7.4	62	Y	21.4	
9	2212	1.07	454	486	7.8	7.5	61	Y	21.7	
10	2009	1.03	451	465	8.0	7.4	61	Y	21.9	
11	259	1.07	451	482	8.0	7.5	61	Y	21.9	
12	2358	1.12	462	518	8.2	7.5	61	Y	21.3	
13	2228	1.08	460	497	7.8	7.5	61	Y	21.4	
14	231	1.04	571	594	8.1	7.4	61	Y	17.3	
15	427	1.09	575	627	7.9	7.4	61	Y	17.2	
16	447	1.15	481	553	7.8	7.4	61	Y	20.5	
17	2305	1.01	485	490	7.8	7.5	74	Y	20.4	
18	204	0.96	482	463	7.4	7.6	72	Y	20.5	
19	1723	1.04	482	501	7.8	7.5	61	Y	20.5	
20	104	1.12	480	538	7.4	7.5	74	Y	20.6	
21	1312	1.13	479	541	8.0	7.5	61	Y	20.6	
22	335	0.93	374	348	7.5	7.8	72	Y	26.4	
23	127	1.11	433	480	7.6	7.7	74	Y	22.8	
24	238	1.11	482	535	7.7	7.6	74	Y	20.5	
25	1656	1.34	483	647	8.6	7.4	62	Y	20.4	
26	2304	1.09	455	496	8.4	7.4	61	Y	21.7	
27	2127	0.89	466	415	8.5	7.5	60	Y	21.2	
28	16	0.96	466	447	8.6	7.5	60	Y	21.2	

* Site: Line 1 Alt. Flow Path Aldersgate CT sample point, 7790 Marion Rd. SE Turner, OR

Report Date: Mar 03, 2026

OHA-Drinking Water Program- Surface Water Quality Form							County	Marion		
Salem Public Works		ID# OR4100731	WTP-A		Mo/Yr		February,2026			
DATE	Time 0000-2400	Minimum Cl2 Residual at first user (C) mg/L	Contact Time (T) Minutes	Actual CT C X T	Temp (Deg. C)	pH	Required CT	CT Met? Yes/No	Peak Hourly Demand Flow (MGD)	
1	1006	1.14	781	890	7.6	7.7	74	Y	5.7	
2	1522	1.17	781	914	7.7	7.5	74	Y	5.7	
3	1100	1.09	856	933	7.7	7.8	74	Y	5.2	
4	852	1.25	768	960	7.8	7.6	76	Y	5.8	
5	1308	1.17	795	930	8.2	7.8	74	Y	5.6	
6	1326	1.15	809	931	8.7	7.8	74	Y	5.5	
7	1402	1.17	799	935	8.0	7.6	74	Y	5.6	
8	1638	1.15	795	914	8.2	7.5	61	Y	5.6	
9	2019	1.11	795	882	8.0	7.5	74	Y	5.6	
10	1701	1.09	792	863	8.0	7.6	74	Y	5.6	
11	1425	1.06	722	765	8.0	7.5	74	Y	6.2	
12	1517	1.12	743	832	8.2	7.5	61	Y	6.0	
13	2153	1.14	675	769	8.2	7.5	74	Y	6.6	
14	1239	1.10	795	875	8.1	7.5	74	Y	5.6	
15	1353	1.15	766	881	8.1	7.6	74	Y	5.8	
16	630	1.14	834	950	7.8	7.6	74	Y	5.3	
17	1547	1.17	821	961	7.9	7.5	74	Y	5.4	
18	1455	1.06	764	809	7.9	7.6	74	Y	5.8	
19	351	1.13	777	878	7.9	7.6	74	Y	5.7	
20	404	1.13	777	878	7.4	7.6	74	Y	5.7	
21	2328	1.21	780	943	7.8	7.6	76	Y	5.7	
22	1634	1.12	669	750	7.8	7.8	74	Y	6.7	
23	1240	1.15	751	863	7.8	7.7	74	Y	5.9	
24	1548	1.19	752	895	7.9	7.7	74	Y	5.9	
25	1808	1.20	805	966	8.0	7.6	74	Y	5.5	
26	1743	1.11	808	897	8.2	7.5	61	Y	5.5	
27	1443	1.08	823	889	8.3	7.5	74	Y	5.4	
28	1918	1.04	823	856	8.3	7.7	74	Y	5.4	

* Site: Line 2 Alt Flow Path at Aldersgate CT point, 7790 Marion Rd. SE. Turner, OR

Report Date: Mar 03, 2026




Chlorine/Turbidity/CT Summary Report

PWS ID#:	4100731	Sample Period:	February 2026
System Name:	<i>Salem Public Works Department</i>	Laboratory Results:	<i>Willow Lake Lab</i>
Address:	1410 20th St SE, Bldg 2 Salem OR 97302	OHD-Certified Lab	OR100010
Contact Person:	Dwayne Barnes, Utility Operations Manager	Date Report Issued:	3/3/2026
Contact Number:	503-588-6483	Contact Person:	Paul Mitchell
Source Water:	North Santiam River	Contact Number:	503-588-6380
Treatment Type:	Slow Sand Filtration	Sampler:	Treatment Operators
Sample Location:	Aldersgate and Geren Island	Sample Date:	As reported
		Source ID #:	EP-A and WTP-A

Summary Table

1. Turbidity	Were 95 percent of the turbidity readings less than or equal to 1.0 NTU for the month?	Yes
2. Turbidity	Were all turbidity readings less than or equal to 5.0 NTU for the month?	Yes
3. CT	Were all CTs values met each day of the month?	Yes
4. Chlorine	Were all entry point chlorine residuals readings greater than or equal to 0.2 mg/L for the month?	Yes
5. Chlorine	Was a detectable chlorine residual measured in at least 95% of the samples measured for the month?	Yes

Print Name: Dwayne Barnes, Utility Operations Manager

Signature: 

Date: March 4, 2026