

OHA - Drinking Water Services - Surface Water Quality Data Form

County: Clackamas

Conventional or Direct Filtration

Month/Year: Oct, 2025

System Name:	City of Sandy			ID#: 4100789			WTP: TP- Alder Creek
	12AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the day [NTU] *1
1	NF	0.050	0.040	0.040	NF	NF	0.050
2	NF	0.050	0.050	0.050	0.040	NF	0.050
3	NF	0.040	0.040	0.040	NF	0.040	0.040
4	0.040	0.160	0.040	0.040	0.040	0.050	0.160
5	0.040	NF	0.040	NF	NF	0.040	0.040
6	0.040	0.040	NF	NF	0.040	0.040	0.040
7	0.040	NF	0.040	0.040	NF	0.040	0.040
8	0.040	NF	0.040	NF	0.040	0.040	0.040
9	0.040	NF	NF	NF	NF	0.040	0.040
10	0.040	NF	0.040	0.050	NF	0.060	0.060
11	NF	0.050	NF	NF	0.050	NF	0.050
12	0.080	NF	0.060	0.070	NF	NF	0.080
13	NF	0.150	0.100	0.080	NF	0.060	0.150
14	0.060	NF	NF	NF	NF	0.050	0.060
15	NF	0.040	NF	NF	0.040	0.040	0.040
16	0.040	0.040	0.040	NF	0.040	NF	0.040
17	0.040	0.040	NF	NF	NF	NF	0.040
18	0.050	0.040	NF	NF	NF	NF	0.050
19	0.060	0.160	NF	0.140	NF	0.080	0.160
20	0.060	0.060	0.050	NF	0.060	0.050	0.060
21	0.040	0.040	NF	0.050	NF	0.050	0.050
22	0.040	0.040	NF	NF	NF	0.050	0.050
23	0.040	NF	0.040	NF	0.040	NF	0.040
24	0.040	0.040	NF	NF	0.070	0.070	0.070
25	0.060	0.050	NF	NF	NF	0.110	0.110
26	NF	0.180	NF	NF	0.090	0.100	0.180
27	NF	NF	NF	NF	0.060	NF	0.060
28	0.050	NF	NF	NF	0.050	0.050	0.050
29	0.060	NF	NF	0.130	0.080	0.070	0.130
30	NF	NF	0.120	0.060	0.060	0.060	0.120
31	NF	NF	NF	0.050	0.050	0.060	0.060

Slow Sand/Membrane/DE Filtration/Unfiltered

Monthly Summary (Answer Yes or No)

95% of 4-hour turbidity readings $\leq$ 0.3 NTU?	Yes / No	CT's met Everyday?	ALL CL2 residuals at Entry Point
All 4-hour turbidity readings $\leq$ 1 NTU?	Yes / No	(see back)	$\geq$ 0.2 mg/l?
All turbidity readings < IFE triggers *2	Yes / No	Yes / No	Yes / No

NOTES:

Printed Name:

Brian Hutchins

Signature



DATE:

11/5/2025

PHONE #:

503-572-3788

CERT#:

6660

*1 Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in columns 12 AM through 8 PM may not correspond to continuous readings' maximum. *2 IFE = Individ. Filter Effl. (333-061-0040(1)(e)(B&C))

OHA - Drinking Water Program - Surface Water Quality Data Form						WTP - : Alder Creek Plant		
System Name: City of Sandy Water System			ID#: 4100789 Month/Year: Oct, 2025		Disinfection		1.0	
Date / Time	Peak Flow	Minimum Cl ₂ Residual at 1st User (C) *3	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? *3
	GPM	[ppm or mg/L]	[minutes]	C X T	[° C]		formula	Yes / No
1	860	0.94	117.13	110.10	11.90	6.98	33.69	Yes
2	876	0.94	112.87	106.10	11.40	7.41	40.35	Yes
3	868	1.11	114.32	126.90	11.30	7.46	42.12	Yes
4	856	1.14	113.25	129.10	11.70	7.38	40.04	Yes
5	1,016	1.04	113.17	117.70	11.70	7.48	41.00	Yes
6	872	1.18	111.44	131.50	11.00	7.46	43.30	Yes
7	868	1.19	111.85	133.10	10.70	7.40	43.29	Yes
8	870	1.11	113.42	125.90	11.20	7.29	39.96	Yes
9	870	1.19	112.77	134.20	10.90	7.49	44.10	Yes
10	889	1.03	109.90	113.20	10.70	7.54	44.66	Yes
11	875	0.91	110.66	100.70	10.90	7.39	41.26	Yes
12	885	1.10	112.09	123.30	10.70	7.37	42.41	Yes
13	888	0.88	100.11	88.10	8.90	6.99	40.77	Yes
14	886	1.10	147.91	162.70	8.30	7.04	44.24	Yes
15	878	1.36	111.69	151.90	8.50	7.47	52.37	Yes
16	854	1.69	113.73	192.20	8.40	7.61	57.60	Yes
17	868	1.43	128.32	183.50	8.90	7.48	51.58	Yes
18	864	1.45	112.55	163.20	8.70	7.47	52.21	Yes
19	882	0.24	244.17	58.60	9.40	7.25	40.21	Yes
20	872	1.35	109.93	148.40	9.20	7.45	49.57	Yes
21	872	1.39	113.53	157.80	9.00	7.43	50.10	Yes
22	876	1.12	112.50	126.00	9.10	7.30	46.09	Yes
23	861	1.01	112.77	113.90	9.50	7.30	44.33	Yes
24	867	1.04	115.19	119.80	9.50	7.22	43.25	Yes
25	867	1.24	109.76	136.10	9.30	7.66	52.40	Yes
26	946	1.13	108.94	123.10	8.90	7.45	49.31	Yes
27	922	0.61	133.11	81.20	8.60	7.32	45.28	Yes
28	883	1.45	111.59	161.80	8.40	7.25	49.25	Yes
29	878	1.31	112.21	147.00	9.30	7.19	44.70	Yes
30	877	1.51	111.19	167.90	8.90	7.17	46.63	Yes
31	906	1.50	107.67	161.50	9.30	7.42	49.56	Yes