

## OHA - Drinking Water Services - Surface Water Quality Data Form


County: Clackamas

Conventional or Direct Filtration

Month/Year: Nov, 2025

| System Name: |               | City of Sandy |               | ID#: 4100789  |               | WTP: TP- Alder Creek |                                        |
|--------------|---------------|---------------|---------------|---------------|---------------|----------------------|----------------------------------------|
|              | 12AM<br>[NTU] | 4 AM<br>[NTU] | 8 AM<br>[NTU] | NOON<br>[NTU] | 4 PM<br>[NTU] | 8 PM<br>[NTU]        | Highest Reading of<br>the day [NTU] *1 |
| 1            | NF            | NF            | NF            | 0.200         | NF            | NF                   | 0.200                                  |
| 2            | 0.240         | NF            | NF            | 0.130         | 0.110         | 0.110                | 0.240                                  |
| 3            | 0.110         | NF            | 0.080         | 0.080         | 0.090         | 0.110                | 0.110                                  |
| 4            | NF            | NF            | 0.110         | NF            | 0.090         | 0.090                | 0.110                                  |
| 5            | 0.100         | NF            | 0.080         | 0.080         | 0.090         | 0.100                | 0.100                                  |
| 6            | 0.090         | NF            | 0.080         | NF            | 0.080         | 0.090                | 0.090                                  |
| 7            | NF            | NF            | 0.120         | NF            | 0.100         | NF                   | 0.120                                  |
| 8            | 0.090         | NF            | NF            | 0.080         | NF            | 0.080                | 0.090                                  |
| 9            | NF            | NF            | 0.090         | NF            | NF            | 0.080                | 0.090                                  |
| 10           | 0.080         | NF            | NF            | 0.080         | 0.080         | NF                   | 0.080                                  |
| 11           | 0.080         | NF            | 0.080         | NF            | NF            | 0.070                | 0.080                                  |
| 12           | NF            | NF            | NF            | 0.070         | 0.080         | NF                   | 0.080                                  |
| 13           | NF            | NF            | NF            | NF            | 0.090         | NF                   | 0.090                                  |
| 14           | 0.090         | NF            | NF            | NF            | 0.080         | NF                   | 0.090                                  |
| 15           | 0.070         | NF            | NF            | 0.080         | 0.080         | NF                   | 0.080                                  |
| 16           | 0.070         | NF            | NF            | 0.080         | 0.090         | NF                   | 0.090                                  |
| 17           | 0.080         | NF            | 0.080         | NF            | 0.090         | 0.080                | 0.090                                  |
| 18           | NF            | 0.070         | NF            | NF            | 0.070         | 0.070                | 0.070                                  |
| 19           | 0.070         | NF            | 0.060         | NF            | NF            | 0.070                | 0.070                                  |
| 20           | 0.070         | NF            | NF            | NF            | NF            | 0.070                | 0.070                                  |
| 21           | 0.060         | NF            | NF            | NF            | NF            | 0.060                | 0.060                                  |
| 22           | 0.060         | NF            | NF            | NF            | NF            | 0.060                | 0.060                                  |
| 23           | 0.060         | NF            | 0.060         | NF            | NF            | 0.230                | 0.230                                  |
| 24           | NF            | NF            | 0.110         | 0.090         | NF            | 0.080                | 0.110                                  |
| 25           | 0.080         | 0.070         | 0.070         | 0.070         | 0.070         | 0.080                | 0.080                                  |
| 26           | 0.090         | 0.190         | NF            | 0.150         | 0.150         | 0.220                | 0.220                                  |
| 27           | NF            | 0.160         | NF            | NF            | 0.140         | NF                   | 0.160                                  |
| 28           | 0.120         | NF            | 0.110         | NF            | NF            | 0.100                | 0.120                                  |
| 29           | NF            | 0.080         | NF            | NF            | NF            | 0.080                | 0.080                                  |
| 30           | 0.080         | NF            | 0.080         | NF            | NF            | 0.080                | 0.080                                  |
| 31           |               |               |               |               |               |                      |                                        |

| Slow Sand/Membrane/DE Filtration/Unfiltered                                                                      | Monthly Summary (Answer Yes or No)                                                                  |                                                                                                                         |
|------------------------------------------------------------------------------------------------------------------|-----------------------------------------------------------------------------------------------------|-------------------------------------------------------------------------------------------------------------------------|
| 95% of 4-hour turbidity readings $\leq$ 0.3 NTU? <input checked="" type="radio"/> Yes / <input type="radio"/> No | CT's met Everyday?<br>(see back)<br><input checked="" type="radio"/> Yes / <input type="radio"/> No | ALL CL2 residuals at Entry Point<br>$\geq$ 0.2 mg/l?<br><input checked="" type="radio"/> Yes / <input type="radio"/> No |
| All 4-hour turbidity readings $\leq$ 1 NTU? <input checked="" type="radio"/> Yes / <input type="radio"/> No      |                                                                                                     |                                                                                                                         |
| All turbidity readings < IFE triggers *2 <input checked="" type="radio"/> Yes / <input type="radio"/> No         |                                                                                                     |                                                                                                                         |

|        |                                                                                                 |                 |
|--------|-------------------------------------------------------------------------------------------------|-----------------|
| NOTES: | Printed Name: Brian Hutchins                                                                    |                 |
|        | Signature:  | DATE: 11/3/2025 |
|        | PHONE #: 503-572-3788                                                                           | CERT#: 6660     |

\*1 Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in columns 12 AM through 8 PM may not correspond to continuous readings' maximum. \*2 IFE = Individ. Filter Effl. (333-061-0040(1)(e)(B&C))

| OHA - Drinking Water Program - Surface Water Quality Data Form |           |                                                     |                  |             |       | WTP - : Alder Creek Plant |             |              |
|----------------------------------------------------------------|-----------|-----------------------------------------------------|------------------|-------------|-------|---------------------------|-------------|--------------|
| System Name City of Sandy Water System                         |           |                                                     |                  | ID#: 410078 |       | Month/Year: Nov, 2025     |             | Disinfection |
|                                                                |           |                                                     |                  |             |       |                           |             | 1.0          |
| Date / Time                                                    | Peak Flow | Minimum Cl <sub>2</sub> Residual at 1st User (C) *3 | Contact Time (T) | Actual CT   | Temp  | pH                        | Required CT | CT Met? *3   |
|                                                                | GPM       | [ppm or mg/L]                                       | [minutes]        | C X T       | [° C] |                           | formula     | Yes / No     |
| 1                                                              | 901       | 0.28                                                | 352.86           | 98.80       | 10.00 | 7.27                      | 39.11       | Yes          |
| 2                                                              | 914       | 1.28                                                | 110.23           | 141.10      | 10.70 | 6.99                      | 37.91       | Yes          |
| 3                                                              | 862       | 0.88                                                | 115.80           | 101.90      | 10.30 | 7.13                      | 39.06       | Yes          |
| 4                                                              | 892       | 0.71                                                | 110.70           | 78.60       | 9.80  | 7.10                      | 39.19       | Yes          |
| 5                                                              | 888       | 1.06                                                | 110.38           | 117.00      | 10.00 | 6.98                      | 38.58       | Yes          |
| 6                                                              | 911       | 0.45                                                | 219.11           | 98.60       | 10.50 | 6.89                      | 33.86       | Yes          |
| 7                                                              | 902       | 0.91                                                | 106.92           | 97.30       | 10.00 | 7.25                      | 41.68       | Yes          |
| 8                                                              | 911       | 1.24                                                | 106.45           | 132.00      | 10.20 | 6.92                      | 38.06       | Yes          |
| 9                                                              | 899       | 1.33                                                | 112.03           | 149.00      | 9.50  | 7.28                      | 45.64       | Yes          |
| 10                                                             | 892       | 1.42                                                | 110.99           | 157.60      | 10.20 | 6.85                      | 37.90       | Yes          |
| 11                                                             | 884       | 1.33                                                | 112.78           | 150.00      | 10.50 | 6.78                      | 35.92       | Yes          |
| 12                                                             | 897       | 1.31                                                | 108.17           | 141.70      | 10.20 | 7.10                      | 40.83       | Yes          |
| 13                                                             | 885       | 1.34                                                | 111.57           | 149.50      | 11.10 | 7.22                      | 40.27       | Yes          |
| 14                                                             | 893       | 1.31                                                | 107.56           | 140.90      | 10.40 | 7.10                      | 40.30       | Yes          |
| 15                                                             | 893       | 1.24                                                | 109.44           | 135.70      | 10.60 | 7.33                      | 42.76       | Yes          |
| 16                                                             | 878       | 1.23                                                | 106.99           | 131.60      | 11.30 | 7.19                      | 38.86       | Yes          |
| 17                                                             | 904       | 1.17                                                | 108.03           | 126.40      | 10.70 | 7.27                      | 41.27       | Yes          |
| 18                                                             | 828       | 1.13                                                | 110.35           | 124.70      | 10.00 | 7.12                      | 40.82       | Yes          |
| 19                                                             | 960       | 1.29                                                | 107.52           | 138.70      | 8.80  | 7.07                      | 44.19       | Yes          |
| 20                                                             | 900       | 1.30                                                | 107.46           | 139.70      | 8.70  | 7.06                      | 44.38       | Yes          |
| 21                                                             | 941       | 1.28                                                | 103.59           | 132.60      | 7.50  | 7.35                      | 53.17       | Yes          |
| 22                                                             | 892       | 1.12                                                | 117.95           | 132.10      | 7.50  | 7.14                      | 48.44       | Yes          |
| 23                                                             | 888       | 0.88                                                | 122.05           | 107.40      | 7.70  | 7.32                      | 49.57       | Yes          |
| 24                                                             | 981       | 1.08                                                | 122.59           | 132.40      | 8.90  | 7.16                      | 44.25       | Yes          |
| 25                                                             | 892       | 1.86                                                | 107.80           | 200.50      | 8.70  | 7.32                      | 51.87       | Yes          |
| 26                                                             | 914       | 1.49                                                | 110.07           | 164.00      | 9.20  | 7.14                      | 45.13       | Yes          |
| 27                                                             | 1,020     | 0.77                                                | 102.08           | 78.60       | 14.10 | 7.38                      | 32.44       | Yes          |
| 28                                                             | 1,006     | 0.73                                                | 119.04           | 86.90       | 9.70  | 7.07                      | 39.12       | Yes          |
| 29                                                             | 895       | 0.73                                                | 107.12           | 78.20       | 9.40  | 6.99                      | 38.80       | Yes          |
| 30                                                             | 907       | 0.93                                                | 107.42           | 99.90       | 8.40  | 7.19                      | 45.45       | Yes          |
|                                                                |           |                                                     |                  |             |       |                           |             |              |

\*3 If Cl<sub>2</sub> at entry point < 0.2 mg/l or CT not met, notify DWS within 24 hours.

Revised February 2016