

OHA - Drinking Water Services - Surface Water Quality Data Form

County: Clackamas

Conventional or Direct Filtration

Month/Year: Jan, 2026

System Name:	City of Sandy			ID#: 4100789	EP-A	WTP: TP- Alder Creek	
	12AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the day [NTU] *1
1	0.050	NF	NF	0.060	NF	0.090	0.090
2	NF	0.120	NF	NF	NF	0.190	0.190
3	NF	0.090	NF	NF	0.030	0.050	0.090
4	NF	0.100	NF	NF	0.100	0.120	0.120
5	NF	NF	NF	NF	NF	0.160	0.160
6	0.150	NF	0.270	NF	0.130	NF	0.270
7	NF	NF	0.090	NF	0.100	NF	0.100
8	0.130	NF	0.090	NF	0.060	NF	0.130
9	0.100	NF	0.060	NF	0.040	NF	0.100
10	NF	NF	0.050	0.100	0.100	0.110	0.110
11	NF	0.100	NF	0.100	NF	0.100	0.100
12	NF	0.090	NF	0.100	NF	0.100	0.100
13	0.100	NF	NF	0.100	NF	NF	0.100
14	0.100	NF	NF	0.110	NF	NF	0.110
15	NF	0.110	NF	NF	0.110	NF	0.110
16	0.120	0.120	NF	0.130	NF	NF	0.130
17	0.120	0.110	NF	NF	NF	NF	0.120
18	0.090	0.090	NF	NF	NF	NF	0.090
19	0.100	NF	NF	0.090	NF	0.100	0.100
20	0.100	0.090	NF	NF	NF	NF	0.100
21	0.090	0.090	NF	NF	NF	NF	0.090
22	0.090	0.090	0.110	NF	0.090	NF	0.110
23	0.090	0.090	NF	NF	NF	NF	0.090
24	0.090	0.090	NF	NF	NF	NF	0.090
25	0.090	0.090	NF	NF	NF	NF	0.090
26	0.090	0.090	NF	NF	NF	NF	0.090
27	0.090	0.090	NF	NF	NF	NF	0.090
28	0.090	NF	NF	NF	0.010	NF	0.090
29	0.020	NF	NF	NF	0.130	NF	0.130
30	0.120	NF	NF	NF	NF	0.110	0.120
31	NF	0.110	0.110	NF	0.110	0.100	0.110

Slow Sand/Membrane/DE Filtration/Unfiltered	Monthly Summary (Answer Yes or No)	
95% of 4-hour turbidity readings ≤ 0.3 NTU? Yes / No	CT's met Everyday? Yes / No	ALL CL2 residuals at Entry Point ≥ 0.2 mg/l? Yes / No
All 4-hour turbidity readings ≤ 1 NTU? Yes / No	(see back)	
All turbidity readings < IFE triggers *2 Yes / No		

NOTES:

Printed Name: Brian Hutchins

Signature: [Signature]

PHONE #: (503) 572-3788

DATE: 2/3/2026

CERT#: 6660

*1 Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in columns 12 AM through 8 PM may not correspond to continuous readings' maximum. *2 IFE = Individ. Filter Effl. (333-061-0040(1)(e)(B&C))

OHA - Drinking Water Program - Surface Water Quality Data Form

WTP - : Alder Creek Plant *EPA*

System Name: City of Sandy Water System

ID#: 4100789 Month/Year: Jan, 2026

Disinfection

1.0

Date / Time	Peak Flow	Minimum Cl2 Residual at 1st User (C) *3	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? *3
	GPM	[ppm or mg/L]	[minutes]	C X T	[° C]		formula	Yes / No
1	886	1.29	106.98	138.00	10.10	7.21	42.61	Yes
2	887	1.19	108.91	129.60	10.50	7.24	41.48	Yes
3	878	1.28	107.50	137.60	11.40	7.01	36.48	Yes
4	877	1.21	109.26	132.20	9.10	7.29	46.40	Yes
5	907	1.25	108.00	135.00	10.70	7.37	43.13	Yes
6	933	1.30	107.38	139.60	6.70	7.49	59.15	Yes
7	945	1.27	108.03	137.20	8.40	7.16	46.74	Yes
8	888	1.37	106.79	146.30	7.70	7.35	53.00	Yes
9	867	1.29	108.37	139.80	9.10	7.07	43.33	Yes
10	948	1.14	110.35	125.80	8.40	7.10	45.09	Yes
11	920	1.16	105.34	122.20	9.80	7.10	41.21	Yes
12	930	1.18	106.69	125.90	7.80	7.23	49.36	Yes
13	935	1.27	107.32	136.30	7.70	7.29	51.29	Yes
14	947	1.28	106.17	135.90	9.60	7.18	43.53	Yes
15	890	1.27	108.82	138.20	8.70	7.41	50.06	Yes
16	889	1.27	107.01	135.90	9.10	7.33	47.38	Yes
17	886	1.20	107.83	129.40	9.70	7.19	43.00	Yes
18	880	1.21	108.43	131.20	8.90	7.13	44.44	Yes
19	888	1.23	109.43	134.60	7.50	7.02	47.00	Yes
20	895	1.19	108.07	128.60	8.30	7.40	50.77	Yes
21	960	1.22	106.97	130.50	6.60	7.38	56.71	Yes
22	962	1.13	108.58	122.70	7.00	7.28	52.71	Yes
23	948	1.25	109.20	136.50	7.10	7.20	51.58	Yes
24	956	1.26	110.56	139.30	5.60	7.10	55.11	Yes
25	941	1.22	110.00	134.20	6.80	7.38	55.95	Yes
26	873	1.25	110.00	137.50	5.70	7.48	62.71	Yes
27	876	1.24	110.65	137.20	6.70	7.60	61.12	Yes
28	851	1.53	148.04	226.50	6.30	7.38	59.99	Yes
29	880	1.23	108.78	133.80	8.70	7.32	48.27	Yes
30	886	0.61	155.74	95.00	7.80	7.13	44.65	Yes
31	880	1.18	107.80	127.20	10.40	7.31	42.74	Yes

*3 If Cl2 at entry point < 0.2 mg/l or CT not met, notify DWS within 24 hours.

Revised February 2016