

OHA - Drinking Water Services - Surface Water Quality Data Form

County: Clackamas

Conventional or Direct Filtration

Month/Year: Feb, 2026

System Name:	City of Sandy			ID#: 4100789			WTP: TP- Alder Creek
	12AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the day [NTU] *1
1	0.100	NF	NF	NF	0.170	NF	0.170
2	0.110	NF	NF	NF	0.110	0.110	0.110
3	0.110	NF	0.110	NF	NF	0.110	0.110
4	NF	0.110	NF	NF	NF	NF	0.110
5	0.110	NF	NF	NF	0.110	NF	0.110
6	0.110	NF	0.110	NF	NF	0.040	0.110
7	NF	0.040	NF	NF	0.100	NF	0.100
8	0.110	NF	NF	NF	0.170	NF	0.170
9	NF	NF	NF	0.100	NF	0.070	0.100
10	NF	NF	0.060	NF	NF	0.060	0.060
11	NF	NF	0.050	0.050	NF	0.050	0.050
12	NF	NF	NF	NF	0.050	NF	0.050
13	0.040	NF	NF	NF	0.050	0.050	0.050
14	NF	NF	0.060	NF	NF	0.050	0.060
15	NF	0.050	NF	NF	0.050	NF	0.050
16	0.050	NF	NF	NF	0.050	NF	0.050
17	0.050	NF	0.050	NF	NF	0.040	0.050
18	NF	0.040	NF	NF	0.050	NF	0.050
19	0.040	NF	NF	0.050	NF	0.040	0.050
20	NF	NF	NF	NF	NF	0.050	0.050
21	NF	0.040	NF	NF	0.050	NF	0.050
22	NF	NF	NF	NF	0.050	NF	0.050
23	0.040	NF	NF	0.080	NF	NF	0.080
24	NF	NF	NF	0.200	0.080	0.100	0.200
25	0.130	NF	NF	NF	0.130	0.160	0.160
26	0.170	0.160	0.190	NF	NF	0.120	0.190
27	NF	NF	NF	NF	NF	0.090	0.090
28	0.090	NF	NF	NF	0.100	0.090	0.100
29							
30							
31							

Slow Sand/Membrane/DE Filtration/Unfiltered	Monthly Summary (Answer Yes or No)	
95% of 4-hour turbidity readings ≤ 0.3 NTU? Yes / No	CT's met Everyday? (see back) Yes / No	ALL CL2 residuals at Entry Point ≥ 0.2 mg/l? Yes / No
All 4-hour turbidity readings ≤ 1 NTU? Yes / No		
All turbidity readings < IFE triggers *2 Yes / No		
NOTES:	Printed Name: <i>Brian Hutchins</i>	DATE: <i>3/2/2026</i>
	Signature: <i>[Signature]</i>	CERT#: <i>6660</i>
	PHONE #: <i>503-572-3788</i>	

*1 Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in columns 12 AM through 8 PM may not correspond to continuous readings' maximum. *2 IFE = Individ. Filter Effl. (333-061-0040(1)(e)(B&C))

OHA - Drinking Water Program - Surface Water Quality Data Form

WTP - : Alder Creek Plant

System Name: City of Sandy Water System

ID#: 4100789 Month/Year: Feb, 2026

Disinfection

1.0

Date / Time	Peak Flow	Minimum Cl2 Residual at 1st User (C) *3	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? *3
	GPM	[ppm or mg/L]	[minutes]	C X T	[° C]		formula	Yes / No
1	872	1.14	110.18	125.60	9.50	7.35	45.79	Yes
2	886	1.22	108.28	132.10	9.30	7.50	49.38	Yes
3	877	1.30	110.23	143.30	8.50	7.33	49.48	Yes
4	876	1.35	108.07	145.90	8.80	7.42	50.37	Yes
5	840	1.37	108.98	149.30	10.10	7.23	43.30	Yes
6	876	1.20	110.67	132.80	9.00	7.31	46.99	Yes
7	891	1.13	105.75	119.50	10.00	7.16	41.40	Yes
8	896	0.99	109.09	108.00	10.40	7.42	43.48	Yes
9	906	1.26	106.35	134.00	12.00	7.28	38.43	Yes
10	901	1.53	106.80	163.40	8.50	7.50	53.99	Yes
11	892	1.36	107.65	146.40	8.10	7.44	53.23	Yes
12	937	1.38	105.58	145.70	9.10	7.23	46.31	Yes
13	884	1.35	107.11	144.60	9.90	7.15	42.56	Yes
14	871	1.34	108.13	144.90	8.00	7.28	50.49	Yes
15	881	1.29	108.37	139.80	9.60	7.18	43.58	Yes
16	936	1.32	108.33	143.00	10.40	7.42	45.13	Yes
17	932	1.32	107.80	142.30	8.10	7.36	51.49	Yes
18	932	1.23	107.40	132.10	8.50	7.36	49.62	Yes
19	954	1.21	105.54	127.70	8.70	7.37	49.02	Yes
20	973	1.37	104.96	143.80	6.70	7.30	55.69	Yes
21	930	1.34	104.78	140.40	7.10	7.39	55.79	Yes
22	888	1.31	105.95	138.80	8.10	7.27	49.81	Yes
23	883	0.98	267.45	262.10	8.90	7.28	45.64	Yes
24	651	1.04	151.25	157.30	9.40	7.18	42.93	Yes
25	644	1.19	275.04	327.30	9.10	7.19	44.69	Yes
26	901	0.48	213.33	102.40	8.60	7.34	44.94	Yes
27	939	1.43	106.01	151.60	8.80	7.32	49.05	Yes
28	898	1.46	105.55	154.10	8.20	7.41	52.91	Yes

*3 If Cl2 at entry point < 0.2 mg/l or CT not met, notify DWS within 24 hours.

Revised February 2016