

OHA - Drinking Water Services - Surface Water Quality Data Form

County: Clackamas

Conventional or Direct Filtration

Month/Year: Mar, 2026

System Name:	City of Sandy			ID#: 4100789	WTP: TP- Alder Creek		
	12AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the day [NTU] *1
1	0.090	NF	NF	NF	0.080	0.090	0.090
2	NF	NF	NF	0.060	0.010	NF	0.060
3	0.020	NF	0.040	0.080	NF	0.070	0.080
4	NF	NF	0.090	NF	NF	0.110	0.110
5	NF	0.130	NF	NF	0.170	NF	0.170
6	0.020	NF	NF	NF	0.040	NF	0.040
7	0.030	NF	NF	NF	0.040	NF	0.040
8	NF	NF	NF	NF	0.070	NF	0.070
9	0.150	NF	0.130	NF	NF	NF	0.150
10	0.060	NF	NF	NF	NF	0.030	0.060
11	NF	0.040	NF	NF	0.030	NF	0.040
12	0.060	NF	NF	NF	0.300	NF	0.300
13	0.260	NF	NF	0.070	NF	0.130	0.260
14	NF	NF	NF	0.020	0.040	NF	0.040
15	0.080	NF	NF	0.070	NF	0.180	0.180
16	0.170	NF	NF	0.050	NF	NF	0.170
17	0.120	NF	NF	NF	NF	NF	0.120
18	0.130	NF	NF	NF	0.060	NF	0.130
19	0.070	NF	NF	0.030	0.030	NF	0.070
20	0.070	NF	NF	NF	0.040	NF	0.070
21	0.090	NF	NF	0.080	NF	0.100	0.100
22	NF	NF	NF	0.110	NF	0.110	0.110
23	NF	NF	NF	0.110	NF	0.100	0.110
24	NF	NF	NF	NF	NF	0.120	0.120
25	NF	0.130	NF	0.040	0.040	0.070	0.130
26	NF	0.110	NF	0.020	0.020	NF	0.110
27	0.040	NF	NF	0.040	0.050	0.040	0.050
28	NF	NF	NF	0.030	NF	0.030	0.030
29	0.030	NF	NF	0.040	NF	0.050	0.050
30	0.070	NF	NF	0.050	NF	0.030	0.070
31	0.040	NF	NF	NF	0.050	NF	0.050

Slow Sand/Membrane/DE Filtration/Unfiltered	Monthly Summary (Answer Yes or No)	
95% of 4-hour turbidity readings ≤ 0.3 NTU? Yes / No	CT's met Everyday? (see back) Yes / No	ALL CL2 residuals at Entry Point ≥ 0.2 mg/l? Yes / No
All 4-hour turbidity readings ≤ 1 NTU? Yes / No		
All turbidity readings < IFE triggers *2 Yes / No		

NOTES:	Printed Name: Brian Hutchins	DATE: 4/2/26
	Signature: <i>[Signature]</i>	CERT#: 6660
	PHONE #: (503) 572-3780	

*1 Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in columns 12 AM through 8 PM may not correspond to continuous readings' maximum. *2 IFE = Individ. Filter Effl. (333-061-0040(1)(e)(B&C))

OHA - Drinking Water Program - Surface Water Quality Data Form

WTP - : Alder Creek Plant

System Name: City of Sandy Water System

ID#: 4100789 Month/Year: Mar, 2026

Disinfection

1.0

Date / Time	Peak Flow	Minimum Cl ₂ Residual at 1st User (C) *3	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? *3
	GPM	[ppm or mg/L]	[minutes]	C X T	[° C]		formula	Yes / No
1	900	1.44	107.50	154.80	8.90	7.44	50.91	Yes
2	686	1.21	149.42	180.80	10.00	7.29	43.72	Yes
3	888	1.31	107.10	140.30	9.10	7.25	46.27	Yes
4	969	1.11	109.19	121.20	9.30	7.34	46.08	Yes
5	988	1.10	107.91	118.70	9.30	7.37	46.52	Yes
6	884	1.38	109.93	151.70	10.00	7.19	43.03	Yes
7	892	1.26	107.62	135.60	10.10	7.12	41.15	Yes
8	882	1.33	107.22	142.60	11.60	7.18	38.40	Yes
9	882	1.40	107.64	150.70	8.70	7.18	46.83	Yes
10	892	1.40	107.29	150.20	7.50	7.30	52.95	Yes
11	886	1.27	105.43	133.90	8.20	7.28	49.42	Yes
12	888	1.40	105.36	147.50	9.00	7.17	45.74	Yes
13	881	1.59	108.55	172.60	8.90	7.12	46.23	Yes
14	952	1.21	106.03	128.30	10.10	7.22	42.38	Yes
15	903	1.27	104.57	132.80	8.00	7.15	47.83	Yes
16	894	1.37	108.91	149.20	8.50	7.45	52.06	Yes
17	897	1.11	106.04	117.70	8.80	7.36	47.97	Yes
18	964	0.65	132.92	86.40	9.10	7.25	42.94	Yes
19	881	1.25	109.92	137.40	11.80	7.15	37.19	Yes
20	886	1.34	108.73	145.70	9.70	7.25	44.62	Yes
21	882	1.31	107.33	140.60	10.00	7.34	45.00	Yes
22	886	1.33	106.54	141.70	9.80	7.40	46.68	Yes
23	894	1.30	108.77	141.40	8.20	7.35	50.85	Yes
24	893	1.25	109.20	136.50	8.60	7.56	53.05	Yes
25	874	1.18	109.07	128.70	10.30	7.42	44.71	Yes
26	745	1.36	145.74	198.20	10.10	7.31	44.48	Yes
27	735	0.25	192.00	48.00	10.20	7.14	36.79	Yes
28	683	1.43	142.24	203.40	10.10	7.08	41.36	Yes
29	694	1.29	142.02	183.20	10.30	7.18	41.62	Yes
30	719	1.41	145.89	205.70	8.70	7.17	46.72	Yes
31	691	1.61	143.23	230.60	9.40	7.25	46.93	Yes

*3 If Cl₂ at entry point < 0.2 mg/l or CT not met, notify DWS within 24 hours.

Revised February 2016