

OHA - Drinking Water Services - Surface Water Quality Data Form


Slow Sand, Membrane, Diatomaceous Earth Filtration, or Unfiltered Systems

County:

Clackamas

Month/Year:

Dec, 2024

System Name: City of Sandy		ID#: 4100789C		WTP: TP- Bull Run	
Slow Sand/Membrane/DE Filtration/Unfiltered			Monthly Summary (Answer Yes or No)		
95% of daily turbidity readings \leq 1 NTU? *2		Yes / No		CT's met Everyday? (see back)	
All daily turbidity readings \leq 5 NTU?		Yes / No		ALL CL2 residuals at Entry Point \geq 0.2 mg/l?	
NOTES: PWB Turbidity Reported by PWB		Printed Name: Mike Greene		Signature: 	
		PHONE #: (503) 807-5241		DATE: 12/16/25	
				CERT#: 2097	

OHA - Drinking Water Program - Surface Water Quality Data Form

WTP:- Bull Run

System Name:	City of Sandy	ID#: 4100789 C	Month/Yea: Dec / 2024	Disinfection Giardia Log Inactiv:	3
--------------	---------------	----------------	-----------------------	---	---

Date / Time	CT Headworks to Larsen					CT Larsen to Hudson					Temp	Required CT	CT Met? *3	Combined Inactivation
	pH	Minimum Cl2 Residual	Contact Time (T)	Actual CT	Required CT	pH	Minimum Cl2 Residual	Contact Time (T)	Actual CT	Required CT				
		[ppm or mg/L]	[minutes]	C X T	formula		[ppm or mg/L]	[minutes]	C X T	formula				
1	6.52	2.74	67.92	186.09	143.77	6.52	2.56	102.69	262.88	140.85	7.13	284.62	Yes	3.16
2	6.51	2.78	68.69	190.96	144.11	6.51	2.59	103.88	269.05	141.02	7.11	285.13	Yes	3.23
3	6.52	2.79	63.14	176.17	146.53	6.52	2.64	95.43	251.93	144.04	6.93	290.57	Yes	2.95
4	6.53	2.76	63.11	174.19	148.02	6.53	2.58	95.45	246.25	145.01	6.78	293.03	Yes	2.87
5	6.54	2.84	63.19	179.45	151.73	6.54	2.59	95.60	247.59	147.45	6.60	299.18	Yes	2.86
6	6.54	2.86	63.19	180.71	152.69	6.54	2.62	95.58	250.42	148.55	6.54	301.24	Yes	2.87
7	6.54	2.84	62.93	178.72	153.77	6.54	2.61	95.06	248.11	149.78	6.40	303.55	Yes	2.82
8	6.53	2.80	63.40	177.52	154.48	6.53	2.61	95.87	250.21	151.15	6.21	305.63	Yes	2.80
9	6.53	2.77	63.23	175.14	154.36	6.53	2.59	95.51	247.38	151.21	6.17	305.57	Yes	2.77
10	6.53	2.76	63.44	175.10	153.05	6.53	2.57	95.88	246.42	149.76	6.28	302.81	Yes	2.79
11	6.54	2.82	63.56	179.24	155.49	6.54	2.53	96.17	243.31	150.41	6.20	305.90	Yes	2.77
12	6.55	2.78	63.38	176.19	155.96	6.55	2.59	95.87	248.29	152.60	6.14	308.56	Yes	2.76
13	6.53	2.87	65.80	188.85	158.25	6.53	2.67	99.41	265.43	154.66	5.97	312.91	Yes	2.91
14	6.53	2.86	66.54	190.30	158.71	6.53	2.62	100.73	263.92	154.39	5.91	313.10	Yes	2.91
15	6.53	2.84	61.56	174.84	159.09	6.53	2.65	93.10	246.71	155.65	5.84	314.74	Yes	2.68
16	6.53	2.83	61.44	173.88	159.01	6.53	2.66	92.96	247.27	155.94	5.83	314.95	Yes	2.68
17	6.54	2.80	58.17	162.87	158.71	6.54	2.62	88.04	230.65	155.47	5.86	314.18	Yes	2.51
18	6.53	2.69	58.94	158.55	156.48	6.53	2.69	88.95	239.29	156.48	5.83	312.95	Yes	2.54
19	6.50	2.81	65.48	183.99	154.97	6.50	2.60	98.98	257.34	151.28	6.02	306.25	Yes	2.89
20	6.50	2.80	65.49	183.37	154.69	6.50	2.60	98.91	257.16	151.18	6.03	305.87	Yes	2.89
21	6.51	2.80	65.72	184.01	154.41	6.51	2.61	99.21	258.95	151.08	6.11	305.50	Yes	2.91
22	6.52	2.76	65.52	180.84	154.67	6.52	2.58	99.19	255.92	151.51	6.07	306.18	Yes	2.86
23	6.51	2.77	64.79	179.45	153.06	6.51	2.62	98.00	256.76	150.45	6.19	303.51	Yes	2.88
24	6.51	2.72	64.48	175.39	151.57	6.51	2.55	97.37	248.30	148.65	6.25	300.23	Yes	2.83
25	6.50	2.76	68.69	189.59	152.34	6.50	2.62	103.90	272.22	149.92	6.19	302.26	Yes	3.06
26	6.53	2.68	68.62	183.89	150.65	6.53	2.52	103.74	261.43	147.91	6.38	298.56	Yes	2.99
27	6.49	2.72	75.51	205.38	150.40	6.49	2.61	114.26	298.22	148.52	6.26	298.91	Yes	3.37
28	6.48	2.68	75.48	202.27	149.78	6.48	2.58	114.28	294.85	148.08	6.20	297.85	Yes	3.34
29	6.48	2.69	75.55	203.23	149.15	6.48	2.59	114.19	295.74	147.46	6.28	296.61	Yes	3.37
30	6.47	2.63	61.77	162.44	147.31	6.47	2.59	93.37	241.83	146.64	6.31	293.95	Yes	2.75
31	6.47	2.63	61.78	162.47	147.31	6.47	2.57	93.34	239.88	146.30	6.31	293.61	Yes	2.74

*3 If Cl2 at entry point < 0.2 mg/l or CT not met, notify DWS within 24 hours.